

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



#	TIME	Testing Start	Sync	Total Voltage	ToltaL Current	Discharging Energy(Ah)
1	2021-08-30 14:24:13	00:00:01	00:00:00	53.821	0	0
2	2021-08-30 14:24:23	00:00:10	00:00:00	53.821	0	0
3	2021-08-30 14:24:32	00:00:19	00:00:09	53.821	0	0
4	2021-08-30 14:24:33	00:00:20	00:00:00	49.463	-180.024	0.0157
5	2021-08-30 14:24:34	00:00:21	00:00:01	49.379	-180.068	0.0658
6	2021-08-30 14:24:35	00:00:22	00:00:02	49.26	-180.029	0.0908
7	2021-08-30 14:24:36	00:00:23	00:00:03	49.131	-180.089	0.1659
8	2021-08-30 14:24:37	00:00:24	00:00:04	49.005	-180.091	0.2159
9	2021-08-30 14:24:38	00:00:25	00:00:05	48.884	-180	0.2659
10	2021-08-30 14:24:39	00:00:26	00:00:06	48.827	-180.02	0.3159
11	2021-08-30 14:24:40	00:00:27	00:00:07	48.72	-180.054	0.366
12	2021-08-30 14:24:41	00:00:28	00:00:08	48.623	-180.092	0.416
13	2021-08-30 14:24:42	00:00:29	00:00:09	48.535	-180.053	0.466
14	2021-08-30 14:24:43	00:00:30	00:00:10	48.455	-180.079	0.516
15	2021-08-30 14:24:44	00:00:31	00:00:11	48.383	-180.051	0.566
16	2021-08-30 14:24:45	00:00:32	00:00:12	48.317	-180.012	0.616
17	2021-08-30 14:24:46	00:00:33	00:00:13	48.257	-180.063	0.666
18	2021-08-30 14:24:47	00:00:34	00:00:14	48.203	-180.004	0.7161
19	2021-08-30 14:24:48	00:00:35	00:00:15	48.131	-179.964	0.766
20	2021-08-30 14:24:49	00:00:36	00:00:16	48.088	-180.028	0.8161
21	2021-08-30 14:24:50	00:00:37	00:00:17	48.051	-180.06	0.8411
22	2021-08-30 14:24:51	00:00:38	00:00:18	48.015	-180.035	0.9161
23	2021-08-30 14:24:52	00:00:39	00:00:19	47.981	-180.064	0.9661
24	2021-08-30 14:24:53	00:00:40	00:00:00	47.965	-180.025	1.0137
25	2021-08-30 14:24:54	00:00:41	00:00:01	51.889	0	1.0137
26	2021-08-30 14:24:55	00:00:42	00:00:02	51.938	0	1.0137
27	2021-08-30 14:24:56	00:00:43	00:00:03	51.992	0	1.0137
28	2021-08-30 14:24:57	00:00:44	00:00:04	52.046	0	1.0137
29	2021-08-30 14:24:58	00:00:45	00:00:05	52.097	0	1.0137
30	2021-08-30 14:24:59	00:00:46	00:00:06	52.146	0	1.0137
31	2021-08-30 14:25:00	00:00:47	00:00:07	52.191	0	1.0137
32	2021-08-30 14:25:01	00:00:48	00:00:08	52.232	0	1.0137
33	2021-08-30 14:25:02	00:00:49	00:00:09	52.289	0	1.0137
34	2021-08-30 14:25:03	00:00:50	00:00:10	52.323	0	1.0137
35	2021-08-30 14:25:04	00:00:51	00:00:11	52.354	0	1.0137
36	2021-08-30 14:25:05	00:00:53	00:00:12	52.382	0	1.0137
37	2021-08-30 14:25:06	00:00:53	00:00:13	52.409	0	1.0137
38	2021-08-30 14:25:07	00:00:55	00:00:14	52.433	0	1.0137
39	2021-08-30 14:25:08	00:00:55	00:00:15	52.445	0	1.0137
40	2021-08-30 14:25:09	00:00:57	00:00:16	52.467	0	1.0137
41	2021-08-30 14:25:10	00:00:57	00:00:17	52.488	0	1.0137
42	2021-08-30 14:25:11	00:00:59	00:00:18	52.508	0	1.0137
43	2021-08-30 14:25:12	00:00:59	00:00:19	52.528	0	1.0137
44	2021-08-30 14:25:13	00:01:01	00:00:20	52.546	0	1.0137
45	2021-08-30 14:25:14	00:01:01	00:00:21	52.562	0	1.0137
46	2021-08-30 14:25:15	00:01:03	00:00:22	52.578	0	1.0137
47	2021-08-30 14:25:16	00:01:03	00:00:23	52.594	0	1.0137
48	2021-08-30 14:25:17	00:01:05	00:00:24	52.615	0	1.0137
49	2021-08-30 14:25:18	00:01:05	00:00:25	52.628	0	1.0137
50	2021-08-30 14:25:19	00:01:07	00:00:26	52.641	0	1.0137
51	2021-08-30 14:25:20	00:01:07	00:00:27	52.653	0	1.0137
52	2021-08-30 14:25:21	00:01:09	00:00:28	52.665	0	1.0137
53	2021-08-30 14:25:22	00:01:09	00:00:29	52.677	0	1.0137
54	2021-08-30 14:25:23	00:01:11	00:00:30	52.689	0	1.0137
55	2021-08-30 14:25:24	00:01:11	00:00:31	52.704	0	1.0137
56	2021-08-30 14:25:25	00:01:13	00:00:32	52.714	0	1.0137
57	2021-08-30 14:25:26	00:01:13	00:00:33	52.724	0	1.0137

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



58	2021-08-30 14:25:27	00:01:15	00:00:34	52.733	0	1.0137
59	2021-08-30 14:25:28	00:01:15	00:00:35	52.742	0	1.0137
60	2021-08-30 14:25:29	00:01:17	00:00:36	52.75	0	1.0137
61	2021-08-30 14:25:31	00:01:17	00:00:37	52.754	0	1.0137
62	2021-08-30 14:25:32	00:01:19	00:00:38	52.762	0	1.0137
63	2021-08-30 14:25:33	00:01:19	00:00:39	52.77	0	1.0137
64	2021-08-30 14:25:34	00:01:21	00:00:40	52.778	0	1.0137
65	2021-08-30 14:25:35	00:01:21	00:00:41	52.785	0	1.0137
66	2021-08-30 14:25:36	00:01:23	00:00:42	52.793	0	1.0137
67	2021-08-30 14:25:37	00:01:23	00:00:43	52.799	0	1.0137
68	2021-08-30 14:25:38	00:01:25	00:00:44	52.806	0	1.0137
69	2021-08-30 14:25:39	00:01:25	00:00:45	52.812	0	1.0137
70	2021-08-30 14:25:40	00:01:27	00:00:46	52.821	0	1.0137
71	2021-08-30 14:25:41	00:01:28	00:00:47	52.827	0	1.0137
72	2021-08-30 14:25:42	00:01:29	00:00:48	52.833	0	1.0137
73	2021-08-30 14:25:43	00:01:30	00:00:49	52.839	0	1.0137
74	2021-08-30 14:25:44	00:01:31	00:00:50	52.845	0	1.0137
75	2021-08-30 14:25:45	00:01:32	00:00:51	52.851	0	1.0137
76	2021-08-30 14:25:46	00:01:33	00:00:52	52.854	0	1.0137
77	2021-08-30 14:25:47	00:01:34	00:00:53	52.859	0	1.0137
78	2021-08-30 14:25:48	00:01:35	00:00:54	52.863	0	1.0137
79	2021-08-30 14:25:49	00:01:36	00:00:55	52.868	0	1.0137
80	2021-08-30 14:25:50	00:01:37	00:00:56	52.872	0	1.0137
81	2021-08-30 14:25:51	00:01:38	00:00:57	52.876	0	1.0137
82	2021-08-30 14:25:52	00:01:39	00:00:58	52.88	0	1.0137
83	2021-08-30 14:25:53	00:01:40	00:00:59	52.885	0	1.0137
84	2021-08-30 14:25:54	00:01:41	00:01:00	52.89	0	1.0137
85	2021-08-30 14:25:55	00:01:42	00:01:01	52.896	0	1.0137
86	2021-08-30 14:25:56	00:01:43	00:01:02	52.9	0	1.0137
87	2021-08-30 14:25:57	00:01:44	00:01:03	52.904	0	1.0137
88	2021-08-30 14:25:58	00:01:45	00:01:04	52.908	0	1.0137
89	2021-08-30 14:25:59	00:01:46	00:01:05	52.912	0	1.0137
90	2021-08-30 14:26:00	00:01:47	00:01:06	52.916	0	1.0137
91	2021-08-30 14:26:01	00:01:48	00:01:07	52.919	0	1.0137
92	2021-08-30 14:26:02	00:01:49	00:01:08	52.925	0	1.0137
93	2021-08-30 14:26:03	00:01:50	00:01:09	52.928	0	1.0137
94	2021-08-30 14:26:04	00:01:51	00:01:10	52.93	0	1.0137
95	2021-08-30 14:26:05	00:01:52	00:01:11	52.933	0	1.0137
96	2021-08-30 14:26:06	00:01:53	00:01:12	52.936	0	1.0137
97	2021-08-30 14:26:07	00:01:54	00:01:13	52.939	0	1.0137
98	2021-08-30 14:26:08	00:01:55	00:01:14	52.941	0	1.0137
99	2021-08-30 14:26:09	00:01:56	00:01:15	52.944	0	1.0137
100	2021-08-30 14:26:10	00:01:57	00:01:16	52.946	0	1.0137
101	2021-08-30 14:26:11	00:01:58	00:01:17	52.949	0	1.0137
102	2021-08-30 14:26:12	00:01:59	00:01:18	52.952	0	1.0137
103	2021-08-30 14:26:13	00:02:00	00:01:20	52.955	0	1.0137
104	2021-08-30 14:26:14	00:02:01	00:01:20	52.957	0	1.0137
105	2021-08-30 14:26:15	00:02:02	00:01:22	52.959	0	1.0137
106	2021-08-30 14:26:16	00:02:03	00:01:22	52.961	0	1.0137
107	2021-08-30 14:26:17	00:02:04	00:01:24	52.965	0	1.0137
108	2021-08-30 14:26:18	00:02:05	00:01:24	52.967	0	1.0137
109	2021-08-30 14:26:19	00:02:06	00:01:26	52.969	0	1.0137
110	2021-08-30 14:26:20	00:02:07	00:01:26	52.971	0	1.0137
111	2021-08-30 14:26:21	00:02:08	00:01:28	52.973	0	1.0137
112	2021-08-30 14:26:22	00:02:09	00:01:28	52.975	0	1.0137
113	2021-08-30 14:26:23	00:02:10	00:01:30	52.976	0	1.0137
114	2021-08-30 14:26:24	00:02:11	00:01:30	52.978	0	1.0137
115	2021-08-30 14:26:25	00:02:12	00:01:32	52.98	0	1.0137
116	2021-08-30 14:26:26	00:02:13	00:01:32	52.982	0	1.0137
117	2021-08-30 14:26:27	00:02:14	00:01:34	52.984	0	1.0137
118	2021-08-30 14:26:28	00:02:15	00:01:34	52.986	0	1.0137

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



119	2021-08-30 14:26:29	00:02:16	00:01:36	52.988	0	1.0137
120	2021-08-30 14:26:30	00:02:17	00:01:36	52.99	0	1.0137
121	2021-08-30 14:26:31	00:02:18	00:01:38	52.991	0	1.0137
122	2021-08-30 14:26:32	00:02:19	00:01:38	52.994	0	1.0137
123	2021-08-30 14:32:07	00:02:20	00:01:56	49.993	-90.07	3.0892
124	2021-08-30 14:32:08	00:02:21	00:01:57	49.992	-90.017	3.1142
125	2021-08-30 14:32:09	00:02:22	00:01:58	49.991	-90.057	3.1393
126	2021-08-30 14:32:10	00:02:23	00:01:59	49.99	-90.059	3.1642
127	2021-08-30 14:32:11	00:02:24	00:02:00	49.988	-90.005	3.1893
128	2021-08-30 14:32:12	00:02:25	00:02:01	49.987	-90.094	3.2144
129	2021-08-30 14:32:13	00:02:26	00:02:02	49.985	-90.043	3.2394
130	2021-08-30 14:32:14	00:02:27	00:02:03	49.983	-90.069	3.2644
131	2021-08-30 14:32:15	00:02:28	00:02:04	49.984	-90.066	3.2895
132	2021-08-30 14:32:16	00:02:29	00:02:05	49.985	-90.067	3.302
133	2021-08-30 14:32:17	00:02:30	00:02:06	49.985	-90.076	3.3395
134	2021-08-30 14:32:18	00:02:31	00:02:07	49.985	-90.039	3.3645
135	2021-08-30 14:32:19	00:02:32	00:02:08	49.985	-90.03	3.3895
136	2021-08-30 14:32:20	00:02:33	00:02:09	49.985	-90.033	3.4146
137	2021-08-30 14:32:21	00:02:34	00:02:10	49.987	-89.924	3.4521
138	2021-08-30 14:32:22	00:02:35	00:02:11	49.987	-89.95	3.477
139	2021-08-30 14:32:23	00:02:36	00:02:12	49.986	-89.909	3.4895
140	2021-08-30 14:32:24	00:02:37	00:02:13	49.985	-89.919	3.527
141	2021-08-30 14:32:25	00:02:38	00:02:14	49.985	-89.943	3.552
142	2021-08-30 14:32:26	00:02:39	00:02:15	49.985	-89.936	3.577
143	2021-08-30 14:32:27	00:02:40	00:02:16	49.985	-89.961	3.602
144	2021-08-30 14:32:28	00:02:41	00:02:17	49.983	-90.096	3.6271
145	2021-08-30 14:32:29	00:02:42	00:02:18	49.984	-90.067	3.6521
146	2021-08-30 14:32:30	00:02:43	00:02:19	49.984	-90.073	3.6771
147	2021-08-30 14:32:31	00:02:44	00:02:20	49.983	-90.099	3.7021
148	2021-08-30 14:32:32	00:02:45	00:02:21	49.983	-90.022	3.727
149	2021-08-30 14:32:33	00:02:46	00:02:22	49.983	-90.035	3.752
150	2021-08-30 14:32:34	00:02:47	00:02:23	49.982	-90.013	3.777
151	2021-08-30 14:32:35	00:02:48	00:02:24	49.981	-90.051	3.802
152	2021-08-30 14:32:36	00:02:49	00:02:25	49.979	-90.039	3.8271
153	2021-08-30 14:32:37	00:02:50	00:02:26	49.98	-90.053	3.852
154	2021-08-30 14:32:38	00:02:51	00:02:27	49.978	-90.022	3.8646
155	2021-08-30 14:32:39	00:02:52	00:02:28	49.977	-90.061	3.9021
156	2021-08-30 14:32:40	00:02:53	00:02:29	49.977	-90.045	3.9271
157	2021-08-30 14:32:41	00:02:54	00:02:30	49.978	-89.982	3.9522
158	2021-08-30 14:32:42	00:02:55	00:02:31	49.978	-89.957	3.9771
159	2021-08-30 14:32:43	00:02:56	00:02:32	49.978	-89.967	4.0022
160	2021-08-30 14:32:44	00:02:57	00:02:33	49.979	-89.915	4.0272
161	2021-08-30 14:32:45	00:02:58	00:02:34	49.979	-89.99	4.0522
162	2021-08-30 14:32:46	00:02:59	00:02:35	49.979	-89.944	4.0772
163	2021-08-30 14:32:47	00:03:00	00:02:36	49.977	-89.999	4.1022
164	2021-08-30 14:32:48	00:03:01	00:02:37	49.977	-90.034	4.1272
165	2021-08-30 14:32:49	00:03:02	00:02:38	49.977	-90.087	4.1523
166	2021-08-30 14:32:50	00:03:03	00:02:39	49.977	-90.088	4.1772
167	2021-08-30 14:32:51	00:03:04	00:02:40	49.975	-90.037	4.2023
168	2021-08-30 14:32:52	00:03:05	00:02:41	49.977	-90.059	4.2273
169	2021-08-30 14:32:53	00:03:06	00:02:42	49.977	-90.032	4.2398
170	2021-08-30 14:32:54	00:03:07	00:02:43	49.974	-90.031	4.2773
171	2021-08-30 14:32:55	00:03:08	00:02:44	49.975	-89.969	4.3023
172	2021-08-30 14:32:56	00:03:09	00:02:45	49.975	-89.929	4.3273
173	2021-08-30 14:32:57	00:03:10	00:02:46	49.975	-89.905	4.3523
174	2021-08-30 14:32:58	00:03:11	00:02:47	49.975	-89.999	4.3773
175	2021-08-30 14:32:59	00:03:12	00:02:48	49.975	-89.926	4.4023
176	2021-08-30 14:33:00	00:03:13	00:02:49	49.975	-89.951	4.4273
177	2021-08-30 14:33:01	00:03:14	00:02:50	49.975	-89.994	4.4523
178	2021-08-30 14:33:02	00:03:15	00:02:51	49.973	-90.084	4.4774
179	2021-08-30 14:33:03	00:03:16	00:02:52	49.974	-90.084	4.5023

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



180	2021-08-30 14:33:04	00:03:17	00:02:53	49.973	-90.016	4.5273
181	2021-08-30 14:33:05	00:03:18	00:02:54	49.972	-90.011	4.5523
182	2021-08-30 14:33:06	00:03:19	00:02:55	49.971	-90.018	4.5773
183	2021-08-30 14:33:07	00:03:20	00:02:56	49.972	-89.975	4.6023
184	2021-08-30 14:33:08	00:03:21	00:02:57	49.973	-89.924	4.6148
185	2021-08-30 14:33:09	00:03:22	00:02:58	49.972	-89.948	4.6523
186	2021-08-30 14:33:10	00:03:23	00:02:59	49.974	-89.935	4.6773
187	2021-08-30 14:33:11	00:03:24	00:03:00	49.973	-89.983	4.7023
188	2021-08-30 14:33:12	00:03:25	00:03:01	49.972	-90.03	4.7273
189	2021-08-30 14:33:13	00:03:26	00:03:02	49.973	-90.044	4.7523
190	2021-08-30 14:33:14	00:03:27	00:03:03	49.972	-90.023	4.7774
191	2021-08-30 14:33:15	00:03:28	00:03:04	49.971	-90.028	4.8024
192	2021-08-30 14:33:16	00:03:29	00:03:05	49.97	-90.038	4.8274
193	2021-08-30 14:33:17	00:03:30	00:03:06	49.97	-90.051	4.8524
194	2021-08-30 14:33:18	00:03:31	00:03:07	49.971	-90.027	4.8774
195	2021-08-30 14:33:19	00:03:32	00:03:08	49.969	-90.044	4.9025
196	2021-08-30 14:33:20	00:03:33	00:03:09	49.97	-89.974	4.9275
197	2021-08-30 14:33:21	00:03:34	00:03:10	49.97	-90.037	4.9525
198	2021-08-30 14:33:22	00:03:35	00:03:11	49.969	-90.068	4.9775
199	2021-08-30 14:33:23	00:03:36	00:03:12	49.97	-89.993	4.99
200	2021-08-30 14:33:24	00:03:37	00:03:13	49.968	-90.006	5.0275
201	2021-08-30 14:33:25	00:03:38	00:03:14	49.967	-90.012	5.0526
202	2021-08-30 14:33:26	00:03:39	00:03:15	49.967	-90.044	5.0776
203	2021-08-30 14:33:27	00:03:40	00:03:16	49.968	-90.002	5.1026
204	2021-08-30 14:33:28	00:03:41	00:03:17	49.968	-89.984	5.1276
205	2021-08-30 14:33:29	00:03:42	00:03:18	49.969	-89.943	5.1526
206	2021-08-30 14:33:30	00:03:43	00:03:19	49.97	-89.91	5.1776
207	2021-08-30 14:33:31	00:03:44	00:03:20	49.97	-89.994	5.2026
208	2021-08-30 14:33:32	00:03:45	00:03:21	49.967	-89.982	5.2276
209	2021-08-30 14:33:33	00:03:46	00:03:22	49.968	-90.019	5.2651
210	2021-08-30 14:33:34	00:03:47	00:03:23	49.966	-90.082	5.2901
211	2021-08-30 14:33:35	00:03:48	00:03:24	49.964	-90.098	5.3152
212	2021-08-30 14:33:36	00:03:49	00:03:25	49.964	-90.036	5.3401
213	2021-08-30 14:33:37	00:03:50	00:03:26	49.965	-89.945	5.3651
214	2021-08-30 14:33:38	00:03:51	00:03:27	49.964	-89.996	5.3902
215	2021-08-30 14:33:39	00:03:52	00:03:28	49.964	-89.985	5.4152
216	2021-08-30 14:33:40	00:03:53	00:03:29	49.966	-89.934	5.4401
217	2021-08-30 14:33:41	00:03:54	00:03:30	49.965	-89.998	5.4652
218	2021-08-30 14:33:42	00:03:55	00:03:31	49.966	-90.001	5.4902
219	2021-08-30 14:33:44	00:03:56	00:03:32	49.966	-90.038	5.5152
220	2021-08-30 14:33:45	00:03:57	00:03:33	49.966	-90.025	5.5402
221	2021-08-30 14:33:46	00:03:58	00:03:34	49.966	-90.053	5.5527
222	2021-08-30 14:33:47	00:03:59	00:03:35	49.964	-90.07	5.5902
223	2021-08-30 14:33:48	00:04:00	00:03:36	49.963	-90.082	5.6152
224	2021-08-30 14:33:49	00:04:01	00:03:37	49.963	-90.075	5.6402
225	2021-08-30 14:33:50	00:04:02	00:03:38	49.963	-90.08	5.6652
226	2021-08-30 14:33:51	00:04:03	00:03:39	49.964	-90.011	5.6901
227	2021-08-30 14:33:52	00:04:04	00:03:40	49.966	-89.938	5.7151
228	2021-08-30 14:33:53	00:04:05	00:03:41	49.966	-89.978	5.7402
229	2021-08-30 14:33:54	00:04:06	00:03:42	49.966	-89.925	5.7652
230	2021-08-30 14:33:55	00:04:07	00:03:43	49.964	-89.967	5.7902
231	2021-08-30 14:33:56	00:04:08	00:03:44	49.964	-89.998	5.8152
232	2021-08-30 14:33:57	00:04:09	00:03:45	49.964	-90.001	5.8402
233	2021-08-30 14:33:58	00:04:10	00:03:46	49.963	-90.081	5.8652
234	2021-08-30 14:33:59	00:04:11	00:03:47	49.964	-90.009	5.8903
235	2021-08-30 14:34:00	00:04:12	00:03:48	49.964	-90.01	5.9153
236	2021-08-30 14:34:01	00:04:13	00:03:49	49.964	-90.032	5.9277
237	2021-08-30 14:34:02	00:04:14	00:03:50	49.962	-90.074	5.9653
238	2021-08-30 14:34:03	00:04:15	00:03:51	49.963	-90.063	5.9903
239	2021-08-30 14:34:04	00:04:16	00:03:52	49.962	-90.055	6.0152
240	2021-08-30 14:34:05	00:04:17	00:03:53	49.961	-90.091	6.0403

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



241	2021-08-30 14:34:06	00:04:18	00:03:54	49.961	-90.078	6.0653
242	2021-08-30 14:34:07	00:04:19	00:03:55	49.962	-90.099	6.0903
243	2021-08-30 14:34:08	00:04:20	00:03:56	49.962	-90.014	6.1153
244	2021-08-30 14:34:09	00:04:22	00:03:58	49.961	-90.032	6.1403
245	2021-08-30 14:34:10	00:04:22	00:03:58	49.961	-90.021	6.1653
246	2021-08-30 14:34:11	00:04:24	00:04:00	49.961	-90.008	6.1903
247	2021-08-30 14:34:12	00:04:24	00:04:00	49.961	-90.003	6.2153
248	2021-08-30 14:34:13	00:04:26	00:04:02	49.962	-89.936	6.2403
249	2021-08-30 14:34:14	00:04:26	00:04:02	49.961	-89.985	6.2654
250	2021-08-30 14:34:15	00:04:28	00:04:04	49.96	-89.943	6.2904
251	2021-08-30 14:34:16	00:04:28	00:04:04	49.96	-89.95	6.3029
252	2021-08-30 14:34:17	00:04:30	00:04:06	49.959	-89.966	6.3405
253	2021-08-30 14:34:18	00:04:30	00:04:06	49.96	-89.948	6.3655
254	2021-08-30 14:34:19	00:04:32	00:04:08	49.96	-89.917	6.3905
255	2021-08-30 14:34:20	00:04:32	00:04:08	49.961	-89.998	6.4155
256	2021-08-30 14:34:21	00:04:34	00:04:10	49.96	-89.939	6.4405
257	2021-08-30 14:34:22	00:04:34	00:04:10	49.96	-89.995	6.4655
258	2021-08-30 14:34:23	00:04:36	00:04:12	49.958	-90.085	6.4906
259	2021-08-30 14:34:24	00:04:36	00:04:12	49.959	-90.041	6.5156
260	2021-08-30 14:34:25	00:04:38	00:04:14	49.961	-90.039	6.5406
261	2021-08-30 14:34:26	00:04:38	00:04:14	49.96	-90.074	6.5656
262	2021-08-30 14:34:27	00:04:40	00:04:16	49.959	-90.095	6.5906
263	2021-08-30 14:34:28	00:04:40	00:04:16	49.959	-90.072	6.6156
264	2021-08-30 14:34:29	00:04:42	00:04:18	49.958	-90.025	6.6407
265	2021-08-30 14:34:30	00:04:42	00:04:18	49.958	-90.019	6.6656
266	2021-08-30 14:34:31	00:04:44	00:04:20	49.958	-90.021	6.6781
267	2021-08-30 14:34:32	00:04:44	00:04:20	49.956	-90.045	6.7157
268	2021-08-30 14:34:33	00:04:46	00:04:22	49.956	-90.095	6.7407
269	2021-08-30 14:34:34	00:04:46	00:04:22	49.956	-90.042	6.7657
270	2021-08-30 14:34:35	00:04:48	00:04:24	49.955	-90.075	6.7907
271	2021-08-30 14:34:36	00:04:48	00:04:24	49.954	-90.036	6.8157
272	2021-08-30 14:34:37	00:04:50	00:04:26	49.955	-90.04	6.8407
273	2021-08-30 14:34:38	00:04:50	00:04:26	49.955	-90.058	6.8657
274	2021-08-30 14:34:39	00:04:52	00:04:28	49.955	-90.046	6.8907
275	2021-08-30 14:34:40	00:04:52	00:04:28	49.956	-89.975	6.9157
276	2021-08-30 14:34:41	00:04:54	00:04:30	49.956	-89.992	6.9408
277	2021-08-30 14:34:42	00:04:54	00:04:30	49.957	-89.938	6.9658
278	2021-08-30 14:34:43	00:04:56	00:04:32	49.957	-89.949	6.9908
279	2021-08-30 14:34:44	00:04:56	00:04:32	49.958	-89.996	7.0158
280	2021-08-30 14:34:45	00:04:58	00:04:34	49.958	-89.934	7.0408
281	2021-08-30 14:34:46	00:04:59	00:04:35	49.958	-89.989	7.0533
282	2021-08-30 14:34:47	00:05:00	00:04:36	49.959	-89.929	7.0908
283	2021-08-30 14:34:48	00:05:01	00:04:37	49.957	-90.006	7.1158
284	2021-08-30 14:34:49	00:05:02	00:04:38	49.959	-89.939	7.1408
285	2021-08-30 14:34:50	00:05:03	00:04:39	49.96	-89.965	7.1658
286	2021-08-30 14:34:51	00:05:04	00:04:40	49.958	-89.997	7.1908
287	2021-08-30 14:34:52	00:05:05	00:04:41	49.958	-90.035	7.2158
288	2021-08-30 14:34:53	00:05:06	00:04:42	49.956	-90.086	7.2408
289	2021-08-30 14:34:54	00:05:07	00:04:43	49.956	-90.046	7.2658
290	2021-08-30 14:34:55	00:05:08	00:04:44	49.955	-90.06	7.2908
291	2021-08-30 14:34:56	00:05:09	00:04:45	49.953	-90.029	7.3159
292	2021-08-30 14:34:57	00:05:10	00:04:46	49.953	-90.077	7.3409
293	2021-08-30 14:34:58	00:05:11	00:04:47	49.954	-90.016	7.3658
294	2021-08-30 14:34:59	00:05:12	00:04:48	49.954	-90.018	7.3909
295	2021-08-30 14:35:00	00:05:13	00:04:49	49.955	-90.041	7.4159
296	2021-08-30 14:35:01	00:05:14	00:04:50	49.953	-90.057	7.4284
297	2021-08-30 14:35:02	00:05:15	00:04:51	49.954	-89.985	7.4659
298	2021-08-30 14:35:03	00:05:16	00:04:52	49.954	-89.974	7.4909
299	2021-08-30 14:35:04	00:05:17	00:04:53	49.955	-89.937	7.5159
300	2021-08-30 14:35:05	00:05:18	00:04:54	49.954	-89.963	7.5409
301	2021-08-30 14:35:06	00:05:19	00:04:55	49.954	-89.953	7.5659

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



302	2021-08-30 14:35:07	00:05:20	00:04:56	49.954	-89.937	7.5909
303	2021-08-30 14:35:08	00:05:21	00:04:57	49.953	-89.991	7.616
304	2021-08-30 14:35:09	00:05:22	00:04:58	49.954	-89.917	7.641
305	2021-08-30 14:35:10	00:05:23	00:04:59	49.956	-89.903	7.6659
306	2021-08-30 14:35:11	00:05:24	00:05:00	49.957	-89.99	7.6909
307	2021-08-30 14:35:12	00:05:25	00:05:01	49.957	-89.94	7.7159
308	2021-08-30 14:35:13	00:05:26	00:05:02	49.956	-90.006	7.7409
309	2021-08-30 14:35:14	00:05:27	00:05:03	49.955	-90.026	7.766
310	2021-08-30 14:35:15	00:05:28	00:05:04	49.953	-90.072	7.791
311	2021-08-30 14:35:16	00:05:29	00:05:05	49.953	-90.08	7.8035
312	2021-08-30 14:35:17	00:05:30	00:05:06	49.952	-90.056	7.8409
313	2021-08-30 14:35:18	00:05:31	00:05:07	49.952	-90.048	7.8659
314	2021-08-30 14:35:19	00:05:32	00:05:08	49.951	-90.096	7.9034
315	2021-08-30 14:35:20	00:05:33	00:05:09	49.951	-90.083	7.9284
316	2021-08-30 14:35:21	00:05:34	00:05:10	49.952	-90.05	7.9534
317	2021-08-30 14:35:22	00:05:35	00:05:11	49.954	-89.993	7.9784
318	2021-08-30 14:35:23	00:05:36	00:05:12	49.953	-90.024	7.9909
319	2021-08-30 14:35:24	00:05:37	00:05:13	49.953	-89.967	8.0285
320	2021-08-30 14:35:25	00:05:38	00:05:14	49.954	-89.929	8.0535
321	2021-08-30 14:35:26	00:05:39	00:05:15	49.954	-89.994	8.0784
322	2021-08-30 14:35:27	00:05:40	00:05:16	49.955	-89.917	8.1034
323	2021-08-30 14:35:28	00:05:41	00:05:17	49.953	-89.976	8.1285
324	2021-08-30 14:35:29	00:05:42	00:05:18	49.954	-89.928	8.1535
325	2021-08-30 14:35:30	00:05:43	00:05:19	49.954	-89.923	8.1785
326	2021-08-30 14:35:31	00:05:44	00:05:20	49.954	-89.948	8.2035
327	2021-08-30 14:35:32	00:05:45	00:05:21	49.952	-90.047	8.2285
328	2021-08-30 14:35:33	00:05:46	00:05:22	49.952	-90.036	8.2535
329	2021-08-30 14:35:34	00:05:47	00:05:23	49.951	-90.062	8.2785
330	2021-08-30 14:35:35	00:05:48	00:05:24	49.951	-90.012	8.3035
331	2021-08-30 14:35:36	00:05:49	00:05:25	49.951	-90.054	8.3285
332	2021-08-30 14:35:37	00:05:50	00:05:26	49.95	-90.047	8.3536
333	2021-08-30 14:35:38	00:05:51	00:05:27	49.95	-89.995	8.3661
334	2021-08-30 14:35:39	00:05:52	00:05:28	49.949	-90.061	8.4036
335	2021-08-30 14:35:40	00:05:53	00:05:29	49.95	-89.974	8.4286
336	2021-08-30 14:35:41	00:05:54	00:05:30	49.951	-89.97	8.4536
337	2021-08-30 14:35:42	00:05:55	00:05:31	49.951	-89.983	8.4787
338	2021-08-30 14:35:43	00:05:56	00:05:32	49.952	-89.94	8.5037
339	2021-08-30 14:35:44	00:05:57	00:05:33	49.953	-89.916	8.5287
340	2021-08-30 14:35:45	00:05:58	00:05:34	49.952	-89.963	8.5538
341	2021-08-30 14:35:46	00:05:59	00:05:35	49.953	-89.971	8.5788
342	2021-08-30 14:35:47	00:06:00	00:05:36	49.952	-89.969	8.6038
343	2021-08-30 14:35:48	00:06:01	00:05:37	49.951	-90.037	8.6289
344	2021-08-30 14:35:49	00:06:02	00:05:38	49.951	-90.076	8.6539
345	2021-08-30 14:35:50	00:06:03	00:05:39	49.951	-90.068	8.6789
346	2021-08-30 14:35:51	00:06:04	00:05:40	49.948	-90.03	8.7039
347	2021-08-30 14:35:52	00:06:05	00:05:41	49.948	-90.016	8.729
348	2021-08-30 14:35:53	00:06:06	00:05:42	49.948	-90.058	8.7414
349	2021-08-30 14:35:54	00:06:07	00:05:43	49.946	-90.098	8.779
350	2021-08-30 14:35:55	00:06:08	00:05:44	49.946	-90.003	8.8041
351	2021-08-30 14:35:56	00:06:09	00:05:45	49.946	-90.096	8.8291
352	2021-08-30 14:35:57	00:06:10	00:05:46	49.946	-90.012	8.8541
353	2021-08-30 14:35:58	00:06:11	00:05:47	49.946	-90.094	8.8791
354	2021-08-30 14:35:59	00:06:12	00:05:48	49.946	-90.081	8.9042
355	2021-08-30 14:36:00	00:06:13	00:05:49	49.947	-90.04	8.9292
356	2021-08-30 14:36:01	00:06:14	00:05:50	49.948	-89.967	8.9542
357	2021-08-30 14:36:02	00:06:15	00:05:51	49.949	-89.943	8.9792
358	2021-08-30 14:36:03	00:06:16	00:05:52	49.947	-89.998	9.0042
359	2021-08-30 14:36:04	00:06:17	00:05:53	49.948	-89.958	9.0292
360	2021-08-30 14:36:05	00:06:18	00:05:54	49.948	-89.977	9.0542
361	2021-08-30 14:36:06	00:06:19	00:05:55	49.947	-90.038	9.0792
362	2021-08-30 14:36:07	00:06:20	00:05:56	49.947	-90.039	9.1042

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



363	2021-08-30 14:36:08	00:06:21	00:05:57	49.947	-90.026	9.1167
364	2021-08-30 14:36:09	00:06:22	00:05:58	49.947	-90.075	9.1542
365	2021-08-30 14:36:10	00:06:23	00:05:59	49.945	-90.082	9.1793
366	2021-08-30 14:36:11	00:06:24	00:06:00	49.946	-90.087	9.2043
367	2021-08-30 14:36:12	00:06:25	00:06:01	49.946	-90.09	9.2293
368	2021-08-30 14:36:13	00:06:26	00:06:02	49.947	-89.996	9.2543
369	2021-08-30 14:36:14	00:06:27	00:06:03	49.946	-90.03	9.2794
370	2021-08-30 14:36:15	00:06:28	00:06:04	49.946	-90.001	9.3044
371	2021-08-30 14:36:16	00:06:29	00:06:05	49.947	-89.953	9.3294
372	2021-08-30 14:36:17	00:06:30	00:06:06	49.946	-90.016	9.3544
373	2021-08-30 14:36:18	00:06:31	00:06:07	49.946	-90.003	9.3794
374	2021-08-30 14:36:19	00:06:32	00:06:08	49.947	-89.978	9.4045
375	2021-08-30 14:36:20	00:06:33	00:06:09	49.949	-89.96	9.4294
376	2021-08-30 14:36:21	00:06:34	00:06:10	49.948	-90.069	9.4544
377	2021-08-30 14:36:22	00:06:35	00:06:11	49.946	-90.015	9.4795
378	2021-08-30 14:36:23	00:06:36	00:06:12	49.946	-90.09	9.492
379	2021-08-30 14:36:24	00:06:37	00:06:13	49.946	-90	9.5295
380	2021-08-30 14:36:25	00:06:38	00:06:14	49.945	-90.017	9.5546
381	2021-08-30 14:36:26	00:06:39	00:06:15	49.945	-90.02	9.5796
382	2021-08-30 14:36:27	00:06:40	00:06:16	49.946	-90.081	9.6047
383	2021-08-30 14:36:28	00:06:41	00:06:17	49.948	-90.021	9.6296
384	2021-08-30 14:36:29	00:06:42	00:06:18	49.946	-90.067	9.6547
385	2021-08-30 14:36:30	00:06:43	00:06:19	49.947	-89.996	9.6797
386	2021-08-30 14:36:31	00:06:44	00:06:20	49.946	-89.989	9.7047
387	2021-08-30 14:36:32	00:06:45	00:06:21	49.946	-90.01	9.7297
388	2021-08-30 14:36:33	00:06:46	00:06:22	49.947	-90.007	9.7547
389	2021-08-30 14:36:34	00:06:47	00:06:23	49.948	-89.967	9.7797
390	2021-08-30 14:36:35	00:06:48	00:06:24	49.948	-90.036	9.8173
391	2021-08-30 14:36:36	00:06:49	00:06:25	49.948	-90.038	9.8423
392	2021-08-30 14:36:37	00:06:50	00:06:26	49.945	-90.042	9.8674
393	2021-08-30 14:36:38	00:06:51	00:06:27	49.944	-90.085	9.8924
394	2021-08-30 14:36:39	00:06:52	00:06:28	49.945	-90.069	9.9173
395	2021-08-30 14:36:40	00:06:53	00:06:29	49.945	-90.089	9.9423
396	2021-08-30 14:36:41	00:06:54	00:06:30	49.945	-90.029	9.9673
397	2021-08-30 14:36:42	00:06:55	00:06:31	49.944	-90.011	9.9924
398	2021-08-30 14:36:43	00:06:56	00:06:32	49.943	-90.033	10.0174
399	2021-08-30 14:36:44	00:06:57	00:06:33	49.943	-90.051	10.0424
400	2021-08-30 14:36:45	00:06:58	00:06:34	49.943	-90.006	10.0549
401	2021-08-30 14:36:46	00:06:59	00:06:35	49.944	-90.033	10.0924
402	2021-08-30 14:36:47	00:07:00	00:06:36	49.943	-90.087	10.1174
403	2021-08-30 14:36:49	00:07:01	00:06:37	49.944	-90.018	10.1424
404	2021-08-30 14:36:50	00:07:02	00:06:38	49.944	-89.996	10.1674
405	2021-08-30 14:36:51	00:07:03	00:06:39	49.945	-89.94	10.1924
406	2021-08-30 14:36:52	00:07:04	00:06:40	49.945	-89.993	10.2174
407	2021-08-30 14:36:53	00:07:05	00:06:41	49.945	-89.993	10.2424
408	2021-08-30 14:36:54	00:07:06	00:06:42	49.946	-89.923	10.2674
409	2021-08-30 14:36:55	00:07:07	00:06:43	49.946	-89.964	10.2924
410	2021-08-30 14:36:56	00:07:08	00:06:44	49.945	-90.034	10.3174
411	2021-08-30 14:36:57	00:07:09	00:06:45	49.944	-90.085	10.3424
412	2021-08-30 14:36:58	00:07:10	00:06:46	49.943	-90.072	10.3675
413	2021-08-30 14:36:59	00:07:11	00:06:47	49.942	-90.097	10.3924
414	2021-08-30 14:37:00	00:07:12	00:06:48	49.94	-90.033	10.4175
415	2021-08-30 14:37:01	00:07:13	00:06:49	49.94	-90.014	10.43
416	2021-08-30 14:37:02	00:07:14	00:06:50	49.942	-90.031	10.4675
417	2021-08-30 14:37:03	00:07:15	00:06:51	49.942	-90.051	10.4925
418	2021-08-30 14:37:04	00:07:16	00:06:52	49.941	-90.069	10.5175
419	2021-08-30 14:37:05	00:07:17	00:06:53	49.942	-90.024	10.5425
420	2021-08-30 14:37:06	00:07:18	00:06:54	49.944	-89.993	10.5675
421	2021-08-30 14:37:07	00:07:19	00:06:55	49.942	-90.066	10.5925
422	2021-08-30 14:37:08	00:07:20	00:06:56	49.942	-90.071	10.6175
423	2021-08-30 14:37:09	00:07:21	00:06:57	49.942	-90.066	10.6425

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



424	2021-08-30 14:37:10	00:07:22	00:06:58	49.942	-90.087	10.6675
425	2021-08-30 14:37:11	00:07:23	00:06:59	49.942	-90.063	10.6925
426	2021-08-30 14:37:12	00:07:24	00:07:00	49.94	-90.086	10.7175
427	2021-08-30 14:37:13	00:07:25	00:07:01	49.941	-90.003	10.7425
428	2021-08-30 14:37:14	00:07:26	00:07:02	49.942	-89.974	10.7675
429	2021-08-30 14:37:15	00:07:27	00:07:03	49.943	-89.929	10.7925
430	2021-08-30 14:37:16	00:07:28	00:07:04	49.944	-89.924	10.805
431	2021-08-30 14:37:17	00:07:29	00:07:05	49.942	-90.025	10.8426
432	2021-08-30 14:37:18	00:07:30	00:07:06	49.942	-89.992	10.8676
433	2021-08-30 14:37:19	00:07:31	00:07:07	49.941	-90.06	10.8926
434	2021-08-30 14:37:20	00:07:32	00:07:08	49.94	-90.096	10.9176
435	2021-08-30 14:37:21	00:07:33	00:07:09	49.94	-90.086	10.9426
436	2021-08-30 14:37:22	00:07:34	00:07:10	49.94	-90.013	10.9676
437	2021-08-30 14:37:23	00:07:35	00:07:11	49.94	-90.029	10.9927
438	2021-08-30 14:37:24	00:07:36	00:07:12	49.941	-89.981	11.0177
439	2021-08-30 14:37:25	00:07:38	00:07:14	49.941	-90.016	11.0427
440	2021-08-30 14:37:26	00:07:38	00:07:14	49.942	-89.957	11.0677
441	2021-08-30 14:37:27	00:07:40	00:07:16	49.941	-90.016	11.0928
442	2021-08-30 14:37:28	00:07:40	00:07:16	49.94	-90.071	11.1178
443	2021-08-30 14:37:29	00:07:42	00:07:18	49.941	-90.015	11.1428
444	2021-08-30 14:37:30	00:07:42	00:07:18	49.939	-90.094	11.1678
445	2021-08-30 14:37:31	00:07:44	00:07:20	49.939	-90.004	11.1803
446	2021-08-30 14:37:32	00:07:44	00:07:20	49.94	-90.001	11.2178
447	2021-08-30 14:37:33	00:07:46	00:07:22	49.941	-90.004	11.2427
448	2021-08-30 14:37:34	00:07:46	00:07:22	49.941	-89.957	11.2677
449	2021-08-30 14:37:35	00:07:48	00:07:24	49.941	-89.93	11.2927
450	2021-08-30 14:37:36	00:07:48	00:07:24	49.941	-89.996	11.3177
451	2021-08-30 14:37:37	00:07:50	00:07:26	49.941	-89.964	11.3427
452	2021-08-30 14:37:38	00:07:50	00:07:26	49.94	-90.015	11.3677
453	2021-08-30 14:37:39	00:07:52	00:07:28	49.94	-89.985	11.3927
454	2021-08-30 14:37:40	00:07:52	00:07:28	49.939	-90.05	11.4178
455	2021-08-30 14:37:41	00:07:54	00:07:30	49.939	-90.066	11.4427
456	2021-08-30 14:37:42	00:07:54	00:07:30	49.939	-90.098	11.4677
457	2021-08-30 14:37:43	00:07:56	00:07:32	49.939	-90.055	11.4927
458	2021-08-30 14:37:44	00:07:56	00:07:32	49.939	-90.091	11.5177
459	2021-08-30 14:37:45	00:07:58	00:07:34	49.938	-90.087	11.5427
460	2021-08-30 14:37:46	00:07:58	00:07:34	49.939	-90.041	11.5552
461	2021-08-30 14:37:47	00:08:00	00:07:36	49.938	-90.044	11.5927
462	2021-08-30 14:37:48	00:08:00	00:07:36	49.939	-90.011	11.6177
463	2021-08-30 14:37:49	00:08:02	00:07:38	49.939	-89.981	11.6427
464	2021-08-30 14:37:50	00:08:02	00:07:38	49.939	-89.952	11.6677
465	2021-08-30 14:37:51	00:08:04	00:07:40	49.94	-89.92	11.6926
466	2021-08-30 14:37:52	00:08:04	00:07:40	49.939	-89.919	11.7177
467	2021-08-30 14:37:53	00:08:06	00:07:42	49.938	-89.989	11.7427
468	2021-08-30 14:37:54	00:08:07	00:07:43	49.938	-90.006	11.7677
469	2021-08-30 14:37:55	00:08:08	00:07:44	49.938	-89.944	11.7927
470	2021-08-30 14:37:56	00:08:09	00:07:45	49.937	-90.008	11.8177
471	2021-08-30 14:37:57	00:08:10	00:07:46	49.937	-90.027	11.8427
472	2021-08-30 14:37:58	00:08:11	00:07:47	49.936	-90.056	11.8677
473	2021-08-30 14:37:59	00:08:12	00:07:48	49.936	-90.04	11.8927
474	2021-08-30 14:38:00	00:08:13	00:07:49	49.936	-90.02	11.9177
475	2021-08-30 14:38:01	00:08:14	00:07:50	49.936	-90.042	11.9302
476	2021-08-30 14:38:02	00:08:15	00:07:51	49.935	-90.035	11.9677
477	2021-08-30 14:38:03	00:08:16	00:07:52	49.935	-90.09	11.9928
478	2021-08-30 14:38:04	00:08:17	00:07:53	49.935	-90.079	12.0178
479	2021-08-30 14:38:05	00:08:18	00:07:54	49.935	-90.014	12.0428
480	2021-08-30 14:38:06	00:08:19	00:07:55	49.935	-90.022	12.0678
481	2021-08-30 14:38:07	00:08:20	00:07:56	49.934	-90.081	12.0928
482	2021-08-30 14:38:08	00:08:21	00:07:57	49.936	-90.027	12.1178
483	2021-08-30 14:38:09	00:08:22	00:07:58	49.937	-90.031	12.1428
484	2021-08-30 14:38:10	00:08:23	00:07:59	49.934	-90.048	12.1679

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



485	2021-08-30 14:38:11	00:08:24	00:08:00	49.933	-90.079	12.1929
486	2021-08-30 14:38:12	00:08:25	00:08:01	49.934	-89.991	12.2179
487	2021-08-30 14:38:13	00:08:26	00:08:02	49.934	-90.016	12.2429
488	2021-08-30 14:38:14	00:08:27	00:08:03	49.934	-90.005	12.268
489	2021-08-30 14:38:15	00:08:28	00:08:04	49.935	-89.999	12.293
490	2021-08-30 14:38:16	00:08:29	00:08:05	49.934	-89.973	12.3055
491	2021-08-30 14:38:17	00:08:30	00:08:06	49.934	-89.976	12.343
492	2021-08-30 14:38:18	00:08:31	00:08:07	49.933	-90.04	12.3681
493	2021-08-30 14:38:19	00:08:32	00:08:08	49.933	-89.976	12.3931
494	2021-08-30 14:38:20	00:08:33	00:08:09	49.933	-90.016	12.4181
495	2021-08-30 14:38:21	00:08:34	00:08:10	49.934	-90.006	12.4431
496	2021-08-30 14:38:22	00:08:35	00:08:11	49.934	-90.023	12.4681
497	2021-08-30 14:38:23	00:08:36	00:08:12	49.934	-90.037	12.4931
498	2021-08-30 14:38:24	00:08:37	00:08:13	49.934	-90.031	12.5181
499	2021-08-30 14:38:25	00:08:38	00:08:14	49.935	-90.058	12.5556
500	2021-08-30 14:38:26	00:08:39	00:08:15	49.933	-90.069	12.5806
501	2021-08-30 14:38:27	00:08:40	00:08:16	49.933	-90.05	12.6056
502	2021-08-30 14:38:28	00:08:41	00:08:17	49.933	-90.052	12.6306
503	2021-08-30 14:38:29	00:08:42	00:08:18	49.933	-90.069	12.6556
504	2021-08-30 14:38:30	00:08:43	00:08:19	49.933	-90.094	12.6806
505	2021-08-30 14:38:31	00:08:44	00:08:20	49.933	-90.093	12.7056
506	2021-08-30 14:38:32	00:08:45	00:08:21	49.932	-90.028	12.7306
507	2021-08-30 14:38:33	00:08:46	00:08:22	49.932	-90.02	12.7557
508	2021-08-30 14:38:34	00:08:47	00:08:23	49.93	-90.019	12.7807
509	2021-08-30 14:38:35	00:08:48	00:08:24	49.93	-90.03	12.8057
510	2021-08-30 14:38:36	00:08:49	00:08:25	49.93	-90	12.8307
511	2021-08-30 14:38:37	00:08:50	00:08:26	49.932	-90.02	12.8557
512	2021-08-30 14:38:38	00:08:51	00:08:27	49.93	-90.03	12.8682
513	2021-08-30 14:38:39	00:08:52	00:08:28	49.931	-90.016	12.9058
514	2021-08-30 14:38:40	00:08:53	00:08:29	49.932	-89.992	12.9308
515	2021-08-30 14:38:41	00:08:54	00:08:30	49.934	-89.95	12.9558
516	2021-08-30 14:38:42	00:08:55	00:08:31	49.935	-89.937	12.9808
517	2021-08-30 14:38:43	00:08:56	00:08:32	49.935	-89.936	13.0058
518	2021-08-30 14:38:44	00:08:57	00:08:33	49.935	-89.936	13.0309
519	2021-08-30 14:38:45	00:08:58	00:08:34	49.935	-89.911	13.0559
520	2021-08-30 14:38:46	00:08:59	00:08:35	49.934	-89.989	13.0809
521	2021-08-30 14:38:47	00:09:00	00:08:36	49.933	-90.046	13.1059
522	2021-08-30 14:38:48	00:09:01	00:08:37	49.932	-90.059	13.131
523	2021-08-30 14:38:49	00:09:02	00:08:38	49.93	-90.095	13.156
524	2021-08-30 14:38:50	00:09:03	00:08:39	49.931	-90.096	13.181
525	2021-08-30 14:38:51	00:09:04	00:08:40	49.93	-90.001	13.206
526	2021-08-30 14:38:52	00:09:05	00:08:41	49.929	-90.062	13.231
527	2021-08-30 14:38:53	00:09:06	00:08:42	49.928	-90.076	13.2436
528	2021-08-30 14:38:54	00:09:07	00:08:43	49.928	-90.029	13.281
529	2021-08-30 14:38:55	00:09:08	00:08:44	49.928	-90.058	13.3061
530	2021-08-30 14:38:56	00:09:09	00:08:45	49.929	-90.061	13.3311
531	2021-08-30 14:38:57	00:09:10	00:08:46	49.929	-90.039	13.3561
532	2021-08-30 14:38:58	00:09:11	00:08:47	49.93	-90.004	13.3811
533	2021-08-30 14:38:59	00:09:12	00:08:48	49.929	-89.957	13.4061
534	2021-08-30 14:39:00	00:09:13	00:08:49	49.927	-90.004	13.4311
535	2021-08-30 14:39:01	00:09:14	00:08:50	49.928	-89.973	13.4561
536	2021-08-30 14:39:02	00:09:15	00:08:51	49.928	-90.014	13.4811
537	2021-08-30 14:39:03	00:09:16	00:08:52	49.928	-90.031	13.5061
538	2021-08-30 14:39:04	00:09:17	00:08:53	49.926	-90.056	13.5312
539	2021-08-30 14:39:05	00:09:18	00:08:54	49.926	-90.024	13.5562
540	2021-08-30 14:39:06	00:09:19	00:08:55	49.926	-90.065	13.5812
541	2021-08-30 14:39:07	00:09:20	00:08:56	49.926	-90.037	13.6062
542	2021-08-30 14:39:08	00:09:21	00:08:57	49.925	-90.032	13.6187
543	2021-08-30 14:39:09	00:09:22	00:08:58	49.924	-90.072	13.6563
544	2021-08-30 14:39:10	00:09:23	00:08:59	49.924	-90.014	13.6813
545	2021-08-30 14:39:11	00:09:24	00:09:00	49.925	-90.051	13.7063

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



546	2021-08-30 14:39:12	00:09:25	00:09:01	49.925	-90.026	13.7313
547	2021-08-30 14:39:13	00:09:26	00:09:02	49.925	-90.032	13.7563
548	2021-08-30 14:39:14	00:09:27	00:09:03	49.925	-89.964	13.7813
549	2021-08-30 14:39:15	00:09:28	00:09:04	49.925	-90.006	13.8064
550	2021-08-30 14:39:16	00:09:29	00:09:05	49.925	-90.042	13.8314
551	2021-08-30 14:39:17	00:09:30	00:09:06	49.924	-90.097	13.8564
552	2021-08-30 14:39:18	00:09:31	00:09:07	49.924	-90.006	13.8815
553	2021-08-30 14:39:19	00:09:32	00:09:08	49.925	-90.088	13.9064
554	2021-08-30 14:39:20	00:09:33	00:09:09	49.925	-90	13.9314
555	2021-08-30 14:39:21	00:09:34	00:09:10	49.923	-90.033	13.9565
556	2021-08-30 14:39:22	00:09:35	00:09:11	49.923	-90.056	13.9815
557	2021-08-30 14:39:23	00:09:36	00:09:12	49.922	-90.042	13.994
558	2021-08-30 14:39:24	00:09:37	00:09:13	49.921	-90.065	14.0316
559	2021-08-30 14:39:25	00:09:38	00:09:14	49.922	-90.008	14.0566
560	2021-08-30 14:39:26	00:09:39	00:09:15	49.923	-90.008	14.0816
561	2021-08-30 14:39:27	00:09:40	00:09:16	49.923	-90.026	14.1067
562	2021-08-30 14:39:28	00:09:41	00:09:17	49.924	-90.009	14.1317
563	2021-08-30 14:39:29	00:09:42	00:09:18	49.924	-90.006	14.1567
564	2021-08-30 14:39:30	00:09:43	00:09:19	49.923	-90.039	14.1817
565	2021-08-30 14:39:31	00:09:44	00:09:20	49.92	-90.02	14.2193
566	2021-08-30 14:39:32	00:09:45	00:09:21	49.921	-90.045	14.2443
567	2021-08-30 14:39:33	00:09:46	00:09:22	49.92	-90.002	14.2693
568	2021-08-30 14:39:34	00:09:47	00:09:23	49.919	-90.051	14.2944
569	2021-08-30 14:39:35	00:09:48	00:09:24	49.92	-90.07	14.3194
570	2021-08-30 14:39:36	00:09:49	00:09:25	49.92	-90.089	14.3444
571	2021-08-30 14:39:37	00:09:50	00:09:26	49.922	-90.01	14.3694
572	2021-08-30 14:39:38	00:09:51	00:09:27	49.922	-89.992	14.3945
573	2021-08-30 14:39:39	00:09:52	00:09:28	49.922	-89.991	14.4195
574	2021-08-30 14:39:40	00:09:53	00:09:29	49.923	-89.942	14.4445
575	2021-08-30 14:39:42	00:09:54	00:09:30	49.922	-90.041	14.4695
576	2021-08-30 14:39:43	00:09:55	00:09:31	49.922	-90.057	14.4945
577	2021-08-30 14:39:44	00:09:56	00:09:32	49.921	-90.019	14.5195
578	2021-08-30 14:39:45	00:09:57	00:09:33	49.92	-90.049	14.5446
579	2021-08-30 14:39:46	00:09:58	00:09:34	49.919	-90.014	14.5571
580	2021-08-30 14:39:47	00:09:59	00:09:35	49.918	-90.004	14.5946
581	2021-08-30 14:39:48	00:10:00	00:09:36	49.919	-90.036	14.6196
582	2021-08-30 14:39:49	00:10:01	00:09:37	49.918	-90.072	14.6446
583	2021-08-30 14:39:50	00:10:02	00:09:38	49.917	-90.033	14.6696
584	2021-08-30 14:39:51	00:10:03	00:09:39	49.918	-90	14.6946
585	2021-08-30 14:39:52	00:10:04	00:09:40	49.918	-90.012	14.7197
586	2021-08-30 14:39:53	00:10:05	00:09:41	49.919	-89.976	14.7447
587	2021-08-30 14:39:54	00:10:06	00:09:42	49.918	-89.976	14.7697
588	2021-08-30 14:39:55	00:10:07	00:09:43	49.918	-89.988	14.7947
589	2021-08-30 14:39:56	00:10:08	00:09:44	49.918	-89.969	14.8197
590	2021-08-30 14:39:57	00:10:09	00:09:45	49.916	-90.045	14.8448
591	2021-08-30 14:39:58	00:10:10	00:09:46	49.916	-90.068	14.8697
592	2021-08-30 14:39:59	00:10:11	00:09:47	49.916	-90.003	14.8947
593	2021-08-30 14:40:00	00:10:12	00:09:48	49.916	-90.023	14.9198
594	2021-08-30 14:40:01	00:10:13	00:09:49	49.915	-90.019	14.9323
595	2021-08-30 14:40:02	00:10:14	00:09:50	49.915	-90.021	14.9698
596	2021-08-30 14:40:03	00:10:15	00:09:51	49.916	-90.049	14.9948
597	2021-08-30 14:40:04	00:10:16	00:09:52	49.916	-90.021	15.0198
598	2021-08-30 14:40:05	00:10:17	00:09:53	49.916	-90.045	15.0449
599	2021-08-30 14:40:06	00:10:18	00:09:54	49.916	-90.04	15.0699
600	2021-08-30 14:40:07	00:10:19	00:09:55	49.915	-90.023	15.0949
601	2021-08-30 14:40:08	00:10:20	00:09:56	49.913	-90.032	15.1199
602	2021-08-30 14:40:09	00:10:22	00:09:58	49.915	-90.005	15.1449
603	2021-08-30 14:40:10	00:10:22	00:09:58	49.916	-90.033	15.1699
604	2021-08-30 14:40:11	00:10:24	00:10:00	49.914	-90.025	15.195
605	2021-08-30 14:40:12	00:10:24	00:10:00	49.913	-90.028	15.22
606	2021-08-30 14:40:13	00:10:26	00:10:02	49.913	-90.09	15.2449

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



607	2021-08-30 14:40:14	00:10:26	00:10:02	49.912	-90.019	15.27
608	2021-08-30 14:40:15	00:10:28	00:10:04	49.912	-90.05	15.295
609	2021-08-30 14:40:16	00:10:28	00:10:04	49.912	-90.046	15.3075
610	2021-08-30 14:40:17	00:10:30	00:10:06	49.913	-90.066	15.345
611	2021-08-30 14:40:18	00:10:30	00:10:06	49.913	-90.075	15.37
612	2021-08-30 14:40:19	00:10:32	00:10:08	49.914	-90.052	15.395
613	2021-08-30 14:40:20	00:10:32	00:10:08	49.914	-90.027	15.42
614	2021-08-30 14:40:21	00:10:34	00:10:10	49.914	-90.085	15.445
615	2021-08-30 14:40:22	00:10:34	00:10:10	49.912	-90.039	15.4701
616	2021-08-30 14:40:23	00:10:36	00:10:12	49.912	-90.085	15.4951
617	2021-08-30 14:40:24	00:10:36	00:10:12	49.911	-90.009	15.5201
618	2021-08-30 14:40:25	00:10:38	00:10:14	49.91	-90.013	15.5451
619	2021-08-30 14:40:26	00:10:38	00:10:14	49.91	-90.081	15.5702
620	2021-08-30 14:40:27	00:10:40	00:10:16	49.91	-90.072	15.5952
621	2021-08-30 14:40:28	00:10:40	00:10:16	49.911	-90.037	15.6202
622	2021-08-30 14:40:29	00:10:42	00:10:18	49.911	-90.008	15.6452
623	2021-08-30 14:40:30	00:10:42	00:10:18	49.911	-89.968	15.6702
624	2021-08-30 14:40:31	00:10:44	00:10:20	49.91	-90.073	15.6828
625	2021-08-30 14:40:32	00:10:44	00:10:20	49.909	-90.013	15.7203
626	2021-08-30 14:40:33	00:10:46	00:10:22	49.91	-90.003	15.7453
627	2021-08-30 14:40:34	00:10:46	00:10:22	49.909	-90.079	15.7704
628	2021-08-30 14:40:35	00:10:48	00:10:24	49.908	-90.075	15.7954
629	2021-08-30 14:40:36	00:10:48	00:10:24	49.909	-90	15.8204
630	2021-08-30 14:40:37	00:10:50	00:10:26	49.908	-90.013	15.8455
631	2021-08-30 14:40:38	00:10:50	00:10:26	49.909	-90.052	15.8705
632	2021-08-30 14:40:39	00:10:52	00:10:28	49.909	-90.077	15.8956
633	2021-08-30 14:40:40	00:10:53	00:10:29	49.91	-90.035	15.9206
634	2021-08-30 14:40:41	00:10:54	00:10:30	49.911	-90.023	15.9456
635	2021-08-30 14:40:42	00:10:55	00:10:31	49.91	-90.037	15.9706
636	2021-08-30 14:40:43	00:10:56	00:10:32	49.91	-90.064	15.9956
637	2021-08-30 14:40:44	00:10:57	00:10:33	49.909	-90.065	16.0206
638	2021-08-30 14:40:45	00:10:58	00:10:34	49.909	-90.069	16.0456
639	2021-08-30 14:40:46	00:10:59	00:10:35	49.908	-90.095	16.0832
640	2021-08-30 14:40:47	00:11:00	00:10:36	49.907	-90.003	16.1082
641	2021-08-30 14:40:48	00:11:01	00:10:37	49.908	-90.069	16.1332
642	2021-08-30 14:40:49	00:11:02	00:10:38	49.906	-90.006	16.1583
643	2021-08-30 14:40:50	00:11:03	00:10:39	49.906	-90.045	16.1833
644	2021-08-30 14:40:51	00:11:04	00:10:40	49.906	-90.013	16.2083
645	2021-08-30 14:40:52	00:11:05	00:10:41	49.907	-89.98	16.2333
646	2021-08-30 14:40:53	00:11:06	00:10:42	49.907	-89.954	16.2458
647	2021-08-30 14:40:54	00:11:07	00:10:43	49.908	-89.932	16.2833
648	2021-08-30 14:40:55	00:11:08	00:10:44	49.908	-89.936	16.3083
649	2021-08-30 14:40:56	00:11:09	00:10:45	49.907	-90.01	16.3334
650	2021-08-30 14:40:57	00:11:10	00:10:46	49.907	-90.041	16.3584
651	2021-08-30 14:40:58	00:11:11	00:10:47	49.908	-90.047	16.3834
652	2021-08-30 14:40:59	00:11:12	00:10:48	49.907	-90.02	16.4084
653	2021-08-30 14:41:00	00:11:13	00:10:49	49.906	-90.096	16.4335
654	2021-08-30 14:41:01	00:11:14	00:10:50	49.906	-90.091	16.4585
655	2021-08-30 14:41:02	00:11:15	00:10:51	49.905	-90.092	16.4835
656	2021-08-30 14:41:03	00:11:16	00:10:52	49.904	-90.081	16.5085
657	2021-08-30 14:41:04	00:11:17	00:10:53	49.904	-90.003	16.5335
658	2021-08-30 14:41:05	00:11:18	00:10:54	49.903	-90.018	16.5586
659	2021-08-30 14:41:06	00:11:19	00:10:55	49.902	-90	16.5836
660	2021-08-30 14:41:07	00:11:20	00:10:56	49.902	-90.072	16.6086
661	2021-08-30 14:41:08	00:11:21	00:10:57	49.902	-90.07	16.6211
662	2021-08-30 14:41:09	00:11:22	00:10:58	49.901	-90.045	16.6586
663	2021-08-30 14:41:10	00:11:23	00:10:59	49.901	-90.079	16.6837
664	2021-08-30 14:41:11	00:11:24	00:11:00	49.902	-90.007	16.7087
665	2021-08-30 14:41:12	00:11:25	00:11:01	49.903	-89.967	16.7337
666	2021-08-30 14:41:13	00:11:26	00:11:02	49.902	-90.024	16.7587
667	2021-08-30 14:41:14	00:11:27	00:11:03	49.903	-89.983	16.7837

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



668	2021-08-30 14:41:15	00:11:28	00:11:04	49.902	-90.038	16.8088
669	2021-08-30 14:41:16	00:11:29	00:11:05	49.902	-90.041	16.8338
670	2021-08-30 14:41:17	00:11:30	00:11:06	49.902	-90.073	16.8588
671	2021-08-30 14:41:18	00:11:31	00:11:07	49.902	-90.012	16.8838
672	2021-08-30 14:41:19	00:11:32	00:11:08	49.9	-90.054	16.9089
673	2021-08-30 14:41:20	00:11:33	00:11:09	49.899	-90.092	16.9338
674	2021-08-30 14:41:21	00:11:34	00:11:10	49.897	-90.02	16.9589
675	2021-08-30 14:41:22	00:11:35	00:11:11	49.897	-90.07	16.9839
676	2021-08-30 14:41:23	00:11:36	00:11:12	49.896	-90.022	16.9964
677	2021-08-30 14:41:24	00:11:37	00:11:13	49.896	-90.078	17.0339
678	2021-08-30 14:41:25	00:11:38	00:11:14	49.896	-90.028	17.0589
679	2021-08-30 14:41:26	00:11:39	00:11:15	49.896	-90.012	17.0839
680	2021-08-30 14:41:27	00:11:40	00:11:16	49.896	-90.007	17.1089
681	2021-08-30 14:41:28	00:11:41	00:11:17	49.897	-90.063	17.1339
682	2021-08-30 14:41:29	00:11:42	00:11:18	49.897	-90.041	17.159
683	2021-08-30 14:41:30	00:11:43	00:11:19	49.897	-90.014	17.184
684	2021-08-30 14:41:31	00:11:44	00:11:20	49.897	-89.978	17.2089
685	2021-08-30 14:41:32	00:11:45	00:11:21	49.897	-89.978	17.234
686	2021-08-30 14:41:33	00:11:46	00:11:22	49.896	-90.008	17.259
687	2021-08-30 14:41:34	00:11:47	00:11:23	49.896	-89.984	17.284
688	2021-08-30 14:41:35	00:11:48	00:11:24	49.895	-90.01	17.309
689	2021-08-30 14:41:36	00:11:49	00:11:25	49.894	-90.004	17.334
690	2021-08-30 14:41:37	00:11:50	00:11:26	49.894	-90.074	17.359
691	2021-08-30 14:41:38	00:11:51	00:11:27	49.893	-90.065	17.3715
692	2021-08-30 14:41:39	00:11:52	00:11:28	49.893	-90.045	17.4091
693	2021-08-30 14:41:40	00:11:53	00:11:29	49.891	-90.005	17.4341
694	2021-08-30 14:41:41	00:11:54	00:11:30	49.892	-90.019	17.4591
695	2021-08-30 14:41:42	00:11:55	00:11:31	49.893	-90.076	17.4841
696	2021-08-30 14:41:43	00:11:56	00:11:32	49.892	-90.087	17.5091
697	2021-08-30 14:41:44	00:11:57	00:11:33	49.891	-90.08	17.5341
698	2021-08-30 14:41:45	00:11:58	00:11:34	49.891	-90.049	17.5591
699	2021-08-30 14:41:46	00:11:59	00:11:35	49.891	-90.062	17.5841
700	2021-08-30 14:41:47	00:12:00	00:11:36	49.892	-90.028	17.6091
701	2021-08-30 14:41:48	00:12:01	00:11:37	49.893	-90.027	17.6341
702	2021-08-30 14:41:49	00:12:02	00:11:38	49.892	-90.028	17.6591
703	2021-08-30 14:41:50	00:12:03	00:11:39	49.892	-90.042	17.6841
704	2021-08-30 14:41:51	00:12:04	00:11:40	49.893	-90.034	17.7091
705	2021-08-30 14:41:52	00:12:05	00:11:41	49.89	-90.021	17.7342
706	2021-08-30 14:41:53	00:12:06	00:11:42	49.89	-90.048	17.7467
707	2021-08-30 14:41:54	00:12:07	00:11:43	49.89	-90.013	17.7842
708	2021-08-30 14:41:55	00:12:08	00:11:44	49.889	-90.046	17.8092
709	2021-08-30 14:41:56	00:12:09	00:11:45	49.889	-90.007	17.8342
710	2021-08-30 14:41:57	00:12:10	00:11:46	49.889	-90.058	17.8592
711	2021-08-30 14:41:58	00:12:11	00:11:47	49.889	-90.091	17.8842
712	2021-08-30 14:41:59	00:12:12	00:11:48	49.889	-90.049	17.9092
713	2021-08-30 14:42:00	00:12:13	00:11:49	49.89	-90.017	17.9342
714	2021-08-30 14:42:01	00:12:14	00:11:50	49.891	-90.011	17.9592
715	2021-08-30 14:42:02	00:12:15	00:11:51	49.891	-90.017	17.9842
716	2021-08-30 14:42:03	00:12:16	00:11:52	49.889	-90.045	18.0093
717	2021-08-30 14:42:04	00:12:17	00:11:53	49.889	-89.977	18.0342
718	2021-08-30 14:42:05	00:12:18	00:11:54	49.888	-90.082	18.0593
719	2021-08-30 14:42:06	00:12:19	00:11:55	49.888	-90.059	18.0843
720	2021-08-30 14:42:07	00:12:20	00:11:56	49.887	-90.051	18.1093
721	2021-08-30 14:42:08	00:12:21	00:11:57	49.886	-90.092	18.1218
722	2021-08-30 14:42:09	00:12:22	00:11:58	49.886	-90.047	18.1593
723	2021-08-30 14:42:10	00:12:23	00:11:59	49.884	-90.064	18.1843
724	2021-08-30 14:42:11	00:12:24	00:12:00	49.886	-89.987	18.2093
725	2021-08-30 14:42:12	00:12:25	00:12:01	49.887	-89.996	18.2343
726	2021-08-30 14:42:13	00:12:26	00:12:02	49.885	-90.048	18.2594
727	2021-08-30 14:42:14	00:12:27	00:12:03	49.886	-89.969	18.2844
728	2021-08-30 14:42:15	00:12:28	00:12:04	49.886	-90.038	18.3094

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



729	2021-08-30 14:42:16	00:12:29	00:12:05	49.886	-90.031	18.3344
730	2021-08-30 14:42:17	00:12:30	00:12:06	49.886	-90.055	18.3594
731	2021-08-30 14:42:18	00:12:31	00:12:07	49.886	-90.06	18.3844
732	2021-08-30 14:42:19	00:12:32	00:12:08	49.884	-90.035	18.4095
733	2021-08-30 14:42:20	00:12:33	00:12:09	49.884	-90.093	18.4344
734	2021-08-30 14:42:21	00:12:34	00:12:10	49.883	-90.062	18.4595
735	2021-08-30 14:42:22	00:12:35	00:12:11	49.884	-89.995	18.4845
736	2021-08-30 14:42:23	00:12:36	00:12:12	49.882	-90.013	18.497
737	2021-08-30 14:42:24	00:12:37	00:12:13	49.882	-89.963	18.5346
738	2021-08-30 14:42:25	00:12:38	00:12:14	49.883	-89.985	18.5596
739	2021-08-30 14:42:26	00:12:39	00:12:15	49.882	-90.006	18.5846
740	2021-08-30 14:42:27	00:12:40	00:12:16	49.882	-90.053	18.6222
741	2021-08-30 14:42:28	00:12:41	00:12:17	49.881	-90.07	18.6472
742	2021-08-30 14:42:29	00:12:42	00:12:18	49.88	-90.048	18.6722
743	2021-08-30 14:42:30	00:12:43	00:12:19	49.879	-90.082	18.6847
744	2021-08-30 14:42:32	00:12:44	00:12:20	49.879	-90.01	18.7223
745	2021-08-30 14:42:33	00:12:45	00:12:21	49.878	-90.083	18.7473
746	2021-08-30 14:42:34	00:12:46	00:12:22	49.877	-90.049	18.7723
747	2021-08-30 14:42:35	00:12:47	00:12:23	49.877	-90.051	18.7973
748	2021-08-30 14:42:36	00:12:48	00:12:24	49.876	-90.039	18.8224
749	2021-08-30 14:42:37	00:12:49	00:12:25	49.878	-90.001	18.8474
750	2021-08-30 14:42:38	00:12:50	00:12:26	49.877	-90.013	18.8724
751	2021-08-30 14:42:39	00:12:51	00:12:27	49.878	-89.975	18.8974
752	2021-08-30 14:42:40	00:12:52	00:12:28	49.878	-89.946	18.9224
753	2021-08-30 14:42:41	00:12:53	00:12:29	49.879	-89.906	18.9474
754	2021-08-30 14:42:42	00:12:54	00:12:30	49.878	-90.011	18.9725
755	2021-08-30 14:42:43	00:12:55	00:12:31	49.877	-90.027	18.9975
756	2021-08-30 14:42:44	00:12:56	00:12:32	49.876	-90.066	19.0225
757	2021-08-30 14:42:45	00:12:57	00:12:33	49.876	-90.071	19.0476
758	2021-08-30 14:42:46	00:12:58	00:12:34	49.875	-90.072	19.0601
759	2021-08-30 14:42:47	00:12:59	00:12:35	49.873	-90.002	19.0976
760	2021-08-30 14:42:48	00:13:00	00:12:36	49.873	-90.018	19.1226
761	2021-08-30 14:42:49	00:13:01	00:12:37	49.873	-90.04	19.1476
762	2021-08-30 14:42:50	00:13:02	00:12:38	49.873	-90.002	19.1726
763	2021-08-30 14:42:51	00:13:03	00:12:39	49.872	-90.058	19.1976
764	2021-08-30 14:42:52	00:13:04	00:12:40	49.873	-90.059	19.2226
765	2021-08-30 14:42:53	00:13:05	00:12:41	49.873	-90.068	19.2477
766	2021-08-30 14:42:54	00:13:06	00:12:42	49.873	-90	19.2727
767	2021-08-30 14:42:55	00:13:08	00:12:44	49.873	-90.041	19.2977
768	2021-08-30 14:42:56	00:13:08	00:12:44	49.874	-89.964	19.3227
769	2021-08-30 14:42:57	00:13:10	00:12:46	49.873	-90.023	19.3477
770	2021-08-30 14:42:58	00:13:10	00:12:46	49.873	-90.019	19.3727
771	2021-08-30 14:42:59	00:13:12	00:12:48	49.875	-89.966	19.3977
772	2021-08-30 14:43:00	00:13:12	00:12:48	49.873	-90.039	19.4228
773	2021-08-30 14:43:01	00:13:14	00:12:50	49.873	-90.042	19.4353
774	2021-08-30 14:43:02	00:13:14	00:12:50	49.871	-90.045	19.4727
775	2021-08-30 14:43:03	00:13:16	00:12:52	49.87	-90.083	19.4977
776	2021-08-30 14:43:04	00:13:16	00:12:52	49.87	-90.081	19.5228
777	2021-08-30 14:43:05	00:13:18	00:12:54	49.87	-90.079	19.5478
778	2021-08-30 14:43:06	00:13:18	00:12:54	49.869	-90.015	19.5728
779	2021-08-30 14:43:07	00:13:20	00:12:56	49.868	-90.044	19.5978
780	2021-08-30 14:43:08	00:13:20	00:12:56	49.866	-90.024	19.6229
781	2021-08-30 14:43:09	00:13:22	00:12:58	49.866	-90.062	19.6478
782	2021-08-30 14:43:10	00:13:22	00:12:58	49.866	-90.053	19.6728
783	2021-08-30 14:43:11	00:13:24	00:13:00	49.865	-90.022	19.6979
784	2021-08-30 14:43:12	00:13:24	00:13:00	49.864	-90.001	19.7229
785	2021-08-30 14:43:13	00:13:26	00:13:02	49.865	-90.04	19.7478
786	2021-08-30 14:43:14	00:13:26	00:13:02	49.865	-89.996	19.7728
787	2021-08-30 14:43:15	00:13:28	00:13:04	49.864	-90.005	19.7978
788	2021-08-30 14:43:16	00:13:28	00:13:04	49.864	-89.982	19.8104
789	2021-08-30 14:43:17	00:13:30	00:13:06	49.864	-90.049	19.8479

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



790	2021-08-30 14:43:18	00:13:30	00:13:06	49.865	-90.071	19.8729
791	2021-08-30 14:43:19	00:13:32	00:13:08	49.865	-90.034	19.8979
792	2021-08-30 14:43:20	00:13:32	00:13:08	49.865	-90.01	19.9229
793	2021-08-30 14:43:21	00:13:34	00:13:10	49.864	-90.008	19.9479
794	2021-08-30 14:43:22	00:13:35	00:13:11	49.864	-90.086	19.9729
795	2021-08-30 14:43:23	00:13:36	00:13:12	49.86	-90.082	19.9979
796	2021-08-30 14:43:24	00:13:37	00:13:13	49.861	-90.068	20.0354
797	2021-08-30 14:43:25	00:13:38	00:13:14	49.86	-90.003	20.0604
798	2021-08-30 14:43:26	00:13:39	00:13:15	49.861	-90.011	20.0855
799	2021-08-30 14:43:27	00:13:40	00:13:16	49.861	-90.074	20.1104
800	2021-08-30 14:43:28	00:13:41	00:13:17	49.862	-90.078	20.1355
801	2021-08-30 14:43:29	00:13:42	00:13:18	49.861	-90.053	20.1605
802	2021-08-30 14:43:30	00:13:43	00:13:19	49.863	-90.007	20.1855
803	2021-08-30 14:43:31	00:13:44	00:13:20	49.862	-90.061	20.2105
804	2021-08-30 14:43:32	00:13:45	00:13:21	49.863	-90.083	20.2355
805	2021-08-30 14:43:33	00:13:46	00:13:22	49.86	-90.054	20.2605
806	2021-08-30 14:43:34	00:13:47	00:13:23	49.86	-90.017	20.2855
807	2021-08-30 14:43:35	00:13:48	00:13:24	49.86	-90.035	20.3105
808	2021-08-30 14:43:36	00:13:49	00:13:25	49.86	-90.049	20.3355
809	2021-08-30 14:43:37	00:13:50	00:13:26	49.86	-90.03	20.3605
810	2021-08-30 14:43:38	00:13:51	00:13:27	49.859	-90.076	20.373
811	2021-08-30 14:43:39	00:13:52	00:13:28	49.859	-90.003	20.4105
812	2021-08-30 14:43:40	00:13:53	00:13:29	49.858	-90.05	20.4356
813	2021-08-30 14:43:41	00:13:54	00:13:30	49.86	-90.055	20.4606
814	2021-08-30 14:43:42	00:13:55	00:13:31	49.858	-90.005	20.4856
815	2021-08-30 14:43:43	00:13:56	00:13:32	49.857	-90.029	20.5107
816	2021-08-30 14:43:44	00:13:57	00:13:33	49.858	-90.016	20.5357
817	2021-08-30 14:43:45	00:13:58	00:13:34	49.857	-90.087	20.5607
818	2021-08-30 14:43:46	00:13:59	00:13:35	49.857	-90.036	20.5857
819	2021-08-30 14:43:47	00:14:00	00:13:36	49.857	-90.062	20.6107
820	2021-08-30 14:43:48	00:14:01	00:13:37	49.857	-90.073	20.6357
821	2021-08-30 14:43:49	00:14:02	00:13:38	49.856	-90.061	20.6608
822	2021-08-30 14:43:50	00:14:03	00:13:39	49.856	-89.988	20.6858
823	2021-08-30 14:43:51	00:14:04	00:13:40	49.855	-90.019	20.7108
824	2021-08-30 14:43:52	00:14:05	00:13:41	49.854	-90.055	20.7358
825	2021-08-30 14:43:53	00:14:06	00:13:42	49.855	-90.05	20.7483
826	2021-08-30 14:43:54	00:14:07	00:13:43	49.853	-90.093	20.7858
827	2021-08-30 14:43:55	00:14:08	00:13:44	49.852	-90.041	20.8108
828	2021-08-30 14:43:56	00:14:09	00:13:45	49.851	-90.002	20.8358
829	2021-08-30 14:43:57	00:14:10	00:13:46	49.851	-90.096	20.8609
830	2021-08-30 14:43:58	00:14:11	00:13:47	49.852	-90.076	20.8859
831	2021-08-30 14:43:59	00:14:12	00:13:48	49.852	-90.034	20.9109
832	2021-08-30 14:44:00	00:14:13	00:13:49	49.853	-89.978	20.9359
833	2021-08-30 14:44:01	00:14:14	00:13:50	49.853	-89.956	20.9609
834	2021-08-30 14:44:02	00:14:15	00:13:51	49.851	-90.002	20.9859
835	2021-08-30 14:44:03	00:14:16	00:13:52	49.851	-90.044	21.0109
836	2021-08-30 14:44:04	00:14:17	00:13:53	49.852	-90.01	21.0359
837	2021-08-30 14:44:05	00:14:18	00:13:54	49.852	-90.049	21.0609
838	2021-08-30 14:44:06	00:14:19	00:13:55	49.85	-90.098	21.0859
839	2021-08-30 14:44:07	00:14:20	00:13:56	49.849	-90.078	21.1109
840	2021-08-30 14:44:08	00:14:21	00:13:57	49.847	-90.055	21.1234
841	2021-08-30 14:44:09	00:14:22	00:13:58	49.847	-90.012	21.1609
842	2021-08-30 14:44:10	00:14:23	00:13:59	49.847	-90.049	21.1859
843	2021-08-30 14:44:11	00:14:24	00:14:00	49.847	-90.054	21.2109
844	2021-08-30 14:44:12	00:14:25	00:14:01	49.847	-90.055	21.2359
845	2021-08-30 14:44:13	00:14:26	00:14:02	49.847	-90.076	21.2609
846	2021-08-30 14:44:14	00:14:27	00:14:03	49.847	-90.005	21.2859
847	2021-08-30 14:44:15	00:14:28	00:14:04	49.847	-90.024	21.3109
848	2021-08-30 14:44:16	00:14:29	00:14:05	49.844	-90.097	21.3359
849	2021-08-30 14:44:17	00:14:30	00:14:06	49.844	-90.089	21.3609
850	2021-08-30 14:44:18	00:14:31	00:14:07	49.843	-90.032	21.3859

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



851	2021-08-30 14:44:19	00:14:32	00:14:08	49.841	-90.094	21.411
852	2021-08-30 14:44:20	00:14:33	00:14:09	49.841	-90.012	21.436
853	2021-08-30 14:44:21	00:14:34	00:14:10	49.841	-90.051	21.461
854	2021-08-30 14:44:22	00:14:35	00:14:11	49.841	-90.025	21.486
855	2021-08-30 14:44:23	00:14:36	00:14:12	49.841	-90.04	21.4986
856	2021-08-30 14:44:24	00:14:37	00:14:13	49.841	-89.96	21.5361
857	2021-08-30 14:44:25	00:14:38	00:14:14	49.841	-89.986	21.5611
858	2021-08-30 14:44:26	00:14:39	00:14:15	49.842	-89.999	21.5861
859	2021-08-30 14:44:27	00:14:40	00:14:16	49.841	-90.027	21.6111
860	2021-08-30 14:44:28	00:14:41	00:14:17	49.839	-90.077	21.6361
861	2021-08-30 14:44:29	00:14:42	00:14:18	49.84	-90.013	21.6611
862	2021-08-30 14:44:30	00:14:43	00:14:19	49.84	-90.066	21.6862
863	2021-08-30 14:44:31	00:14:44	00:14:20	49.839	-90.007	21.7112
864	2021-08-30 14:44:32	00:14:45	00:14:21	49.839	-90.097	21.7362
865	2021-08-30 14:44:33	00:14:46	00:14:22	49.837	-90.027	21.7612
866	2021-08-30 14:44:34	00:14:47	00:14:23	49.836	-90.003	21.7862
867	2021-08-30 14:44:35	00:14:48	00:14:24	49.835	-90.063	21.8113
868	2021-08-30 14:44:36	00:14:49	00:14:25	49.837	-90.044	21.8362
869	2021-08-30 14:44:37	00:14:50	00:14:26	49.836	-90.055	21.8613
870	2021-08-30 14:44:38	00:14:51	00:14:27	49.836	-90.016	21.8738
871	2021-08-30 14:44:39	00:14:52	00:14:28	49.837	-89.969	21.9113
872	2021-08-30 14:44:40	00:14:53	00:14:29	49.837	-89.967	21.9362
873	2021-08-30 14:44:41	00:14:54	00:14:30	49.836	-90.003	21.9613
874	2021-08-30 14:44:42	00:14:55	00:14:31	49.836	-89.997	21.9863
875	2021-08-30 14:44:43	00:14:56	00:14:32	49.836	-90.014	22.0113
876	2021-08-30 14:44:44	00:14:57	00:14:33	49.836	-90.019	22.0363
877	2021-08-30 14:44:45	00:14:58	00:14:34	49.834	-90.015	22.0613
878	2021-08-30 14:44:46	00:14:59	00:14:35	49.832	-90.096	22.0864
879	2021-08-30 14:44:47	00:15:00	00:14:36	49.831	-90.086	22.1114
880	2021-08-30 14:44:48	00:15:01	00:14:37	49.831	-90.072	22.1364
881	2021-08-30 14:44:49	00:15:02	00:14:38	49.83	-90.052	22.1614
882	2021-08-30 14:44:50	00:15:03	00:14:39	49.83	-90.005	22.1864
883	2021-08-30 14:44:51	00:15:04	00:14:40	49.83	-90.08	22.2239
884	2021-08-30 14:44:53	00:15:05	00:14:41	49.831	-90.036	22.2489
885	2021-08-30 14:44:54	00:15:06	00:14:42	49.831	-89.986	22.2739
886	2021-08-30 14:44:55	00:15:07	00:14:43	49.83	-90.005	22.299
887	2021-08-30 14:44:56	00:15:08	00:14:44	49.83	-89.974	22.3239
888	2021-08-30 14:44:57	00:15:09	00:14:45	49.831	-89.932	22.3489
889	2021-08-30 14:44:58	00:15:10	00:14:46	49.83	-90.018	22.3739
890	2021-08-30 14:44:59	00:15:11	00:14:47	49.831	-89.97	22.3989
891	2021-08-30 14:45:00	00:15:12	00:14:48	49.833	-89.972	22.4239
892	2021-08-30 14:45:01	00:15:13	00:14:49	49.831	-90.016	22.4364
893	2021-08-30 14:45:02	00:15:14	00:14:50	49.83	-90.054	22.4739
894	2021-08-30 14:45:03	00:15:15	00:14:51	49.829	-90.004	22.4989
895	2021-08-30 14:45:04	00:15:16	00:14:52	49.828	-90.026	22.524
896	2021-08-30 14:45:05	00:15:17	00:14:53	49.828	-90.039	22.549
897	2021-08-30 14:45:06	00:15:18	00:14:54	49.827	-90.025	22.5739
898	2021-08-30 14:45:07	00:15:19	00:14:55	49.826	-90.041	22.599
899	2021-08-30 14:45:08	00:15:20	00:14:56	49.827	-90.068	22.624
900	2021-08-30 14:45:09	00:15:21	00:14:57	49.826	-90.075	22.6489
901	2021-08-30 14:45:10	00:15:22	00:14:58	49.825	-90.073	22.674
902	2021-08-30 14:45:11	00:15:23	00:14:59	49.823	-90.044	22.699
903	2021-08-30 14:45:12	00:15:24	00:15:00	49.825	-89.995	22.724
904	2021-08-30 14:45:13	00:15:25	00:15:01	49.824	-90.028	22.749
905	2021-08-30 14:45:14	00:15:26	00:15:02	49.823	-89.959	22.774
906	2021-08-30 14:45:15	00:15:27	00:15:03	49.823	-89.919	22.799
907	2021-08-30 14:45:16	00:15:28	00:15:04	49.823	-89.907	22.8115
908	2021-08-30 14:45:17	00:15:29	00:15:05	49.823	-89.923	22.849
909	2021-08-30 14:45:18	00:15:30	00:15:06	49.821	-90.014	22.874
910	2021-08-30 14:45:19	00:15:32	00:15:08	49.821	-90.041	22.899
911	2021-08-30 14:45:20	00:15:32	00:15:08	49.82	-90.053	22.924

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



912	2021-08-30 14:45:21	00:15:34	00:15:10	49.819	-90.04	22.949
913	2021-08-30 14:45:22	00:15:34	00:15:10	49.819	-90.046	22.974
914	2021-08-30 14:45:23	00:15:36	00:15:12	49.819	-90.076	22.999
915	2021-08-30 14:45:24	00:15:36	00:15:12	49.819	-90.087	23.024
916	2021-08-30 14:45:25	00:15:38	00:15:14	49.817	-90.073	23.049
917	2021-08-30 14:45:26	00:15:38	00:15:14	49.818	-90.086	23.074
918	2021-08-30 14:45:27	00:15:40	00:15:16	49.818	-90.056	23.0991
919	2021-08-30 14:45:28	00:15:40	00:15:16	49.82	-90.009	23.1241
920	2021-08-30 14:45:29	00:15:42	00:15:18	49.82	-89.952	23.149
921	2021-08-30 14:45:30	00:15:42	00:15:18	49.82	-89.915	23.174
922	2021-08-30 14:45:31	00:15:44	00:15:20	49.819	-89.968	23.1865
923	2021-08-30 14:45:32	00:15:44	00:15:20	49.819	-89.999	23.224
924	2021-08-30 14:45:33	00:15:46	00:15:22	49.817	-90.099	23.2491
925	2021-08-30 14:45:34	00:15:46	00:15:22	49.817	-90.027	23.2741
926	2021-08-30 14:45:35	00:15:48	00:15:24	49.817	-90.009	23.2991
927	2021-08-30 14:45:36	00:15:48	00:15:24	49.815	-90.012	23.3241
928	2021-08-30 14:45:37	00:15:50	00:15:26	49.812	-90.062	23.3492
929	2021-08-30 14:45:38	00:15:50	00:15:26	49.812	-90.076	23.3741
930	2021-08-30 14:45:39	00:15:52	00:15:28	49.811	-90.012	23.3992
931	2021-08-30 14:45:40	00:15:52	00:15:28	49.811	-90.061	23.4242
932	2021-08-30 14:45:41	00:15:54	00:15:30	49.811	-90.043	23.4492
933	2021-08-30 14:45:42	00:15:54	00:15:30	49.811	-90.003	23.4742
934	2021-08-30 14:45:43	00:15:56	00:15:32	49.811	-90.062	23.4992
935	2021-08-30 14:45:44	00:15:56	00:15:32	49.812	-90.034	23.5242
936	2021-08-30 14:45:45	00:15:58	00:15:34	49.81	-90.007	23.5493
937	2021-08-30 14:45:46	00:15:58	00:15:34	49.808	-90.061	23.5618
938	2021-08-30 14:45:47	00:16:00	00:15:36	49.806	-90.066	23.5993
939	2021-08-30 14:45:48	00:16:01	00:15:37	49.806	-90.038	23.6243
940	2021-08-30 14:45:49	00:16:02	00:15:38	49.806	-90.071	23.6619
941	2021-08-30 14:45:50	00:16:03	00:15:39	49.806	-90.03	23.6869
942	2021-08-30 14:45:51	00:16:04	00:15:40	49.807	-90.021	23.7119
943	2021-08-30 14:45:52	00:16:05	00:15:41	49.806	-90.069	23.7369
944	2021-08-30 14:45:53	00:16:06	00:15:42	49.807	-90.042	23.7495
945	2021-08-30 14:45:54	00:16:07	00:15:43	49.807	-89.993	23.787
946	2021-08-30 14:45:55	00:16:08	00:15:44	49.806	-90.093	23.812
947	2021-08-30 14:45:56	00:16:09	00:15:45	49.805	-90.092	23.837
948	2021-08-30 14:45:57	00:16:10	00:15:46	49.805	-90.067	23.862
949	2021-08-30 14:45:58	00:16:11	00:15:47	49.804	-90.035	23.8871
950	2021-08-30 14:45:59	00:16:12	00:15:48	49.803	-90.078	23.9121
951	2021-08-30 14:46:00	00:16:13	00:15:49	49.803	-90	23.9371
952	2021-08-30 14:46:01	00:16:14	00:15:50	49.803	-90.098	23.9621
953	2021-08-30 14:46:02	00:16:15	00:15:51	49.803	-90.029	23.9871
954	2021-08-30 14:46:03	00:16:16	00:15:52	49.803	-90.027	24.0121
955	2021-08-30 14:46:04	00:16:17	00:15:53	49.802	-90.036	24.0372
956	2021-08-30 14:46:05	00:16:18	00:15:54	49.802	-89.957	24.0622
957	2021-08-30 14:46:06	00:16:19	00:15:55	49.8	-90.081	24.0872
958	2021-08-30 14:46:07	00:16:20	00:15:56	49.799	-90.067	24.1122
959	2021-08-30 14:46:08	00:16:21	00:15:57	49.799	-90.032	24.1247
960	2021-08-30 14:46:09	00:16:22	00:15:58	49.799	-90.019	24.1623
961	2021-08-30 14:46:10	00:16:23	00:15:59	49.798	-90.028	24.1873
962	2021-08-30 14:46:11	00:16:24	00:16:00	49.798	-90.042	24.2123
963	2021-08-30 14:46:12	00:16:25	00:16:01	49.799	-89.996	24.2373
964	2021-08-30 14:46:13	00:16:26	00:16:02	49.799	-89.989	24.2623
965	2021-08-30 14:46:14	00:16:27	00:16:03	49.799	-89.977	24.2873
966	2021-08-30 14:46:15	00:16:28	00:16:04	49.798	-89.99	24.3123
967	2021-08-30 14:46:16	00:16:29	00:16:05	49.796	-90.044	24.3373
968	2021-08-30 14:46:17	00:16:30	00:16:06	49.795	-90.087	24.3624
969	2021-08-30 14:46:18	00:16:31	00:16:07	49.795	-90.081	24.3873
970	2021-08-30 14:46:19	00:16:32	00:16:08	49.794	-90.034	24.4124
971	2021-08-30 14:46:20	00:16:33	00:16:09	49.793	-90.025	24.4374
972	2021-08-30 14:46:21	00:16:34	00:16:10	49.792	-90.076	24.4624

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



973	2021-08-30 14:46:22	00:16:35	00:16:11	49.792	-90.049	24.4874
974	2021-08-30 14:46:23	00:16:36	00:16:12	49.791	-90.022	24.4999
975	2021-08-30 14:46:24	00:16:37	00:16:13	49.792	-90.007	24.5374
976	2021-08-30 14:46:25	00:16:38	00:16:14	49.792	-90.037	24.5624
977	2021-08-30 14:46:26	00:16:39	00:16:15	49.79	-90.021	24.5875
978	2021-08-30 14:46:27	00:16:40	00:16:16	49.79	-90.014	24.6125
979	2021-08-30 14:46:28	00:16:41	00:16:17	49.791	-90.065	24.6375
980	2021-08-30 14:46:29	00:16:42	00:16:18	49.79	-90.078	24.6625
981	2021-08-30 14:46:30	00:16:43	00:16:19	49.788	-90.054	24.6876
982	2021-08-30 14:46:31	00:16:44	00:16:20	49.788	-90.033	24.7126
983	2021-08-30 14:46:32	00:16:45	00:16:21	49.788	-90.092	24.7376
984	2021-08-30 14:46:33	00:16:46	00:16:22	49.79	-90.059	24.7626
985	2021-08-30 14:46:34	00:16:47	00:16:23	49.79	-90.054	24.7877
986	2021-08-30 14:46:35	00:16:48	00:16:24	49.791	-89.998	24.8127
987	2021-08-30 14:46:36	00:16:49	00:16:25	49.789	-90.066	24.8377
988	2021-08-30 14:46:37	00:16:50	00:16:26	49.789	-90.084	24.8627
989	2021-08-30 14:46:38	00:16:51	00:16:27	49.787	-90.089	24.8752
990	2021-08-30 14:46:39	00:16:52	00:16:28	49.787	-90.042	24.9128
991	2021-08-30 14:46:40	00:16:53	00:16:29	49.786	-90.014	24.9378
992	2021-08-30 14:46:41	00:16:54	00:16:30	49.785	-90.003	24.9628
993	2021-08-30 14:46:42	00:16:55	00:16:31	49.785	-90.056	24.9878
994	2021-08-30 14:46:43	00:16:56	00:16:32	49.784	-90.037	25.0129
995	2021-08-30 14:46:44	00:16:57	00:16:33	49.784	-90.052	25.0379
996	2021-08-30 14:46:45	00:16:58	00:16:34	49.784	-90.028	25.0629
997	2021-08-30 14:46:46	00:16:59	00:16:35	49.785	-90.004	25.0879
998	2021-08-30 14:46:47	00:17:00	00:16:36	49.784	-90.005	25.113
999	2021-08-30 14:46:48	00:17:01	00:16:37	49.783	-90.013	25.138
1000	2021-08-30 14:46:49	00:17:02	00:16:38	49.782	-90.032	25.163
1001	2021-08-30 14:46:50	00:17:03	00:16:39	49.782	-90.04	25.188
1002	2021-08-30 14:46:51	00:17:04	00:16:40	49.78	-90.039	25.213
1003	2021-08-30 14:46:52	00:17:05	00:16:41	49.779	-90.092	25.2381
1004	2021-08-30 14:46:54	00:17:06	00:16:42	49.78	-90.025	25.2756
1005	2021-08-30 14:46:55	00:17:07	00:16:43	49.779	-90.027	25.3006
1006	2021-08-30 14:46:56	00:17:08	00:16:44	49.779	-90.065	25.3256
1007	2021-08-30 14:46:57	00:17:09	00:16:45	49.778	-90.024	25.3506
1008	2021-08-30 14:46:58	00:17:10	00:16:46	49.779	-90.03	25.3756
1009	2021-08-30 14:46:59	00:17:11	00:16:47	49.779	-89.972	25.4006
1010	2021-08-30 14:47:00	00:17:12	00:16:48	49.779	-89.963	25.4256
1011	2021-08-30 14:47:01	00:17:13	00:16:49	49.778	-89.992	25.4381
1012	2021-08-30 14:47:02	00:17:14	00:16:50	49.778	-90.006	25.4756
1013	2021-08-30 14:47:03	00:17:15	00:16:51	49.776	-90.046	25.5006
1014	2021-08-30 14:47:04	00:17:16	00:16:52	49.776	-90.066	25.5257
1015	2021-08-30 14:47:05	00:17:17	00:16:53	49.776	-90.051	25.5507
1016	2021-08-30 14:47:06	00:17:18	00:16:54	49.776	-90.099	25.5757
1017	2021-08-30 14:47:07	00:17:19	00:16:55	49.775	-90.021	25.6007
1018	2021-08-30 14:47:08	00:17:20	00:16:56	49.774	-90.056	25.6257
1019	2021-08-30 14:47:09	00:17:21	00:16:57	49.774	-90.076	25.6507
1020	2021-08-30 14:47:10	00:17:22	00:16:58	49.772	-90.06	25.6757
1021	2021-08-30 14:47:11	00:17:23	00:16:59	49.771	-90.087	25.7007
1022	2021-08-30 14:47:12	00:17:24	00:17:00	49.772	-90.064	25.7257
1023	2021-08-30 14:47:13	00:17:25	00:17:01	49.772	-90.001	25.7507
1024	2021-08-30 14:47:14	00:17:26	00:17:02	49.771	-90.027	25.7758
1025	2021-08-30 14:47:15	00:17:27	00:17:03	49.77	-90.015	25.8008
1026	2021-08-30 14:47:16	00:17:28	00:17:04	49.77	-89.98	25.8133
1027	2021-08-30 14:47:17	00:17:29	00:17:05	49.772	-89.965	25.8508
1028	2021-08-30 14:47:18	00:17:30	00:17:06	49.77	-90.003	25.8759
1029	2021-08-30 14:47:19	00:17:31	00:17:07	49.77	-89.964	25.9009
1030	2021-08-30 14:47:20	00:17:32	00:17:08	49.771	-89.968	25.9259
1031	2021-08-30 14:47:21	00:17:33	00:17:09	49.769	-90.002	25.951
1032	2021-08-30 14:47:22	00:17:34	00:17:10	49.767	-90.094	25.976
1033	2021-08-30 14:47:23	00:17:35	00:17:11	49.767	-90.099	26.001

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1034	2021-08-30 14:47:24	00:17:36	00:17:12	49.766	-90.09	26.026
1035	2021-08-30 14:47:25	00:17:38	00:17:14	49.766	-90.032	26.051
1036	2021-08-30 14:47:26	00:17:38	00:17:14	49.767	-90.035	26.076
1037	2021-08-30 14:47:27	00:17:40	00:17:16	49.765	-90.083	26.1011
1038	2021-08-30 14:47:28	00:17:40	00:17:16	49.764	-90.055	26.1261
1039	2021-08-30 14:47:29	00:17:42	00:17:18	49.762	-90.014	26.1511
1040	2021-08-30 14:47:30	00:17:42	00:17:18	49.761	-90.071	26.1762
1041	2021-08-30 14:47:31	00:17:44	00:17:20	49.761	-90.02	26.1887
1042	2021-08-30 14:47:32	00:17:44	00:17:20	49.76	-90.024	26.2262
1043	2021-08-30 14:47:33	00:17:46	00:17:22	49.76	-90.016	26.2512
1044	2021-08-30 14:47:34	00:17:46	00:17:22	49.76	-90.069	26.2762
1045	2021-08-30 14:47:35	00:17:48	00:17:24	49.76	-90.033	26.3012
1046	2021-08-30 14:47:36	00:17:48	00:17:24	49.76	-90.024	26.3263
1047	2021-08-30 14:47:37	00:17:50	00:17:26	49.761	-90.006	26.3513
1048	2021-08-30 14:47:38	00:17:50	00:17:26	49.761	-89.97	26.3762
1049	2021-08-30 14:47:39	00:17:52	00:17:28	49.761	-89.95	26.4012
1050	2021-08-30 14:47:40	00:17:52	00:17:28	49.761	-89.932	26.4263
1051	2021-08-30 14:47:41	00:17:54	00:17:30	49.759	-89.97	26.4513
1052	2021-08-30 14:47:42	00:17:54	00:17:30	49.758	-90.027	26.4763
1053	2021-08-30 14:47:43	00:17:56	00:17:32	49.757	-90.076	26.5013
1054	2021-08-30 14:47:44	00:17:56	00:17:32	49.757	-90.004	26.5263
1055	2021-08-30 14:47:45	00:17:58	00:17:34	49.757	-90.098	26.5513
1056	2021-08-30 14:47:46	00:17:58	00:17:34	49.755	-90.083	26.5638
1057	2021-08-30 14:47:47	00:18:00	00:17:36	49.754	-90.04	26.6013
1058	2021-08-30 14:47:48	00:18:00	00:17:36	49.753	-90.07	26.6263
1059	2021-08-30 14:47:49	00:18:02	00:17:38	49.752	-90.004	26.6514
1060	2021-08-30 14:47:50	00:18:02	00:17:38	49.752	-90.095	26.6764
1061	2021-08-30 14:47:51	00:18:04	00:17:40	49.75	-90.008	26.7014
1062	2021-08-30 14:47:52	00:18:05	00:17:41	49.75	-90.025	26.7264
1063	2021-08-30 14:47:53	00:18:06	00:17:42	49.751	-90.084	26.7514
1064	2021-08-30 14:47:54	00:18:07	00:17:43	49.75	-90.02	26.7765
1065	2021-08-30 14:47:55	00:18:08	00:17:44	49.75	-90.075	26.8015
1066	2021-08-30 14:47:56	00:18:09	00:17:45	49.751	-89.987	26.8389
1067	2021-08-30 14:47:57	00:18:10	00:17:46	49.751	-90.008	26.8639
1068	2021-08-30 14:47:58	00:18:11	00:17:47	49.751	-90.066	26.8889
1069	2021-08-30 14:47:59	00:18:12	00:17:48	49.751	-90.062	26.9139
1070	2021-08-30 14:48:00	00:18:13	00:17:49	49.751	-90.072	26.939
1071	2021-08-30 14:48:01	00:18:14	00:17:50	49.749	-90.051	26.964
1072	2021-08-30 14:48:02	00:18:15	00:17:51	49.749	-90.008	26.989
1073	2021-08-30 14:48:03	00:18:16	00:17:52	49.748	-90.096	27.014
1074	2021-08-30 14:48:04	00:18:17	00:17:53	49.745	-90.078	27.039
1075	2021-08-30 14:48:05	00:18:18	00:17:54	49.745	-90.097	27.064
1076	2021-08-30 14:48:06	00:18:19	00:17:55	49.744	-90.065	27.089
1077	2021-08-30 14:48:07	00:18:20	00:17:56	49.744	-90.035	27.114
1078	2021-08-30 14:48:08	00:18:21	00:17:57	49.745	-90.02	27.1265
1079	2021-08-30 14:48:09	00:18:22	00:17:58	49.745	-89.979	27.164
1080	2021-08-30 14:48:10	00:18:23	00:17:59	49.743	-90.042	27.189
1081	2021-08-30 14:48:11	00:18:24	00:18:00	49.742	-90.092	27.214
1082	2021-08-30 14:48:12	00:18:25	00:18:01	49.741	-90.007	27.239
1083	2021-08-30 14:48:13	00:18:26	00:18:02	49.74	-90.03	27.264
1084	2021-08-30 14:48:14	00:18:27	00:18:03	49.738	-90.052	27.289
1085	2021-08-30 14:48:15	00:18:28	00:18:04	49.738	-90.008	27.314
1086	2021-08-30 14:48:16	00:18:29	00:18:05	49.736	-90.024	27.339
1087	2021-08-30 14:48:17	00:18:30	00:18:06	49.737	-90.029	27.364
1088	2021-08-30 14:48:18	00:18:31	00:18:07	49.737	-90.025	27.3891
1089	2021-08-30 14:48:19	00:18:32	00:18:08	49.735	-90.057	27.4141
1090	2021-08-30 14:48:20	00:18:33	00:18:09	49.736	-89.97	27.4391
1091	2021-08-30 14:48:21	00:18:34	00:18:10	49.735	-90.064	27.4642
1092	2021-08-30 14:48:22	00:18:35	00:18:11	49.734	-90.082	27.4892
1093	2021-08-30 14:48:23	00:18:36	00:18:12	49.735	-90.06	27.5017
1094	2021-08-30 14:48:24	00:18:37	00:18:13	49.734	-90.062	27.5391

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1095	2021-08-30 14:48:25	00:18:38	00:18:14	49.731	-90.07	27.5642
1096	2021-08-30 14:48:26	00:18:39	00:18:15	49.731	-90.078	27.5892
1097	2021-08-30 14:48:27	00:18:40	00:18:16	49.732	-90.051	27.6142
1098	2021-08-30 14:48:28	00:18:41	00:18:17	49.731	-90.092	27.6393
1099	2021-08-30 14:48:29	00:18:42	00:18:18	49.73	-90.079	27.6643
1100	2021-08-30 14:48:30	00:18:43	00:18:19	49.731	-90.012	27.6893
1101	2021-08-30 14:48:31	00:18:44	00:18:20	49.731	-90.017	27.7144
1102	2021-08-30 14:48:32	00:18:45	00:18:21	49.732	-90.029	27.7394
1103	2021-08-30 14:48:33	00:18:46	00:18:22	49.731	-90.045	27.7644
1104	2021-08-30 14:48:34	00:18:47	00:18:23	49.729	-90.069	27.7895
1105	2021-08-30 14:48:35	00:18:48	00:18:24	49.73	-90.054	27.8145
1106	2021-08-30 14:48:36	00:18:49	00:18:25	49.728	-90.031	27.8395
1107	2021-08-30 14:48:37	00:18:50	00:18:26	49.725	-90.063	27.8645
1108	2021-08-30 14:48:38	00:18:51	00:18:27	49.725	-90.043	27.8771
1109	2021-08-30 14:48:39	00:18:52	00:18:28	49.725	-90.064	27.9146
1110	2021-08-30 14:48:40	00:18:53	00:18:29	49.725	-90.01	27.9396
1111	2021-08-30 14:48:41	00:18:54	00:18:30	49.725	-90.004	27.9646
1112	2021-08-30 14:48:42	00:18:55	00:18:31	49.724	-90.098	27.9897
1113	2021-08-30 14:48:43	00:18:56	00:18:32	49.724	-90.072	28.0147
1114	2021-08-30 14:48:44	00:18:57	00:18:33	49.722	-90.012	28.0397
1115	2021-08-30 14:48:45	00:18:58	00:18:34	49.72	-90.019	28.0647
1116	2021-08-30 14:48:46	00:18:59	00:18:35	49.72	-90.081	28.0897
1117	2021-08-30 14:48:47	00:19:00	00:18:36	49.721	-89.998	28.1148
1118	2021-08-30 14:48:48	00:19:01	00:18:37	49.72	-90.031	28.1398
1119	2021-08-30 14:48:49	00:19:02	00:18:38	49.72	-90.012	28.1648
1120	2021-08-30 14:48:50	00:19:03	00:18:39	49.719	-90.027	28.1898
1121	2021-08-30 14:48:51	00:19:04	00:18:40	49.719	-89.989	28.2148
1122	2021-08-30 14:48:52	00:19:05	00:18:41	49.72	-90.018	28.2398
1123	2021-08-30 14:48:53	00:19:06	00:18:42	49.72	-90.052	28.2524
1124	2021-08-30 14:48:54	00:19:07	00:18:43	49.719	-89.995	28.2899
1125	2021-08-30 14:48:55	00:19:08	00:18:44	49.719	-89.966	28.3148
1126	2021-08-30 14:48:56	00:19:09	00:18:45	49.719	-89.951	28.3398
1127	2021-08-30 14:48:57	00:19:10	00:18:46	49.718	-89.96	28.3648
1128	2021-08-30 14:48:58	00:19:11	00:18:47	49.717	-89.969	28.3899
1129	2021-08-30 14:48:59	00:19:12	00:18:48	49.716	-89.962	28.4149
1130	2021-08-30 14:49:00	00:19:13	00:18:49	49.716	-89.962	28.4398
1131	2021-08-30 14:49:01	00:19:14	00:18:50	49.716	-89.99	28.4648
1132	2021-08-30 14:49:02	00:19:15	00:18:51	49.715	-90.027	28.4898
1133	2021-08-30 14:49:03	00:19:16	00:18:52	49.715	-90.023	28.5148
1134	2021-08-30 14:49:04	00:19:17	00:18:53	49.715	-90.047	28.5398
1135	2021-08-30 14:49:05	00:19:18	00:18:54	49.714	-90.058	28.5648
1136	2021-08-30 14:49:06	00:19:19	00:18:55	49.711	-90.026	28.5899
1137	2021-08-30 14:49:07	00:19:20	00:18:56	49.71	-90.036	28.6149
1138	2021-08-30 14:49:08	00:19:21	00:18:57	49.71	-90.025	28.6274
1139	2021-08-30 14:49:09	00:19:22	00:18:58	49.706	-90.074	28.665
1140	2021-08-30 14:49:10	00:19:23	00:18:59	49.706	-90.051	28.69
1141	2021-08-30 14:49:11	00:19:24	00:19:00	49.706	-90.077	28.715
1142	2021-08-30 14:49:12	00:19:25	00:19:01	49.706	-90.004	28.74
1143	2021-08-30 14:49:13	00:19:26	00:19:02	49.705	-90.042	28.7651
1144	2021-08-30 14:49:14	00:19:27	00:19:03	49.705	-90.001	28.7901
1145	2021-08-30 14:49:15	00:19:28	00:19:04	49.704	-90.025	28.8151
1146	2021-08-30 14:49:16	00:19:29	00:19:05	49.704	-90.067	28.8401
1147	2021-08-30 14:49:17	00:19:30	00:19:06	49.704	-90.023	28.8652
1148	2021-08-30 14:49:18	00:19:31	00:19:07	49.702	-90.039	28.8902
1149	2021-08-30 14:49:19	00:19:32	00:19:08	49.703	-89.987	28.9152
1150	2021-08-30 14:49:20	00:19:33	00:19:09	49.703	-89.952	28.9402
1151	2021-08-30 14:49:21	00:19:34	00:19:10	49.704	-90.079	28.9652
1152	2021-08-30 14:49:22	00:19:35	00:19:11	49.701	-90.027	28.9903
1153	2021-08-30 14:49:23	00:19:36	00:19:12	49.701	-90.008	29.0028
1154	2021-08-30 14:49:24	00:19:37	00:19:13	49.7	-90.063	29.0403
1155	2021-08-30 14:49:25	00:19:38	00:19:14	49.698	-90.089	29.0654

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1156	2021-08-30 14:49:26	00:19:39	00:19:15	49.698	-90.035	29.0904
1157	2021-08-30 14:49:27	00:19:40	00:19:16	49.698	-90.084	29.1154
1158	2021-08-30 14:49:28	00:19:41	00:19:17	49.697	-90.062	29.1404
1159	2021-08-30 14:49:29	00:19:42	00:19:18	49.697	-90	29.1654
1160	2021-08-30 14:49:30	00:19:43	00:19:19	49.695	-90.01	29.1905
1161	2021-08-30 14:49:31	00:19:44	00:19:20	49.696	-89.959	29.2155
1162	2021-08-30 14:49:32	00:19:45	00:19:21	49.696	-89.98	29.2405
1163	2021-08-30 14:49:33	00:19:46	00:19:22	49.694	-90.018	29.2656
1164	2021-08-30 14:49:34	00:19:47	00:19:23	49.695	-89.971	29.2906
1165	2021-08-30 14:49:35	00:19:48	00:19:24	49.694	-90.011	29.3155
1166	2021-08-30 14:49:37	00:19:49	00:19:25	49.692	-90.058	29.3406
1167	2021-08-30 14:49:38	00:19:50	00:19:26	49.694	-89.974	29.3656
1168	2021-08-30 14:49:39	00:19:51	00:19:27	49.692	-89.938	29.403
1169	2021-08-30 14:49:40	00:19:52	00:19:28	49.693	-89.904	29.428
1170	2021-08-30 14:49:41	00:19:53	00:19:29	49.693	-89.965	29.453
1171	2021-08-30 14:49:42	00:19:54	00:19:30	49.693	-89.965	29.478
1172	2021-08-30 14:49:43	00:19:55	00:19:31	49.689	-89.983	29.503
1173	2021-08-30 14:49:44	00:19:56	00:19:32	49.69	-89.963	29.528
1174	2021-08-30 14:49:45	00:19:57	00:19:33	49.688	-90.043	29.553
1175	2021-08-30 14:49:46	00:19:58	00:19:34	49.686	-90.097	29.5655
1176	2021-08-30 14:49:47	00:19:59	00:19:35	49.686	-90.053	29.603
1177	2021-08-30 14:49:48	00:20:00	00:19:36	49.686	-90.037	29.628
1178	2021-08-30 14:49:49	00:20:01	00:19:37	49.684	-90.084	29.653
1179	2021-08-30 14:49:50	00:20:02	00:19:38	49.685	-90.051	29.678
1180	2021-08-30 14:49:51	00:20:03	00:19:39	49.686	-89.996	29.703
1181	2021-08-30 14:49:52	00:20:04	00:19:40	49.686	-89.991	29.728
1182	2021-08-30 14:49:53	00:20:05	00:19:41	49.684	-90.052	29.7531
1183	2021-08-30 14:49:54	00:20:06	00:19:42	49.685	-90.019	29.778
1184	2021-08-30 14:49:55	00:20:07	00:19:43	49.684	-90.063	29.8031
1185	2021-08-30 14:49:56	00:20:08	00:19:44	49.681	-90.066	29.8281
1186	2021-08-30 14:49:57	00:20:09	00:19:45	49.681	-90.008	29.8531
1187	2021-08-30 14:49:58	00:20:10	00:19:46	49.681	-90.018	29.8782
1188	2021-08-30 14:49:59	00:20:11	00:19:47	49.681	-90.067	29.9032
1189	2021-08-30 14:50:00	00:20:12	00:19:48	49.681	-90.069	29.9283
1190	2021-08-30 14:50:01	00:20:14	00:19:50	49.681	-90.014	29.9408
1191	2021-08-30 14:50:02	00:20:14	00:19:50	49.682	-90.04	29.9783
1192	2021-08-30 14:50:03	00:20:16	00:00:00	49.68	-90.042	30.0033
1193	2021-08-30 14:50:04	00:20:16	00:00:00	49.906	0	30.0108
1194	2021-08-30 14:50:05	00:20:18	00:00:01	50.297	0	30.0108
1195	2021-08-30 14:50:06	00:20:18	00:00:02	50.611	0	30.0108
1196	2021-08-30 14:50:07	00:20:20	00:00:03	50.863	0	30.0108
1197	2021-08-30 14:50:08	00:20:20	00:00:04	51.064	0	30.0108
1198	2021-08-30 14:50:09	00:20:22	00:00:05	51.225	0	30.0108
1199	2021-08-30 14:50:10	00:20:22	00:00:06	51.355	0	30.0108
1200	2021-08-30 14:50:11	00:20:24	00:00:07	51.461	0	30.0108
1201	2021-08-30 14:50:12	00:20:24	00:00:08	51.549	0	30.0108
1202	2021-08-30 14:50:13	00:20:26	00:00:09	51.653	0	30.0108
1203	2021-08-30 14:50:14	00:20:26	00:00:10	51.709	0	30.0108
1204	2021-08-30 14:50:15	00:20:28	00:00:11	51.756	0	30.0108
1205	2021-08-30 14:50:16	00:20:28	00:00:12	51.796	0	30.0108
1206	2021-08-30 14:50:17	00:20:30	00:00:13	51.831	0	30.0108
1207	2021-08-30 14:50:18	00:20:30	00:00:14	51.862	0	30.0108
1208	2021-08-30 14:50:19	00:20:32	00:00:15	51.876	0	30.0108
1209	2021-08-30 14:50:20	00:20:32	00:00:16	51.903	0	30.0108
1210	2021-08-30 14:50:21	00:20:34	00:00:17	51.926	0	30.0108
1211	2021-08-30 14:50:22	00:20:34	00:00:18	51.947	0	30.0108
1212	2021-08-30 14:50:23	00:20:36	00:00:19	51.967	0	30.0108
1213	2021-08-30 14:50:24	00:20:36	00:00:20	51.985	0	30.0108
1214	2021-08-30 14:50:25	00:20:38	00:00:21	52.002	0	30.0108
1215	2021-08-30 14:50:26	00:20:38	00:00:22	52.018	0	30.0108
1216	2021-08-30 14:50:27	00:20:40	00:00:23	52.033	0	30.0108

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1217	2021-08-30 14:50:28	00:20:40	00:00:24	52.054	0	30.0108
1218	2021-08-30 14:50:29	00:20:42	00:00:25	52.068	0	30.0108
1219	2021-08-30 14:50:30	00:20:42	00:00:26	52.08	0	30.0108
1220	2021-08-30 14:50:31	00:20:44	00:00:27	52.092	0	30.0108
1221	2021-08-30 14:50:32	00:20:44	00:00:28	52.104	0	30.0108
1222	2021-08-30 14:50:33	00:20:46	00:00:29	52.116	0	30.0108
1223	2021-08-30 14:50:34	00:20:47	00:00:30	52.121	0	30.0108
1224	2021-08-30 14:50:35	00:20:48	00:00:31	52.131	0	30.0108
1225	2021-08-30 14:50:36	00:20:49	00:00:32	52.141	0	30.0108
1226	2021-08-30 14:50:37	00:20:50	00:00:33	52.151	0	30.0108
1227	2021-08-30 14:50:38	00:20:51	00:00:34	52.16	0	30.0108
1228	2021-08-30 14:50:39	00:20:52	00:00:35	52.17	0	30.0108
1229	2021-08-30 14:50:40	00:20:53	00:00:36	52.179	0	30.0108
1230	2021-08-30 14:50:41	00:20:54	00:00:37	52.187	0	30.0108
1231	2021-08-30 14:50:42	00:20:55	00:00:38	52.196	0	30.0108
1232	2021-08-30 14:50:43	00:20:56	00:00:39	52.208	0	30.0108
1233	2021-08-30 14:50:44	00:20:57	00:00:40	52.216	0	30.0108
1234	2021-08-30 14:50:45	00:20:58	00:00:41	52.224	0	30.0108
1235	2021-08-30 14:50:46	00:20:59	00:00:42	52.231	0	30.0108
1236	2021-08-30 14:50:47	00:21:00	00:00:43	52.239	0	30.0108
1237	2021-08-30 14:50:48	00:21:01	00:00:44	52.246	0	30.0108
1238	2021-08-30 14:50:49	00:21:02	00:00:45	52.252	0	30.0108
1239	2021-08-30 14:50:50	00:21:03	00:00:46	52.261	0	30.0108
1240	2021-08-30 14:50:51	00:21:04	00:00:47	52.267	0	30.0108
1241	2021-08-30 14:50:52	00:21:05	00:00:48	52.273	0	30.0108
1242	2021-08-30 14:50:53	00:21:06	00:00:49	52.279	0	30.0108
1243	2021-08-30 14:50:54	00:21:07	00:00:50	52.285	0	30.0108
1244	2021-08-30 14:50:55	00:21:08	00:00:52	52.291	0	30.0108
1245	2021-08-30 14:50:56	00:21:09	00:00:52	52.294	0	30.0108
1246	2021-08-30 14:50:57	00:21:10	00:00:54	52.3	0	30.0108
1247	2021-08-30 14:50:58	00:21:11	00:00:54	52.305	0	30.0108
1248	2021-08-30 14:50:59	00:21:12	00:00:56	52.31	0	30.0108
1249	2021-08-30 14:51:00	00:21:13	00:00:56	52.316	0	30.0108
1250	2021-08-30 14:51:01	00:21:14	00:00:58	52.321	0	30.0108
1251	2021-08-30 14:51:02	00:21:15	00:00:58	52.325	0	30.0108
1252	2021-08-30 14:51:03	00:21:16	00:01:00	52.329	0	30.0108
1253	2021-08-30 14:51:04	00:21:17	00:01:00	52.334	0	30.0108
1254	2021-08-30 14:51:05	00:21:18	00:01:02	52.341	0	30.0108
1255	2021-08-30 14:51:06	00:21:19	00:01:02	52.345	0	30.0108
1256	2021-08-30 14:51:07	00:21:20	00:01:04	52.349	0	30.0108
1257	2021-08-30 14:51:08	00:21:21	00:01:04	52.354	0	30.0108
1258	2021-08-30 14:51:09	00:21:22	00:01:06	52.358	0	30.0108
1259	2021-08-30 14:51:10	00:21:23	00:01:06	52.362	0	30.0108
1260	2021-08-30 14:51:11	00:21:24	00:01:08	52.364	0	30.0108
1261	2021-08-30 14:51:12	00:21:25	00:01:08	52.368	0	30.0108
1262	2021-08-30 14:51:13	00:21:26	00:01:10	52.372	0	30.0108
1263	2021-08-30 14:51:14	00:21:27	00:01:10	52.376	0	30.0108
1264	2021-08-30 14:51:15	00:21:28	00:01:12	52.38	0	30.0108
1265	2021-08-30 14:51:16	00:21:29	00:01:12	52.384	0	30.0108
1266	2021-08-30 14:51:17	00:21:30	00:01:14	52.388	0	30.0108
1267	2021-08-30 14:51:18	00:21:31	00:01:14	52.39	0	30.0108
1268	2021-08-30 14:51:19	00:21:32	00:01:16	52.394	0	30.0108
1269	2021-08-30 14:51:20	00:21:33	00:01:16	52.399	0	30.0108
1270	2021-08-30 14:51:21	00:21:34	00:01:18	52.403	0	30.0108
1271	2021-08-30 14:51:22	00:21:35	00:01:18	52.405	0	30.0108
1272	2021-08-30 14:51:23	00:21:36	00:01:20	52.407	0	30.0108
1273	2021-08-30 14:51:24	00:21:37	00:01:20	52.409	0	30.0108
1274	2021-08-30 14:51:25	00:21:38	00:01:22	52.411	0	30.0108
1275	2021-08-30 14:51:26	00:21:39	00:01:22	52.412	0	30.0108
1276	2021-08-30 14:51:27	00:21:40	00:01:24	52.414	0	30.0108
1277	2021-08-30 14:51:28	00:21:41	00:01:25	52.417	0	30.0108

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing

1278	2021-08-30 14:51:29	00:21:42	00:01:26	52.421	0	30.0108
1279	2021-08-30 14:51:30	00:21:43	00:01:27	52.424	0	30.0108
1280	2021-08-30 14:51:31	00:21:44	00:01:28	52.427	0	30.0108
1281	2021-08-30 14:51:32	00:21:45	00:01:29	52.43	0	30.0108
1282	2021-08-30 14:51:33	00:21:46	00:01:30	52.433	0	30.0108
1283	2021-08-30 14:51:34	00:21:47	00:01:31	52.435	0	30.0108
1284	2021-08-30 14:51:35	00:21:48	00:01:32	52.438	0	30.0108
1285	2021-08-30 14:51:36	00:21:49	00:01:33	52.44	0	30.0108
1286	2021-08-30 14:51:37	00:21:50	00:01:34	52.442	0	30.0108
1287	2021-08-30 14:51:38	00:21:51	00:01:35	52.445	0	30.0108
1288	2021-08-30 14:51:39	00:21:52	00:01:36	52.447	0	30.0108
1289	2021-08-30 14:51:40	00:21:53	00:01:37	52.45	0	30.0108
1290	2021-08-30 14:51:41	00:21:54	00:01:38	52.451	0	30.0108
1291	2021-08-30 14:51:42	00:21:55	00:01:39	52.453	0	30.0108
1292	2021-08-30 14:51:43	00:21:56	00:01:40	52.455	0	30.0108
1293	2021-08-30 14:51:44	00:21:57	00:01:41	52.457	0	30.0108
1294	2021-08-30 14:51:45	00:21:58	00:01:42	52.459	0	30.0108
1295	2021-08-30 14:51:46	00:21:59	00:01:43	52.461	0	30.0108
1296	2021-08-30 14:51:47	00:22:00	00:01:44	52.463	0	30.0108
1297	2021-08-30 14:51:48	00:22:01	00:01:45	52.465	0	30.0108
1298	2021-08-30 14:51:49	00:22:02	00:01:46	52.467	0	30.0108
1299	2021-08-30 14:51:50	00:22:03	00:01:47	52.47	0	30.0108
1300	2021-08-30 14:51:51	00:22:04	00:01:48	52.472	0	30.0108
1301	2021-08-30 14:51:52	00:22:05	00:01:49	52.474	0	30.0108
1302	2021-08-30 14:51:53	00:22:06	00:01:50	52.476	0	30.0108
1303	2021-08-30 14:51:54	00:22:07	00:01:51	52.477	0	30.0108
1304	2021-08-30 14:51:55	00:22:08	00:01:52	52.478	0	30.0108
1305	2021-08-30 14:51:56	00:22:09	00:01:53	52.479	0	30.0108
1306	2021-08-30 14:51:58	00:22:11	00:01:54	52.481	0	30.0108
1307	2021-08-30 14:51:59	00:22:11	00:01:55	52.482	0	30.0108
1308	2021-08-30 14:52:00	00:22:13	00:01:56	52.484	0	30.0108
1309	2021-08-30 14:52:01	00:22:13	00:01:57	52.486	0	30.0108
1310	2021-08-30 14:52:02	00:22:15	00:01:58	52.486	0	30.0108
1311	2021-08-30 14:52:03	00:22:15	00:01:59	52.487	0	30.0108
1312	2021-08-30 14:52:04	00:22:17	00:02:00	52.489	0	30.0108
1313	2021-08-30 14:52:05	00:22:17	00:02:01	52.491	0	30.0108
1314	2021-08-30 14:52:06	00:22:19	00:02:02	52.493	0	30.0108
1315	2021-08-30 14:52:07	00:22:19	00:02:03	52.495	0	30.0108
1316	2021-08-30 14:52:08	00:22:21	00:02:04	52.496	0	30.0108
1317	2021-08-30 14:52:09	00:22:21	00:02:05	52.497	0	30.0108
1318	2021-08-30 14:52:10	00:22:23	00:02:06	52.498	0	30.0108
1319	2021-08-30 14:52:11	00:22:23	00:02:07	52.499	0	30.0108
1320	2021-08-30 14:52:12	00:22:25	00:02:08	52.5	0	30.0108
1321	2021-08-30 14:52:13	00:22:25	00:02:09	52.503	0	30.0108
1322	2021-08-30 14:52:14	00:22:27	00:02:10	52.503	0	30.0108
1323	2021-08-30 14:52:15	00:22:27	00:02:11	52.503	0	30.0108
1324	2021-08-30 14:52:16	00:22:29	00:02:12	52.504	0	30.0108
1325	2021-08-30 14:52:17	00:22:29	00:02:13	52.506	0	30.0108
1326	2021-08-30 14:52:18	00:22:31	00:02:14	52.507	0	30.0108
1327	2021-08-30 14:52:19	00:22:31	00:02:15	52.507	0	30.0108
1328	2021-08-30 14:52:20	00:22:33	00:02:16	52.508	0	30.0108
1329	2021-08-30 14:52:21	00:22:33	00:02:17	52.509	0	30.0108
1330	2021-08-30 14:52:22	00:22:35	00:02:18	52.511	0	30.0108
1331	2021-08-30 14:52:23	00:22:35	00:02:19	52.512	0	30.0108
1332	2021-08-30 14:52:24	00:22:37	00:02:20	52.513	0	30.0108
1333	2021-08-30 14:52:25	00:22:37	00:02:21	52.515	0	30.0108
1334	2021-08-30 14:52:26	00:22:39	00:02:22	52.515	0	30.0108
1335	2021-08-30 14:52:27	00:22:39	00:02:23	52.516	0	30.0108
1336	2021-08-30 14:52:28	00:22:41	00:02:24	52.518	0	30.0108
1337	2021-08-30 14:52:29	00:22:41	00:02:25	52.518	0	30.0108
1338	2021-08-30 14:52:30	00:22:43	00:02:26	52.519	0	30.0108

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1339	2021-08-30 14:52:31	00:22:43	00:02:27	52.52	0	30.0108
1340	2021-08-30 14:52:32	00:22:45	00:02:28	52.521	0	30.0108
1341	2021-08-30 14:52:33	00:22:46	00:02:29	52.522	0	30.0108
1342	2021-08-30 14:52:34	00:22:47	00:02:30	52.523	0	30.0108
1343	2021-08-30 14:52:35	00:22:48	00:02:31	52.524	0	30.0108
1344	2021-08-30 14:52:36	00:22:49	00:02:32	52.524	0	30.0108
1345	2021-08-30 14:52:37	00:22:50	00:02:33	52.525	0	30.0108
1346	2021-08-30 14:52:38	00:22:51	00:02:34	52.526	0	30.0108
1347	2021-08-30 14:52:39	00:22:52	00:02:35	52.526	0	30.0108
1348	2021-08-30 14:52:40	00:22:53	00:02:36	52.528	0	30.0108
1349	2021-08-30 14:52:41	00:22:54	00:02:37	52.529	0	30.0108
1350	2021-08-30 14:52:42	00:22:55	00:02:38	52.529	0	30.0108
1351	2021-08-30 14:52:43	00:22:56	00:02:39	52.53	0	30.0108
1352	2021-08-30 14:52:44	00:22:57	00:02:40	52.531	0	30.0108
1353	2021-08-30 14:52:45	00:22:58	00:02:41	52.532	0	30.0108
1354	2021-08-30 14:52:46	00:22:59	00:02:42	52.534	0	30.0108
1355	2021-08-30 14:52:47	00:23:00	00:02:43	52.534	0	30.0108
1356	2021-08-30 14:52:48	00:23:01	00:02:44	52.534	0	30.0108
1357	2021-08-30 14:52:49	00:23:02	00:02:45	52.534	0	30.0108
1358	2021-08-30 14:52:50	00:23:03	00:02:46	52.536	0	30.0108
1359	2021-08-30 14:52:51	00:23:04	00:02:47	52.537	0	30.0108
1360	2021-08-30 14:52:52	00:23:05	00:02:48	52.537	0	30.0108
1361	2021-08-30 14:52:53	00:23:06	00:02:49	52.537	0	30.0108
1362	2021-08-30 14:52:54	00:23:07	00:02:50	52.538	0	30.0108
1363	2021-08-30 14:52:55	00:23:08	00:02:51	52.539	0	30.0108
1364	2021-08-30 14:52:56	00:23:09	00:02:52	52.54	0	30.0108
1365	2021-08-30 14:52:57	00:23:10	00:02:53	52.54	0	30.0108
1366	2021-08-30 14:52:58	00:23:11	00:02:54	52.541	0	30.0108
1367	2021-08-30 14:52:59	00:23:12	00:02:55	52.542	0	30.0108
1368	2021-08-30 14:53:00	00:23:13	00:02:56	52.543	0	30.0108
1369	2021-08-30 14:53:01	00:23:14	00:02:57	52.544	0	30.0108
1370	2021-08-30 14:53:02	00:23:15	00:02:58	52.545	0	30.0108
1371	2021-08-30 14:53:03	00:23:16	00:02:59	52.545	0	30.0108
1372	2021-08-30 14:53:04	00:23:17	00:03:00	52.545	0	30.0108
1373	2021-08-30 14:53:05	00:23:18	00:03:01	52.545	0	30.0108
1374	2021-08-30 14:53:06	00:23:19	00:03:02	52.545	0	30.0108
1375	2021-08-30 14:53:07	00:23:20	00:03:03	52.546	0	30.0108
1376	2021-08-30 14:53:08	00:23:21	00:03:04	52.546	0	30.0108
1377	2021-08-30 14:53:09	00:23:22	00:03:05	52.547	0	30.0108
1378	2021-08-30 14:53:10	00:23:23	00:03:06	52.549	0	30.0108
1379	2021-08-30 14:53:11	00:23:24	00:03:07	52.551	0	30.0108
1380	2021-08-30 14:53:12	00:23:25	00:03:08	52.552	0	30.0108
1381	2021-08-30 14:53:13	00:23:26	00:03:09	52.552	0	30.0108
1382	2021-08-30 14:53:14	00:23:27	00:03:10	52.552	0	30.0108
1383	2021-08-30 14:53:15	00:23:28	00:03:11	52.552	0	30.0108
1384	2021-08-30 14:53:16	00:23:29	00:03:12	52.552	0	30.0108
1385	2021-08-30 14:53:17	00:23:30	00:03:13	52.553	0	30.0108
1386	2021-08-30 14:53:18	00:23:31	00:03:14	52.554	0	30.0108
1387	2021-08-30 14:53:19	00:23:32	00:03:15	52.554	0	30.0108
1388	2021-08-30 14:53:20	00:23:33	00:03:16	52.556	0	30.0108
1389	2021-08-30 14:53:21	00:23:34	00:03:17	52.556	0	30.0108
1390	2021-08-30 14:53:22	00:23:35	00:03:18	52.556	0	30.0108
1391	2021-08-30 14:53:23	00:23:36	00:03:19	52.557	0	30.0108
1392	2021-08-30 14:53:24	00:23:37	00:03:20	52.558	0	30.0108
1393	2021-08-30 14:53:25	00:23:38	00:03:21	52.559	0	30.0108
1394	2021-08-30 14:53:26	00:23:39	00:03:22	52.56	0	30.0108
1395	2021-08-30 14:53:27	00:23:40	00:03:23	52.561	0	30.0108
1396	2021-08-30 14:53:28	00:23:41	00:03:24	52.561	0	30.0108
1397	2021-08-30 14:53:29	00:23:42	00:03:26	52.561	0	30.0108
1398	2021-08-30 14:53:30	00:23:43	00:03:26	52.561	0	30.0108
1399	2021-08-30 14:53:31	00:23:44	00:03:28	52.562	0	30.0108

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1400	2021-08-30 14:53:32	00:23:45	00:03:28	52.563	0	30.0108
1401	2021-08-30 14:53:33	00:23:46	00:03:30	52.563	0	30.0108
1402	2021-08-30 14:53:34	00:23:47	00:03:30	52.563	0	30.0108
1403	2021-08-30 14:53:35	00:23:48	00:03:32	52.563	0	30.0108
1404	2021-08-30 14:53:36	00:23:49	00:03:32	52.564	0	30.0108
1405	2021-08-30 14:53:37	00:23:50	00:03:34	52.565	0	30.0108
1406	2021-08-30 14:53:38	00:23:51	00:03:34	52.565	0	30.0108
1407	2021-08-30 14:53:39	00:23:52	00:03:36	52.567	0	30.0108
1408	2021-08-30 14:53:40	00:23:53	00:03:36	52.567	0	30.0108
1409	2021-08-30 14:53:41	00:23:54	00:03:38	52.567	0	30.0108
1410	2021-08-30 14:53:42	00:23:55	00:03:38	52.568	0	30.0108
1411	2021-08-30 14:53:43	00:23:56	00:03:40	52.569	0	30.0108
1412	2021-08-30 14:53:44	00:23:57	00:03:40	52.57	0	30.0108
1413	2021-08-30 14:53:45	00:23:58	00:03:42	52.57	0	30.0108
1414	2021-08-30 14:53:46	00:23:59	00:03:42	52.57	0	30.0108
1415	2021-08-30 14:53:47	00:24:00	00:03:44	52.571	0	30.0108
1416	2021-08-30 14:53:48	00:24:01	00:03:44	52.571	0	30.0108
1417	2021-08-30 14:53:49	00:24:02	00:03:46	52.571	0	30.0108
1418	2021-08-30 14:53:50	00:24:03	00:03:46	52.573	0	30.0108
1419	2021-08-30 14:53:51	00:24:04	00:03:48	52.573	0	30.0108
1420	2021-08-30 14:53:52	00:24:05	00:03:48	52.574	0	30.0108
1421	2021-08-30 14:53:53	00:24:06	00:03:50	52.575	0	30.0108
1422	2021-08-30 14:53:54	00:24:07	00:03:50	52.575	0	30.0108
1423	2021-08-30 14:53:55	00:24:08	00:03:52	52.575	0	30.0108
1424	2021-08-30 14:53:56	00:24:09	00:03:52	52.575	0	30.0108
1425	2021-08-30 14:53:57	00:24:10	00:03:54	52.575	0	30.0108
1426	2021-08-30 14:53:58	00:24:11	00:03:54	52.576	0	30.0108
1427	2021-08-30 14:53:59	00:24:12	00:03:56	52.577	0	30.0108
1428	2021-08-30 14:54:00	00:24:13	00:03:56	52.577	0	30.0108
1429	2021-08-30 14:54:01	00:24:14	00:03:58	52.578	0	30.0108
1430	2021-08-30 14:54:02	00:24:15	00:03:58	52.578	0	30.0108
1431	2021-08-30 14:54:03	00:24:16	00:04:00	52.578	0	30.0108
1432	2021-08-30 14:54:04	00:24:17	00:04:00	52.578	0	30.0108
1433	2021-08-30 14:54:05	00:24:18	00:04:02	52.579	0	30.0108
1434	2021-08-30 14:54:06	00:24:19	00:04:02	52.58	0	30.0108
1435	2021-08-30 14:54:07	00:24:20	00:04:04	52.58	0	30.0108
1436	2021-08-30 14:54:08	00:24:21	00:04:05	52.581	0	30.0108
1437	2021-08-30 14:54:09	00:24:22	00:04:06	52.582	0	30.0108
1438	2021-08-30 14:54:10	00:24:23	00:04:07	52.583	0	30.0108
1439	2021-08-30 14:54:11	00:24:24	00:04:08	52.583	0	30.0108
1440	2021-08-30 14:54:12	00:24:25	00:04:09	52.583	0	30.0108
1441	2021-08-30 14:54:13	00:24:26	00:04:10	52.584	0	30.0108
1442	2021-08-30 14:54:14	00:24:27	00:04:11	52.584	0	30.0108
1443	2021-08-30 14:54:15	00:24:28	00:04:12	52.585	0	30.0108
1444	2021-08-30 14:54:16	00:24:29	00:04:13	52.586	0	30.0108
1445	2021-08-30 14:54:17	00:24:30	00:04:14	52.586	0	30.0108
1446	2021-08-30 14:54:18	00:24:31	00:04:15	52.586	0	30.0108
1447	2021-08-30 14:54:19	00:24:32	00:04:16	52.587	0	30.0108
1448	2021-08-30 14:54:20	00:24:33	00:04:17	52.588	0	30.0108
1449	2021-08-30 14:54:21	00:24:34	00:04:18	52.589	0	30.0108
1450	2021-08-30 14:54:22	00:24:35	00:04:19	52.589	0	30.0108
1451	2021-08-30 14:54:23	00:24:36	00:04:20	52.589	0	30.0108
1452	2021-08-30 14:54:24	00:24:37	00:04:21	52.589	0	30.0108
1453	2021-08-30 14:54:25	00:24:38	00:04:22	52.589	0	30.0108
1454	2021-08-30 14:54:27	00:24:39	00:04:23	52.589	0	30.0108
1455	2021-08-30 14:54:28	00:24:41	00:04:24	52.589	0	30.0108
1456	2021-08-30 14:54:29	00:24:41	00:04:25	52.59	0	30.0108
1457	2021-08-30 14:54:30	00:24:43	00:04:26	52.592	0	30.0108
1458	2021-08-30 14:54:31	00:24:43	00:04:27	52.594	0	30.0108
1459	2021-08-30 14:54:32	00:24:45	00:04:28	52.594	0	30.0108
1460	2021-08-30 14:54:33	00:24:45	00:04:29	52.594	0	30.0108

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1461	2021-08-30 14:54:34	00:24:47	00:04:30	52.594	0	30.0108
1462	2021-08-30 14:54:35	00:24:47	00:04:31	52.595	0	30.0108
1463	2021-08-30 14:54:36	00:24:49	00:04:32	52.595	0	30.0108
1464	2021-08-30 14:54:37	00:24:49	00:04:33	52.595	0	30.0108
1465	2021-08-30 14:54:38	00:24:51	00:04:34	52.595	0	30.0108
1466	2021-08-30 14:54:39	00:24:51	00:04:35	52.596	0	30.0108
1467	2021-08-30 14:54:40	00:24:53	00:04:36	52.597	0	30.0108
1468	2021-08-30 14:54:41	00:24:53	00:04:37	52.597	0	30.0108
1469	2021-08-30 14:54:42	00:24:55	00:04:38	52.597	0	30.0108
1470	2021-08-30 14:54:43	00:24:55	00:04:39	52.597	0	30.0108
1471	2021-08-30 14:54:44	00:24:57	00:04:40	52.597	0	30.0108
1472	2021-08-30 14:54:45	00:24:57	00:04:41	52.597	0	30.0108
1473	2021-08-30 14:54:46	00:24:59	00:04:42	52.597	0	30.0108
1474	2021-08-30 14:54:47	00:24:59	00:04:43	52.597	0	30.0108
1475	2021-08-30 14:54:48	00:25:01	00:04:44	52.597	0	30.0108
1476	2021-08-30 14:54:49	00:25:01	00:04:45	52.597	0	30.0108
1477	2021-08-30 14:54:50	00:25:03	00:04:46	52.597	0	30.0108
1478	2021-08-30 14:54:51	00:25:03	00:04:47	52.598	0	30.0108
1479	2021-08-30 14:54:52	00:25:05	00:04:48	52.599	0	30.0108
1480	2021-08-30 14:54:53	00:25:05	00:04:49	52.599	0	30.0108
1481	2021-08-30 14:54:54	00:25:07	00:04:50	52.599	0	30.0108
1482	2021-08-30 14:54:55	00:25:07	00:04:51	52.599	0	30.0108
1483	2021-08-30 14:54:56	00:25:09	00:04:52	52.599	0	30.0108
1484	2021-08-30 14:54:57	00:25:09	00:04:53	52.599	0	30.0108
1485	2021-08-30 14:54:58	00:25:11	00:04:54	52.599	0	30.0108
1486	2021-08-30 14:54:59	00:25:12	00:04:55	52.6	0	30.0108
1487	2021-08-30 14:55:00	00:25:13	00:04:56	52.6	0	30.0108
1488	2021-08-30 14:55:01	00:25:14	00:04:57	52.6	0	30.0108
1489	2021-08-30 14:55:02	00:25:15	00:04:58	52.601	0	30.0108
1490	2021-08-30 14:55:03	00:25:16	00:04:59	52.601	0	30.0108
1491	2021-08-30 14:55:04	00:25:17	00:00:00	52.601	0	30.0227
1492	2021-08-30 14:55:05	00:25:18	00:00:01	49	-180.049	30.0728
1493	2021-08-30 14:55:06	00:25:19	00:00:02	48.945	-180.011	30.1228
1494	2021-08-30 14:55:07	00:25:20	00:00:03	48.875	-180.011	30.1729
1495	2021-08-30 14:55:08	00:25:21	00:00:04	48.802	-180.074	30.2229
1496	2021-08-30 14:55:09	00:25:22	00:00:05	48.728	-180.008	30.273
1497	2021-08-30 14:55:10	00:25:23	00:00:06	48.656	-180.005	30.323
1498	2021-08-30 14:55:11	00:25:24	00:00:07	48.587	-180.012	30.373
1499	2021-08-30 14:55:12	00:25:25	00:00:08	48.49	-180.005	30.423
1500	2021-08-30 14:55:13	00:25:26	00:00:09	48.428	-180.052	30.4731
1501	2021-08-30 14:55:14	00:25:27	00:00:10	48.371	-180.047	30.4981
1502	2021-08-30 14:55:15	00:25:28	00:00:11	48.315	-180.07	30.5731
1503	2021-08-30 14:55:16	00:25:29	00:00:12	48.261	-180.064	30.6231
1504	2021-08-30 14:55:17	00:25:30	00:00:13	48.211	-180.094	30.6732
1505	2021-08-30 14:55:18	00:25:31	00:00:14	48.188	-180.023	30.7232
1506	2021-08-30 14:55:19	00:25:32	00:00:15	48.143	-180.04	30.7732
1507	2021-08-30 14:55:20	00:25:33	00:00:16	48.099	-180.014	30.8232
1508	2021-08-30 14:55:21	00:25:34	00:00:17	48.059	-180.088	30.8732
1509	2021-08-30 14:55:22	00:25:35	00:00:18	48.022	-180.068	30.9232
1510	2021-08-30 14:55:23	00:25:36	00:00:00	47.986	-180.049	30.9733
1511	2021-08-30 14:55:24	00:25:37	00:00:00	51.522	0	30.9818
1512	2021-08-30 14:55:25	00:25:38	00:00:02	51.548	0	30.9818
1513	2021-08-30 14:55:26	00:25:39	00:00:02	51.611	0	30.9818
1514	2021-08-30 14:55:27	00:25:40	00:00:04	51.657	0	30.9818
1515	2021-08-30 14:55:28	00:25:41	00:00:04	51.702	0	30.9818
1516	2021-08-30 14:55:29	00:25:42	00:00:06	51.745	0	30.9818
1517	2021-08-30 14:55:30	00:25:43	00:00:06	51.786	0	30.9818
1518	2021-08-30 14:55:31	00:25:44	00:00:08	51.823	0	30.9818
1519	2021-08-30 14:55:32	00:25:45	00:00:08	51.841	0	30.9818
1520	2021-08-30 14:55:33	00:25:46	00:00:10	51.875	0	30.9818
1521	2021-08-30 14:55:34	00:25:47	00:00:10	51.907	0	30.9818

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1522	2021-08-30 14:55:35	00:25:48	00:00:12	51.937	0	30.9818
1523	2021-08-30 14:55:36	00:25:49	00:00:12	51.964	0	30.9818
1524	2021-08-30 14:55:37	00:25:50	00:00:14	51.99	0	30.9818
1525	2021-08-30 14:55:38	00:25:51	00:00:14	52.013	0	30.9818
1526	2021-08-30 14:55:39	00:25:52	00:00:16	52.035	0	30.9818
1527	2021-08-30 14:55:40	00:25:53	00:00:16	52.055	0	30.9818
1528	2021-08-30 14:55:41	00:25:54	00:00:18	52.084	0	30.9818
1529	2021-08-30 14:55:42	00:25:55	00:00:18	52.102	0	30.9818
1530	2021-08-30 14:55:43	00:25:56	00:00:20	52.118	0	30.9818
1531	2021-08-30 14:55:44	00:25:57	00:00:21	52.134	0	30.9818
1532	2021-08-30 14:55:45	00:25:58	00:00:22	52.149	0	30.9818
1533	2021-08-30 14:55:46	00:25:59	00:00:23	52.163	0	30.9818
1534	2021-08-30 14:55:47	00:26:00	00:00:24	52.17	0	30.9818
1535	2021-08-30 14:55:48	00:26:01	00:00:25	52.196	0	30.9818
1536	2021-08-30 14:55:49	00:26:02	00:00:26	52.208	0	30.9818
1537	2021-08-30 14:55:50	00:26:03	00:00:27	52.22	0	30.9818
1538	2021-08-30 14:55:51	00:26:04	00:00:28	52.231	0	30.9818
1539	2021-08-30 14:55:52	00:26:05	00:00:29	52.241	0	30.9818
1540	2021-08-30 14:55:53	00:26:06	00:00:30	52.251	0	30.9818
1541	2021-08-30 14:55:54	00:26:07	00:00:31	52.256	0	30.9818
1542	2021-08-30 14:55:55	00:26:08	00:00:32	52.265	0	30.9818
1543	2021-08-30 14:55:56	00:26:09	00:00:33	52.274	0	30.9818
1544	2021-08-30 14:55:57	00:26:10	00:00:34	52.282	0	30.9818
1545	2021-08-30 14:55:58	00:26:11	00:00:35	52.29	0	30.9818
1546	2021-08-30 14:55:59	00:26:12	00:00:36	52.298	0	30.9818
1547	2021-08-30 14:56:00	00:26:13	00:00:37	52.306	0	30.9818
1548	2021-08-30 14:56:01	00:26:14	00:00:38	52.314	0	30.9818
1549	2021-08-30 14:56:02	00:26:15	00:00:39	52.322	0	30.9818
1550	2021-08-30 14:56:03	00:26:16	00:00:40	52.332	0	30.9818
1551	2021-08-30 14:56:04	00:26:17	00:00:41	52.338	0	30.9818
1552	2021-08-30 14:56:05	00:26:18	00:00:42	52.344	0	30.9818
1553	2021-08-30 14:56:06	00:26:19	00:00:43	52.35	0	30.9818
1554	2021-08-30 14:56:07	00:26:20	00:00:44	52.356	0	30.9818
1555	2021-08-30 14:56:08	00:26:21	00:00:45	52.362	0	30.9818
1556	2021-08-30 14:56:09	00:26:22	00:00:46	52.365	0	30.9818
1557	2021-08-30 14:56:10	00:26:23	00:00:47	52.371	0	30.9818
1558	2021-08-30 14:56:11	00:26:24	00:00:48	52.377	0	30.9818
1559	2021-08-30 14:56:12	00:26:25	00:00:49	52.382	0	30.9818
1560	2021-08-30 14:56:13	00:26:26	00:00:50	52.386	0	30.9818
1561	2021-08-30 14:56:14	00:26:27	00:00:51	52.39	0	30.9818
1562	2021-08-30 14:56:15	00:26:28	00:00:52	52.395	0	30.9818
1563	2021-08-30 14:56:16	00:26:29	00:00:53	52.4	0	30.9818
1564	2021-08-30 14:56:17	00:26:30	00:00:54	52.404	0	30.9818
1565	2021-08-30 14:56:18	00:26:31	00:00:55	52.41	0	30.9818
1566	2021-08-30 14:56:19	00:26:32	00:00:56	52.414	0	30.9818
1567	2021-08-30 14:56:20	00:26:33	00:00:57	52.418	0	30.9818
1568	2021-08-30 14:56:21	00:26:34	00:00:58	52.422	0	30.9818
1569	2021-08-30 14:56:22	00:26:35	00:00:59	52.426	0	30.9818
1570	2021-08-30 14:56:23	00:26:36	00:01:00	52.43	0	30.9818
1571	2021-08-30 14:56:24	00:26:37	00:01:01	52.432	0	30.9818
1572	2021-08-30 14:56:25	00:26:38	00:01:02	52.436	0	30.9818
1573	2021-08-30 14:56:26	00:26:39	00:01:03	52.44	0	30.9818
1574	2021-08-30 14:56:27	00:26:40	00:01:04	52.444	0	30.9818
1575	2021-08-30 14:56:28	00:26:41	00:01:05	52.446	0	30.9818
1576	2021-08-30 14:56:29	00:26:42	00:01:06	52.45	0	30.9818
1577	2021-08-30 14:56:30	00:26:43	00:01:07	52.454	0	30.9818
1578	2021-08-30 14:56:31	00:26:44	00:01:08	52.457	0	30.9818
1579	2021-08-30 14:56:32	00:26:45	00:01:09	52.459	0	30.9818
1580	2021-08-30 14:56:33	00:26:46	00:01:10	52.463	0	30.9818
1581	2021-08-30 14:56:34	00:26:47	00:01:11	52.465	0	30.9818
1582	2021-08-30 14:56:35	00:26:48	00:01:12	52.468	0	30.9818

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1583	2021-08-30 14:56:36	00:26:49	00:01:13	52.47	0	30.9818
1584	2021-08-30 14:56:37	00:26:50	00:01:14	52.472	0	30.9818
1585	2021-08-30 14:56:38	00:26:51	00:01:15	52.474	0	30.9818
1586	2021-08-30 14:56:39	00:26:52	00:01:16	52.475	0	30.9818
1587	2021-08-30 14:56:40	00:26:53	00:01:17	52.479	0	30.9818
1588	2021-08-30 14:56:41	00:26:54	00:01:18	52.481	0	30.9818
1589	2021-08-30 14:56:42	00:26:55	00:01:19	52.483	0	30.9818
1590	2021-08-30 14:56:43	00:26:56	00:01:20	52.485	0	30.9818
1591	2021-08-30 14:56:44	00:26:57	00:01:21	52.487	0	30.9818
1592	2021-08-30 14:56:45	00:26:58	00:01:22	52.489	0	30.9818
1593	2021-08-30 14:56:46	00:26:59	00:01:23	52.491	0	30.9818
1594	2021-08-30 14:56:47	00:27:00	00:01:24	52.493	0	30.9818
1595	2021-08-30 14:56:48	00:27:01	00:01:25	52.496	0	30.9818
1596	2021-08-30 14:56:49	00:27:02	00:01:26	52.498	0	30.9818
1597	2021-08-30 14:56:50	00:27:03	00:01:27	52.5	0	30.9818
1598	2021-08-30 14:56:51	00:27:04	00:01:28	52.502	0	30.9818
1599	2021-08-30 14:56:52	00:27:05	00:01:29	52.504	0	30.9818
1600	2021-08-30 14:56:53	00:27:06	00:01:30	52.506	0	30.9818
1601	2021-08-30 14:56:54	00:27:07	00:01:31	52.507	0	30.9818
1602	2021-08-30 14:56:55	00:27:08	00:01:32	52.508	0	30.9818
1603	2021-08-30 14:56:56	00:27:09	00:01:33	52.509	0	30.9818
1604	2021-08-30 14:56:57	00:27:10	00:01:34	52.51	0	30.9818
1605	2021-08-30 14:56:58	00:27:11	00:01:35	52.512	0	30.9818
1606	2021-08-30 14:56:59	00:27:12	00:01:36	52.514	0	30.9818
1607	2021-08-30 14:57:00	00:27:13	00:01:37	52.516	0	30.9818
1608	2021-08-30 14:57:01	00:27:14	00:01:38	52.517	0	30.9818
1609	2021-08-30 14:57:02	00:27:15	00:01:39	52.519	0	30.9818
1610	2021-08-30 14:57:03	00:27:16	00:01:40	52.52	0	30.9818
1611	2021-08-30 14:57:04	00:27:17	00:01:41	52.522	0	30.9818
1612	2021-08-30 14:57:05	00:27:18	00:01:42	52.524	0	30.9818
1613	2021-08-30 14:57:06	00:27:19	00:01:43	52.526	0	30.9818
1614	2021-08-30 14:57:07	00:27:20	00:01:44	52.528	0	30.9818
1615	2021-08-30 14:57:08	00:27:21	00:01:45	52.529	0	30.9818
1616	2021-08-30 14:57:09	00:27:22	00:01:46	52.529	0	30.9818
1617	2021-08-30 14:57:10	00:27:23	00:01:47	52.53	0	30.9818
1618	2021-08-30 14:57:11	00:27:24	00:01:48	52.532	0	30.9818
1619	2021-08-30 14:57:12	00:27:25	00:01:49	52.534	0	30.9818
1620	2021-08-30 14:57:13	00:27:26	00:01:50	52.536	0	30.9818
1621	2021-08-30 14:57:14	00:27:27	00:01:51	52.538	0	30.9818
1622	2021-08-30 14:57:15	00:27:28	00:01:52	52.538	0	30.9818
1623	2021-08-30 14:57:16	00:27:29	00:01:53	52.539	0	30.9818
1624	2021-08-30 14:57:18	00:27:30	00:01:54	52.54	0	30.9818
1625	2021-08-30 14:57:19	00:27:31	00:01:55	52.541	0	30.9818
1626	2021-08-30 14:57:20	00:27:32	00:01:56	52.543	0	30.9818
1627	2021-08-30 14:57:21	00:27:33	00:01:57	52.544	0	30.9818
1628	2021-08-30 14:57:22	00:27:34	00:01:58	52.544	0	30.9818
1629	2021-08-30 14:57:23	00:27:35	00:01:59	52.545	0	30.9818
1630	2021-08-30 14:57:24	00:27:36	00:02:00	52.545	0	30.9818
1631	2021-08-30 14:57:25	00:27:37	00:02:01	52.546	0	30.9818
1632	2021-08-30 14:57:26	00:27:39	00:02:02	52.549	0	30.9818
1633	2021-08-30 14:57:27	00:27:39	00:02:03	52.55	0	30.9818
1634	2021-08-30 14:57:28	00:27:41	00:02:04	52.551	0	30.9818
1635	2021-08-30 14:57:29	00:27:41	00:02:05	52.552	0	30.9818
1636	2021-08-30 14:57:30	00:27:43	00:02:06	52.552	0	30.9818
1637	2021-08-30 14:57:31	00:27:43	00:02:07	52.554	0	30.9818
1638	2021-08-30 14:57:32	00:27:45	00:02:08	52.554	0	30.9818
1639	2021-08-30 14:57:33	00:27:45	00:02:09	52.556	0	30.9818
1640	2021-08-30 14:57:34	00:27:47	00:02:10	52.556	0	30.9818
1641	2021-08-30 14:57:35	00:27:47	00:02:11	52.556	0	30.9818
1642	2021-08-30 14:57:36	00:27:49	00:02:12	52.556	0	30.9818
1643	2021-08-30 14:57:37	00:27:49	00:02:13	52.557	0	30.9818

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1644	2021-08-30 14:57:38	00:27:51	00:02:14	52.558	0	30.9818
1645	2021-08-30 14:57:39	00:27:51	00:02:15	52.559	0	30.9818
1646	2021-08-30 14:57:40	00:27:53	00:02:16	52.56	0	30.9818
1647	2021-08-30 14:57:41	00:27:53	00:02:17	52.561	0	30.9818
1648	2021-08-30 14:57:42	00:27:55	00:02:18	52.562	0	30.9818
1649	2021-08-30 14:57:43	00:27:55	00:02:19	52.564	0	30.9818
1650	2021-08-30 14:57:44	00:27:57	00:02:20	52.565	0	30.9818
1651	2021-08-30 14:57:45	00:27:57	00:02:21	52.565	0	30.9818
1652	2021-08-30 14:57:46	00:27:59	00:02:22	52.567	0	30.9818
1653	2021-08-30 14:57:47	00:27:59	00:02:23	52.567	0	30.9818
1654	2021-08-30 14:57:48	00:28:01	00:02:24	52.568	0	30.9818
1655	2021-08-30 14:57:49	00:28:01	00:02:25	52.568	0	30.9818
1656	2021-08-30 14:57:50	00:28:03	00:02:26	52.57	0	30.9818
1657	2021-08-30 14:57:51	00:28:03	00:02:27	52.571	0	30.9818
1658	2021-08-30 14:57:52	00:28:05	00:02:28	52.572	0	30.9818
1659	2021-08-30 14:57:53	00:28:05	00:02:29	52.572	0	30.9818
1660	2021-08-30 14:57:54	00:28:07	00:02:30	52.573	0	30.9818
1661	2021-08-30 14:57:55	00:28:07	00:02:31	52.573	0	30.9818
1662	2021-08-30 14:57:56	00:28:09	00:02:32	52.574	0	30.9818
1663	2021-08-30 14:57:57	00:28:10	00:02:34	52.574	0	30.9818
1664	2021-08-30 14:57:58	00:28:11	00:02:34	52.574	0	30.9818
1665	2021-08-30 14:57:59	00:28:12	00:02:36	52.575	0	30.9818
1666	2021-08-30 14:58:00	00:28:13	00:02:36	52.576	0	30.9818
1667	2021-08-30 14:58:01	00:28:14	00:02:38	52.577	0	30.9818
1668	2021-08-30 14:58:02	00:28:15	00:02:38	52.577	0	30.9818
1669	2021-08-30 14:58:03	00:28:16	00:02:40	52.577	0	30.9818
1670	2021-08-30 14:58:04	00:28:17	00:02:40	52.578	0	30.9818
1671	2021-08-30 14:58:05	00:28:18	00:02:42	52.579	0	30.9818
1672	2021-08-30 14:58:06	00:28:19	00:02:42	52.58	0	30.9818
1673	2021-08-30 14:58:07	00:28:20	00:02:44	52.582	0	30.9818
1674	2021-08-30 14:58:08	00:28:21	00:02:44	52.582	0	30.9818
1675	2021-08-30 14:58:09	00:28:22	00:02:46	52.582	0	30.9818
1676	2021-08-30 14:58:10	00:28:23	00:02:46	52.582	0	30.9818
1677	2021-08-30 14:58:11	00:28:24	00:02:48	52.583	0	30.9818
1678	2021-08-30 14:58:12	00:28:25	00:02:48	52.583	0	30.9818
1679	2021-08-30 14:58:13	00:28:26	00:02:50	52.583	0	30.9818
1680	2021-08-30 14:58:14	00:28:27	00:02:50	52.583	0	30.9818
1681	2021-08-30 14:58:15	00:28:28	00:02:52	52.585	0	30.9818
1682	2021-08-30 14:58:16	00:28:29	00:02:52	52.585	0	30.9818
1683	2021-08-30 14:58:17	00:28:30	00:02:54	52.586	0	30.9818
1684	2021-08-30 14:58:18	00:28:31	00:02:55	52.587	0	30.9818
1685	2021-08-30 14:58:19	00:28:32	00:02:56	52.588	0	30.9818
1686	2021-08-30 14:58:20	00:28:33	00:02:57	52.589	0	30.9818
1687	2021-08-30 14:58:21	00:28:34	00:02:58	52.589	0	30.9818
1688	2021-08-30 14:58:22	00:28:35	00:02:59	52.589	0	30.9818
1689	2021-08-30 14:58:23	00:28:36	00:03:00	52.589	0	30.9818
1690	2021-08-30 14:58:24	00:28:37	00:03:01	52.589	0	30.9818
1691	2021-08-30 14:58:25	00:28:38	00:03:02	52.59	0	30.9818
1692	2021-08-30 14:58:26	00:28:39	00:03:03	52.59	0	30.9818
1693	2021-08-30 14:58:27	00:28:40	00:03:04	52.591	0	30.9818
1694	2021-08-30 14:58:28	00:28:41	00:03:05	52.591	0	30.9818
1695	2021-08-30 14:58:29	00:28:42	00:03:06	52.591	0	30.9818
1696	2021-08-30 14:58:30	00:28:43	00:03:07	52.592	0	30.9818
1697	2021-08-30 14:58:31	00:28:44	00:03:08	52.592	0	30.9818
1698	2021-08-30 14:58:32	00:28:45	00:03:09	52.593	0	30.9818
1699	2021-08-30 14:58:33	00:28:46	00:03:10	52.594	0	30.9818
1700	2021-08-30 14:58:34	00:28:47	00:03:11	52.594	0	30.9818
1701	2021-08-30 14:58:35	00:28:48	00:03:12	52.594	0	30.9818
1702	2021-08-30 14:58:36	00:28:49	00:03:13	52.596	0	30.9818
1703	2021-08-30 14:58:37	00:28:50	00:03:14	52.596	0	30.9818
1704	2021-08-30 14:58:38	00:28:51	00:03:15	52.596	0	30.9818

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1705	2021-08-30 14:58:39	00:28:52	00:03:16	52.596	0	30.9818
1706	2021-08-30 14:58:40	00:28:53	00:03:17	52.596	0	30.9818
1707	2021-08-30 14:58:41	00:28:54	00:03:18	52.598	0	30.9818
1708	2021-08-30 14:58:42	00:28:55	00:03:19	52.599	0	30.9818
1709	2021-08-30 14:58:43	00:28:56	00:03:20	52.599	0	30.9818
1710	2021-08-30 14:58:44	00:28:57	00:03:21	52.599	0	30.9818
1711	2021-08-30 14:58:45	00:28:58	00:03:22	52.599	0	30.9818
1712	2021-08-30 14:58:46	00:28:59	00:03:23	52.599	0	30.9818
1713	2021-08-30 14:58:47	00:29:00	00:03:24	52.599	0	30.9818
1714	2021-08-30 14:58:48	00:29:01	00:03:25	52.599	0	30.9818
1715	2021-08-30 14:58:49	00:29:02	00:03:26	52.599	0	30.9818
1716	2021-08-30 14:58:50	00:29:03	00:03:27	52.599	0	30.9818
1717	2021-08-30 14:58:51	00:29:04	00:03:28	52.599	0	30.9818
1718	2021-08-30 14:58:52	00:29:05	00:03:29	52.599	0	30.9818
1719	2021-08-30 14:58:53	00:29:06	00:03:30	52.599	0	30.9818
1720	2021-08-30 14:58:54	00:29:07	00:03:31	52.599	0	30.9818
1721	2021-08-30 14:58:55	00:29:08	00:03:32	52.599	0	30.9818
1722	2021-08-30 14:58:56	00:29:09	00:03:33	52.599	0	30.9818
1723	2021-08-30 14:58:57	00:29:10	00:03:34	52.6	0	30.9818
1724	2021-08-30 14:58:58	00:29:11	00:03:35	52.602	0	30.9818
1725	2021-08-30 14:58:59	00:29:12	00:03:36	52.603	0	30.9818
1726	2021-08-30 14:59:00	00:29:13	00:03:37	52.604	0	30.9818
1727	2021-08-30 14:59:01	00:29:14	00:03:38	52.605	0	30.9818
1728	2021-08-30 14:59:02	00:29:15	00:03:39	52.605	0	30.9818
1729	2021-08-30 14:59:03	00:29:16	00:03:40	52.606	0	30.9818
1730	2021-08-30 14:59:04	00:29:17	00:03:41	52.606	0	30.9818
1731	2021-08-30 14:59:05	00:29:18	00:03:42	52.607	0	30.9818
1732	2021-08-30 14:59:06	00:29:19	00:03:43	52.607	0	30.9818
1733	2021-08-30 14:59:07	00:29:20	00:03:44	52.607	0	30.9818
1734	2021-08-30 14:59:08	00:29:21	00:03:45	52.607	0	30.9818
1735	2021-08-30 14:59:09	00:29:22	00:03:46	52.607	0	30.9818
1736	2021-08-30 14:59:10	00:29:23	00:03:47	52.607	0	30.9818
1737	2021-08-30 14:59:11	00:29:24	00:03:48	52.608	0	30.9818
1738	2021-08-30 14:59:12	00:29:25	00:03:49	52.609	0	30.9818
1739	2021-08-30 14:59:13	00:29:26	00:03:50	52.609	0	30.9818
1740	2021-08-30 14:59:14	00:29:27	00:03:51	52.609	0	30.9818
1741	2021-08-30 14:59:15	00:29:28	00:03:52	52.609	0	30.9818
1742	2021-08-30 14:59:16	00:29:29	00:03:53	52.609	0	30.9818
1743	2021-08-30 14:59:17	00:29:30	00:03:54	52.611	0	30.9818
1744	2021-08-30 14:59:18	00:29:31	00:03:55	52.611	0	30.9818
1745	2021-08-30 14:59:19	00:29:32	00:03:56	52.612	0	30.9818
1746	2021-08-30 14:59:20	00:29:33	00:03:57	52.612	0	30.9818
1747	2021-08-30 14:59:21	00:29:34	00:03:58	52.613	0	30.9818
1748	2021-08-30 14:59:22	00:29:35	00:03:59	52.613	0	30.9818
1749	2021-08-30 14:59:23	00:29:36	00:04:00	52.613	0	30.9818
1750	2021-08-30 14:59:24	00:29:37	00:04:01	52.613	0	30.9818
1751	2021-08-30 14:59:25	00:29:38	00:04:02	52.614	0	30.9818
1752	2021-08-30 14:59:26	00:29:39	00:04:03	52.614	0	30.9818
1753	2021-08-30 14:59:27	00:29:40	00:04:04	52.614	0	30.9818
1754	2021-08-30 14:59:28	00:29:41	00:04:05	52.614	0	30.9818
1755	2021-08-30 14:59:29	00:29:42	00:04:06	52.614	0	30.9818
1756	2021-08-30 14:59:30	00:29:43	00:04:07	52.614	0	30.9818
1757	2021-08-30 14:59:31	00:29:44	00:04:08	52.614	0	30.9818
1758	2021-08-30 14:59:32	00:29:45	00:04:09	52.614	0	30.9818
1759	2021-08-30 14:59:34	00:29:46	00:04:10	52.616	0	30.9818
1760	2021-08-30 14:59:35	00:29:47	00:04:11	52.616	0	30.9818
1761	2021-08-30 14:59:36	00:29:48	00:04:12	52.616	0	30.9818
1762	2021-08-30 14:59:37	00:29:49	00:04:13	52.616	0	30.9818
1763	2021-08-30 14:59:38	00:29:50	00:04:14	52.616	0	30.9818
1764	2021-08-30 14:59:39	00:29:51	00:04:15	52.616	0	30.9818
1765	2021-08-30 14:59:40	00:29:52	00:04:16	52.616	0	30.9818

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1766	2021-08-30 14:59:41	00:29:53	00:04:17	52.616	0	30.9818
1767	2021-08-30 14:59:42	00:29:54	00:04:18	52.616	0	30.9818
1768	2021-08-30 14:59:43	00:29:55	00:04:19	52.616	0	30.9818
1769	2021-08-30 14:59:44	00:29:56	00:04:20	52.616	0	30.9818
1770	2021-08-30 14:59:45	00:29:57	00:04:21	52.617	0	30.9818
1771	2021-08-30 14:59:46	00:29:59	00:04:22	52.618	0	30.9818
1772	2021-08-30 14:59:47	00:29:59	00:04:23	52.618	0	30.9818
1773	2021-08-30 14:59:48	00:30:01	00:04:25	52.619	0	30.9818
1774	2021-08-30 14:59:49	00:30:01	00:04:25	52.619	0	30.9818
1775	2021-08-30 14:59:50	00:30:03	00:04:27	52.619	0	30.9818
1776	2021-08-30 14:59:51	00:30:03	00:04:27	52.62	0	30.9818
1777	2021-08-30 14:59:52	00:30:05	00:04:29	52.62	0	30.9818
1778	2021-08-30 14:59:53	00:30:05	00:04:29	52.62	0	30.9818
1779	2021-08-30 14:59:54	00:30:07	00:04:31	52.62	0	30.9818
1780	2021-08-30 14:59:55	00:30:07	00:04:31	52.62	0	30.9818
1781	2021-08-30 14:59:56	00:30:09	00:04:33	52.62	0	30.9818
1782	2021-08-30 14:59:57	00:30:09	00:04:33	52.62	0	30.9818
1783	2021-08-30 14:59:58	00:30:11	00:04:35	52.62	0	30.9818
1784	2021-08-30 14:59:59	00:30:11	00:04:35	52.62	0	30.9818
1785	2021-08-30 15:00:00	00:30:13	00:04:37	52.621	0	30.9818
1786	2021-08-30 15:00:01	00:30:13	00:04:37	52.621	0	30.9818
1787	2021-08-30 15:00:02	00:30:15	00:04:39	52.621	0	30.9818
1788	2021-08-30 15:00:03	00:30:15	00:04:39	52.621	0	30.9818
1789	2021-08-30 15:00:04	00:30:17	00:04:41	52.621	0	30.9818
1790	2021-08-30 15:00:05	00:30:17	00:04:41	52.621	0	30.9818
1791	2021-08-30 15:00:06	00:30:19	00:04:43	52.622	0	30.9818
1792	2021-08-30 15:00:07	00:30:19	00:04:43	52.622	0	30.9818
1793	2021-08-30 15:00:08	00:30:21	00:04:45	52.622	0	30.9818
1794	2021-08-30 15:00:09	00:30:21	00:04:45	52.624	0	30.9818
1795	2021-08-30 15:00:10	00:30:23	00:04:47	52.624	0	30.9818
1796	2021-08-30 15:00:11	00:30:23	00:04:47	52.624	0	30.9818
1797	2021-08-30 15:00:12	00:30:25	00:04:49	52.624	0	30.9818
1798	2021-08-30 15:00:13	00:30:25	00:04:49	52.624	0	30.9818
1799	2021-08-30 15:00:14	00:30:27	00:04:51	52.624	0	30.9818
1800	2021-08-30 15:00:15	00:30:27	00:04:51	52.624	0	30.9818
1801	2021-08-30 15:00:16	00:30:29	00:04:53	52.624	0	30.9818
1802	2021-08-30 15:00:17	00:30:29	00:04:53	52.624	0	30.9818
1803	2021-08-30 15:00:18	00:30:31	00:04:55	52.624	0	30.9818
1804	2021-08-30 15:00:19	00:30:31	00:04:55	52.624	0	30.9818
1805	2021-08-30 15:00:20	00:30:33	00:04:57	52.625	0	30.9818
1806	2021-08-30 15:00:21	00:30:33	00:04:57	52.625	0	30.9818
1807	2021-08-30 15:00:22	00:30:35	00:04:59	52.625	0	30.9818
1808	2021-08-30 15:00:23	00:30:35	00:04:59	52.626	0	30.9818
11	2021-08-30 15:04:26	00:00:18	00:00:01	49.145	-90.099	0.3715
12	2021-08-30 15:04:27	00:00:19	00:00:02	49.395	-90.076	0.3966
13	2021-08-30 15:04:28	00:00:20	00:00:03	49.586	-90.089	0.4216
14	2021-08-30 15:04:29	00:00:21	00:00:04	49.734	-90.09	0.4466
15	2021-08-30 15:04:30	00:00:22	00:00:05	49.844	-90.054	0.4716
16	2021-08-30 15:04:31	00:00:23	00:00:06	49.959	-90.018	0.4966
17	2021-08-30 15:04:32	00:00:24	00:00:07	50.01	-90.05	0.5216
18	2021-08-30 15:04:33	00:00:25	00:00:08	50.047	-90.02	0.5341
19	2021-08-30 15:04:34	00:00:26	00:00:09	50.071	-90.004	0.5715
20	2021-08-30 15:04:35	00:00:27	00:00:10	50.088	-89.963	0.5965
21	2021-08-30 15:04:36	00:00:28	00:00:11	50.099	-89.912	0.6215
22	2021-08-30 15:04:37	00:00:29	00:00:12	50.102	-89.996	0.6465
23	2021-08-30 15:04:38	00:00:30	00:00:13	50.104	-89.926	0.6715
24	2021-08-30 15:04:39	00:00:31	00:00:14	50.104	-89.989	0.6965
25	2021-08-30 15:04:40	00:00:32	00:00:15	50.1	-89.984	0.7216
26	2021-08-30 15:04:41	00:00:33	00:00:16	50.096	-89.988	0.7466
27	2021-08-30 15:04:42	00:00:34	00:00:17	50.089	-89.929	0.7715
28	2021-08-30 15:04:43	00:00:35	00:00:18	50.072	-90.004	0.8091

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



29	2021-08-30 15:04:44	00:00:36	00:00:19	50.069	-89.986	0.8341
30	2021-08-30 15:04:45	00:00:37	00:00:20	50.06	-90.019	0.8591
31	2021-08-30 15:04:46	00:00:38	00:00:21	50.052	-90.002	0.884
32	2021-08-30 15:04:47	00:00:39	00:00:22	50.044	-89.986	0.909
33	2021-08-30 15:04:48	00:00:40	00:00:23	50.034	-90.012	0.9341
34	2021-08-30 15:04:49	00:00:41	00:00:24	50.025	-89.976	0.9591
35	2021-08-30 15:04:50	00:00:42	00:00:25	50.017	-89.975	0.9841
36	2021-08-30 15:04:51	00:00:43	00:00:26	50.009	-89.934	1.0091
37	2021-08-30 15:04:52	00:00:44	00:00:27	50	-89.939	1.0342
38	2021-08-30 15:04:53	00:00:45	00:00:28	49.987	-89.918	1.0592
39	2021-08-30 15:04:54	00:00:46	00:00:29	49.98	-89.993	1.0842
40	2021-08-30 15:04:55	00:00:47	00:00:30	49.971	-89.925	1.0967
41	2021-08-30 15:04:56	00:00:48	00:00:31	49.963	-89.969	1.1342
42	2021-08-30 15:04:57	00:00:49	00:00:32	49.954	-90.03	1.1592
43	2021-08-30 15:04:58	00:00:51	00:00:34	49.947	-90.024	1.1843
44	2021-08-30 15:04:59	00:00:51	00:00:34	49.943	-90.027	1.2093
45	2021-08-30 15:05:00	00:00:53	00:00:36	49.936	-90.036	1.2343
46	2021-08-30 15:05:01	00:00:53	00:00:36	49.927	-90.094	1.2593
47	2021-08-30 15:05:02	00:00:55	00:00:38	49.92	-90.097	1.2843
48	2021-08-30 15:05:03	00:00:55	00:00:38	49.914	-90.072	1.3093
49	2021-08-30 15:05:04	00:00:57	00:00:40	49.906	-90.009	1.3343
50	2021-08-30 15:05:05	00:00:57	00:00:40	49.901	-90.049	1.3593
51	2021-08-30 15:05:06	00:00:59	00:00:42	49.895	-89.986	1.3843
52	2021-08-30 15:05:07	00:00:59	00:00:42	49.889	-89.976	1.4094
53	2021-08-30 15:05:08	00:01:01	00:00:44	49.881	-89.925	1.4344
54	2021-08-30 15:05:09	00:01:01	00:00:44	49.874	-89.958	1.4594
55	2021-08-30 15:05:10	00:01:03	00:00:46	49.869	-89.936	1.4719
56	2021-08-30 15:05:11	00:01:03	00:00:46	49.863	-89.985	1.5094
57	2021-08-30 15:05:12	00:01:05	00:00:48	49.856	-90.082	1.5345
58	2021-08-30 15:05:13	00:01:05	00:00:48	49.851	-90.079	1.5594
59	2021-08-30 15:05:14	00:01:07	00:00:50	49.848	-90.006	1.5845
60	2021-08-30 15:05:15	00:01:07	00:00:50	49.844	-90.001	1.6095
61	2021-08-30 15:05:16	00:01:09	00:00:52	49.838	-90.008	1.6345
62	2021-08-30 15:05:17	00:01:09	00:00:52	49.833	-90.078	1.6595
63	2021-08-30 15:05:18	00:01:11	00:00:54	49.828	-90.081	1.6845
64	2021-08-30 15:05:19	00:01:11	00:00:54	49.824	-90.078	1.7096
65	2021-08-30 15:05:20	00:01:13	00:00:56	49.819	-90.078	1.7346
66	2021-08-30 15:05:21	00:01:13	00:00:56	49.815	-90.045	1.7596
67	2021-08-30 15:05:22	00:01:15	00:00:58	49.813	-90.003	1.7846
68	2021-08-30 15:05:23	00:01:15	00:00:58	49.806	-90.027	1.8096
69	2021-08-30 15:05:24	00:01:17	00:01:00	49.802	-90	1.8347
70	2021-08-30 15:05:25	00:01:17	00:01:00	49.798	-90.034	1.8472
71	2021-08-30 15:05:26	00:01:19	00:01:02	49.793	-90.062	1.8847
72	2021-08-30 15:05:27	00:01:19	00:01:02	49.788	-90.031	1.9097
73	2021-08-30 15:05:28	00:01:21	00:01:04	49.783	-90.061	1.9347
74	2021-08-30 15:05:29	00:01:21	00:01:04	49.78	-90.008	1.9597
75	2021-08-30 15:05:30	00:01:23	00:01:06	49.776	-90.004	1.9847
76	2021-08-30 15:05:31	00:01:23	00:01:06	49.774	-90.047	2.0097
77	2021-08-30 15:05:32	00:01:25	00:01:08	49.77	-90.063	2.0348
78	2021-08-30 15:05:33	00:01:25	00:01:08	49.766	-90.019	2.0597
79	2021-08-30 15:05:34	00:01:27	00:01:10	49.763	-89.965	2.0847
80	2021-08-30 15:05:35	00:01:27	00:01:10	49.76	-89.961	2.1098
81	2021-08-30 15:05:36	00:01:29	00:01:12	49.758	-89.912	2.1348
82	2021-08-30 15:05:37	00:01:29	00:01:12	49.754	-89.965	2.1597
83	2021-08-30 15:05:38	00:01:31	00:01:14	49.751	-89.927	2.1847
84	2021-08-30 15:05:39	00:01:32	00:01:15	49.747	-89.948	2.2097
85	2021-08-30 15:05:40	00:01:33	00:01:16	49.744	-90.02	2.2222
86	2021-08-30 15:05:41	00:01:34	00:01:17	49.739	-90.069	2.2598
87	2021-08-30 15:05:42	00:01:35	00:01:18	49.736	-90.025	2.2847
88	2021-08-30 15:05:43	00:01:36	00:01:19	49.733	-90.038	2.3097
89	2021-08-30 15:05:44	00:01:37	00:01:20	49.731	-90.086	2.3348

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



90	2021-08-30 15:05:45	00:01:38	00:01:21	49.728	-90.071	2.3598
91	2021-08-30 15:05:46	00:01:39	00:01:22	49.725	-90.04	2.3848
92	2021-08-30 15:05:47	00:01:40	00:01:23	49.722	-90.013	2.4098
93	2021-08-30 15:05:48	00:01:41	00:01:24	49.72	-89.965	2.4348
94	2021-08-30 15:05:49	00:01:42	00:01:25	49.716	-89.996	2.4598
95	2021-08-30 15:05:50	00:01:43	00:01:26	49.713	-89.968	2.4849
96	2021-08-30 15:05:51	00:01:44	00:01:27	49.711	-89.953	2.5099
97	2021-08-30 15:05:52	00:01:45	00:01:28	49.709	-89.925	2.5348
98	2021-08-30 15:05:53	00:01:46	00:01:29	49.704	-89.976	2.5599
99	2021-08-30 15:05:54	00:01:47	00:01:30	49.701	-89.943	2.5849
100	2021-08-30 15:05:55	00:01:48	00:01:31	49.697	-89.989	2.5974
101	2021-08-30 15:05:56	00:01:49	00:01:32	49.693	-90.043	2.6349
102	2021-08-30 15:05:57	00:01:50	00:01:33	49.69	-90.061	2.6599
103	2021-08-30 15:05:58	00:01:51	00:01:34	49.686	-90.001	2.6849
104	2021-08-30 15:05:59	00:01:52	00:01:35	49.684	-90.038	2.71
105	2021-08-30 15:06:00	00:01:53	00:01:36	49.682	-90.012	2.735
106	2021-08-30 15:06:01	00:01:54	00:01:37	49.681	-90.067	2.76
107	2021-08-30 15:06:02	00:01:55	00:01:38	49.679	-90.072	2.785
108	2021-08-30 15:06:03	00:01:56	00:01:39	49.677	-90.019	2.81
109	2021-08-30 15:06:04	00:01:57	00:01:40	49.674	-90.043	2.835
110	2021-08-30 15:06:05	00:01:58	00:01:41	49.673	-89.986	2.86
111	2021-08-30 15:06:06	00:01:59	00:01:42	49.672	-89.951	2.885
112	2021-08-30 15:06:07	00:02:00	00:01:43	49.669	-89.963	2.91
113	2021-08-30 15:06:08	00:02:01	00:01:44	49.665	-89.953	2.935
114	2021-08-30 15:06:09	00:02:02	00:01:45	49.663	-89.914	2.96
115	2021-08-30 15:06:10	00:02:03	00:01:46	49.66	-89.968	2.9725
116	2021-08-30 15:06:11	00:02:04	00:01:47	49.656	-90.03	3.01
117	2021-08-30 15:06:12	00:02:05	00:01:48	49.654	-89.994	3.035
118	2021-08-30 15:06:13	00:02:06	00:01:49	49.652	-90.026	3.06
119	2021-08-30 15:06:14	00:02:07	00:01:50	49.651	-90.045	3.085
120	2021-08-30 15:06:15	00:02:08	00:01:51	49.649	-90.053	3.11
121	2021-08-30 15:06:16	00:02:09	00:01:52	49.648	-89.99	3.135
122	2021-08-30 15:06:17	00:02:10	00:01:53	49.646	-89.952	3.16
123	2021-08-30 15:06:18	00:02:11	00:01:54	49.644	-89.975	3.185
124	2021-08-30 15:06:19	00:02:12	00:01:55	49.642	-89.946	3.21
125	2021-08-30 15:06:21	00:02:13	00:01:56	49.638	-90.03	3.235
126	2021-08-30 15:06:22	00:02:14	00:01:57	49.636	-90.03	3.26
127	2021-08-30 15:06:23	00:02:15	00:01:58	49.633	-90.096	3.285
128	2021-08-30 15:06:24	00:02:16	00:01:59	49.629	-90.042	3.31
129	2021-08-30 15:06:25	00:02:17	00:02:00	49.627	-90.047	3.3475
130	2021-08-30 15:06:26	00:02:18	00:02:01	49.625	-90.067	3.3726
131	2021-08-30 15:06:27	00:02:19	00:02:02	49.625	-90.053	3.3976
132	2021-08-30 15:06:28	00:02:20	00:02:03	49.622	-90.059	3.4226
133	2021-08-30 15:06:29	00:02:21	00:02:04	49.619	-90.005	3.4476
134	2021-08-30 15:06:30	00:02:22	00:02:05	49.619	-90.035	3.4726
135	2021-08-30 15:06:31	00:02:23	00:02:06	49.615	-90.079	3.4977
136	2021-08-30 15:06:32	00:02:24	00:02:07	49.613	-90.081	3.5227
137	2021-08-30 15:06:33	00:02:25	00:02:08	49.609	-90.061	3.5352
138	2021-08-30 15:06:34	00:02:26	00:02:09	49.605	-90.014	3.5728
139	2021-08-30 15:06:35	00:02:27	00:02:10	49.605	-90.046	3.5977
140	2021-08-30 15:06:36	00:02:28	00:02:11	49.603	-90.027	3.6228
141	2021-08-30 15:06:37	00:02:29	00:02:12	49.603	-90.083	3.6478
142	2021-08-30 15:06:38	00:02:30	00:02:13	49.602	-90.056	3.6728
143	2021-08-30 15:06:39	00:02:31	00:02:14	49.6	-90.093	3.6979
144	2021-08-30 15:06:40	00:02:32	00:02:15	49.599	-90.019	3.7229
145	2021-08-30 15:06:41	00:02:33	00:02:16	49.599	-89.983	3.7479
146	2021-08-30 15:06:42	00:02:34	00:02:17	49.597	-89.994	3.7728
147	2021-08-30 15:06:43	00:02:35	00:02:18	49.595	-90.039	3.7978
148	2021-08-30 15:06:44	00:02:36	00:02:19	49.594	-90.033	3.8229
149	2021-08-30 15:06:45	00:02:37	00:02:20	49.591	-90.011	3.8479
150	2021-08-30 15:06:46	00:02:38	00:02:21	49.588	-90.028	3.8729

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



151	2021-08-30 15:06:47	00:02:39	00:02:22	49.587	-90.028	3.8979
152	2021-08-30 15:06:48	00:02:40	00:02:23	49.586	-90.024	3.9104
153	2021-08-30 15:06:49	00:02:41	00:02:24	49.584	-90.039	3.948
154	2021-08-30 15:06:50	00:02:42	00:02:25	49.582	-90.046	3.973
155	2021-08-30 15:06:51	00:02:43	00:02:26	49.582	-90.059	3.998
156	2021-08-30 15:06:52	00:02:44	00:02:27	49.581	-90.082	4.023
157	2021-08-30 15:06:53	00:02:45	00:02:28	49.58	-90.032	4.048
158	2021-08-30 15:06:54	00:02:46	00:02:29	49.579	-89.993	4.073
159	2021-08-30 15:06:55	00:02:47	00:02:30	49.577	-90.025	4.0981
160	2021-08-30 15:06:56	00:02:48	00:02:31	49.577	-89.98	4.1231
161	2021-08-30 15:06:57	00:02:49	00:02:32	49.576	-89.927	4.148
162	2021-08-30 15:06:58	00:02:50	00:02:33	49.574	-89.972	4.1731
163	2021-08-30 15:06:59	00:02:51	00:02:34	49.573	-89.924	4.1981
164	2021-08-30 15:07:00	00:02:52	00:02:35	49.57	-89.943	4.2231
165	2021-08-30 15:07:01	00:02:53	00:02:36	49.568	-89.948	4.2481
166	2021-08-30 15:07:02	00:02:54	00:02:37	49.564	-90.036	4.2731
167	2021-08-30 15:07:03	00:02:55	00:02:38	49.561	-90.05	4.2857
168	2021-08-30 15:07:04	00:02:56	00:02:39	49.56	-90.034	4.3232
169	2021-08-30 15:07:05	00:02:57	00:02:40	49.558	-90.028	4.3482
170	2021-08-30 15:07:06	00:02:58	00:02:41	49.557	-89.991	4.3732
171	2021-08-30 15:07:07	00:02:59	00:02:42	49.556	-89.988	4.3982
172	2021-08-30 15:07:08	00:03:00	00:02:43	49.554	-90.05	4.4232
173	2021-08-30 15:07:09	00:03:01	00:02:44	49.553	-90.053	4.4482
174	2021-08-30 15:07:10	00:03:02	00:02:45	49.552	-90.047	4.4732
175	2021-08-30 15:07:11	00:03:03	00:02:46	49.548	-90.03	4.4982
176	2021-08-30 15:07:12	00:03:04	00:02:47	49.548	-90.025	4.5232
177	2021-08-30 15:07:13	00:03:05	00:02:48	49.547	-90.002	4.5482
178	2021-08-30 15:07:14	00:03:06	00:02:49	49.545	-90.087	4.5732
179	2021-08-30 15:07:15	00:03:07	00:02:50	49.543	-90.01	4.5982
180	2021-08-30 15:07:16	00:03:08	00:02:51	49.542	-90.055	4.6232
181	2021-08-30 15:07:17	00:03:09	00:02:52	49.54	-90.013	4.6483
182	2021-08-30 15:07:18	00:03:10	00:02:53	49.54	-89.978	4.6608
183	2021-08-30 15:07:19	00:03:11	00:02:54	49.538	-90.014	4.6983
184	2021-08-30 15:07:20	00:03:12	00:02:55	49.538	-89.943	4.7233
185	2021-08-30 15:07:21	00:03:13	00:02:56	49.537	-89.962	4.7483
186	2021-08-30 15:07:22	00:03:14	00:02:57	49.536	-89.98	4.7734
187	2021-08-30 15:07:23	00:03:15	00:02:58	49.535	-89.965	4.7983
188	2021-08-30 15:07:24	00:03:16	00:02:59	49.533	-89.96	4.8234
189	2021-08-30 15:07:25	00:03:17	00:03:00	49.531	-89.995	4.8484
190	2021-08-30 15:07:26	00:03:18	00:03:01	49.53	-89.966	4.8734
191	2021-08-30 15:07:27	00:03:19	00:03:02	49.526	-90.094	4.8985
192	2021-08-30 15:07:28	00:03:20	00:03:03	49.526	-90.027	4.9235
193	2021-08-30 15:07:29	00:03:21	00:03:04	49.525	-90.096	4.9485
194	2021-08-30 15:07:30	00:03:22	00:03:05	49.521	-90.063	4.9735
195	2021-08-30 15:07:31	00:03:23	00:03:06	49.52	-90.009	4.9985
196	2021-08-30 15:07:32	00:03:24	00:03:07	49.52	-90.041	5.0235
197	2021-08-30 15:07:33	00:03:25	00:03:08	49.518	-90.046	5.036
198	2021-08-30 15:07:34	00:03:26	00:03:09	49.516	-90.062	5.086
199	2021-08-30 15:07:35	00:03:27	00:03:10	49.516	-90.008	5.111
200	2021-08-30 15:07:36	00:03:28	00:03:11	49.514	-90.02	5.1361
201	2021-08-30 15:07:37	00:03:29	00:03:12	49.513	-90.013	5.1611
202	2021-08-30 15:07:38	00:03:30	00:03:13	49.51	-90.051	5.1861
203	2021-08-30 15:07:39	00:03:31	00:03:14	49.51	-89.999	5.2111
204	2021-08-30 15:07:40	00:03:32	00:03:15	49.508	-90.038	5.2236
205	2021-08-30 15:07:41	00:03:33	00:03:16	49.506	-90.07	5.2612
206	2021-08-30 15:07:42	00:03:34	00:03:17	49.505	-90.042	5.2862
207	2021-08-30 15:07:43	00:03:35	00:03:18	49.502	-90.026	5.3112
208	2021-08-30 15:07:44	00:03:36	00:03:19	49.502	-90.005	5.3362
209	2021-08-30 15:07:45	00:03:37	00:03:20	49.502	-90.041	5.3612
210	2021-08-30 15:07:46	00:03:39	00:03:22	49.502	-90.027	5.3862
211	2021-08-30 15:07:47	00:03:39	00:03:22	49.501	-90.024	5.4112

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



212	2021-08-30 15:07:48	00:03:41	00:03:24	49.499	-90.027	5.4362
213	2021-08-30 15:07:49	00:03:41	00:03:24	49.499	-89.992	5.4612
214	2021-08-30 15:07:50	00:03:43	00:03:26	49.498	-90.036	5.4862
215	2021-08-30 15:07:51	00:03:43	00:03:26	49.496	-90.079	5.5112
216	2021-08-30 15:07:52	00:03:45	00:03:28	49.494	-90.082	5.5362
217	2021-08-30 15:07:53	00:03:45	00:03:28	49.491	-90.031	5.5613
218	2021-08-30 15:07:54	00:03:47	00:03:30	49.49	-90.093	5.5863
219	2021-08-30 15:07:55	00:03:47	00:03:30	49.487	-90.023	5.5988
220	2021-08-30 15:07:56	00:03:49	00:03:32	49.487	-90.042	5.6363
221	2021-08-30 15:07:57	00:03:49	00:03:32	49.486	-90.062	5.6613
222	2021-08-30 15:07:58	00:03:51	00:03:34	49.485	-90.078	5.6864
223	2021-08-30 15:07:59	00:03:51	00:03:34	49.484	-90.08	5.7114
224	2021-08-30 15:08:00	00:03:53	00:03:36	49.482	-90.027	5.7364
225	2021-08-30 15:08:01	00:03:53	00:03:36	49.481	-90.001	5.7614
226	2021-08-30 15:08:02	00:03:55	00:03:38	49.48	-90.046	5.7865
227	2021-08-30 15:08:03	00:03:55	00:03:38	49.476	-90.009	5.8115
228	2021-08-30 15:08:04	00:03:57	00:03:40	49.475	-90.007	5.8365
229	2021-08-30 15:08:05	00:03:57	00:03:40	49.473	-90.007	5.8615
230	2021-08-30 15:08:06	00:03:59	00:03:42	49.473	-90.04	5.8865
231	2021-08-30 15:08:07	00:03:59	00:03:42	49.473	-90.079	5.9115
232	2021-08-30 15:08:08	00:04:01	00:03:44	49.471	-90.019	5.9366
233	2021-08-30 15:08:09	00:04:01	00:03:44	49.471	-90.051	5.9616
234	2021-08-30 15:08:10	00:04:03	00:03:46	49.469	-90.089	5.9741
235	2021-08-30 15:08:11	00:04:03	00:03:46	49.468	-90.079	6.0117
236	2021-08-30 15:08:12	00:04:05	00:03:48	49.466	-90.002	6.0367
237	2021-08-30 15:08:13	00:04:05	00:03:48	49.464	-90.05	6.0617
238	2021-08-30 15:08:14	00:04:07	00:03:50	49.464	-90.005	6.0867
239	2021-08-30 15:08:15	00:04:07	00:03:50	49.462	-90.039	6.1118
240	2021-08-30 15:08:16	00:04:09	00:03:52	49.459	-90.069	6.1368
241	2021-08-30 15:08:17	00:04:09	00:03:52	49.458	-90.066	6.1618
242	2021-08-30 15:08:18	00:04:11	00:03:54	49.456	-90.079	6.1868
243	2021-08-30 15:08:19	00:04:12	00:03:55	49.455	-90.092	6.2119
244	2021-08-30 15:08:20	00:04:13	00:03:56	49.455	-90.078	6.2369
245	2021-08-30 15:08:21	00:04:14	00:03:57	49.453	-90.087	6.2619
246	2021-08-30 15:08:22	00:04:15	00:03:58	49.453	-90.036	6.2869
247	2021-08-30 15:08:23	00:04:16	00:03:59	49.453	-90.092	6.3119
248	2021-08-30 15:08:24	00:04:17	00:04:00	49.452	-90.001	6.337
249	2021-08-30 15:08:25	00:04:18	00:04:01	49.452	-90.013	6.3495
250	2021-08-30 15:08:26	00:04:19	00:04:02	49.45	-90.053	6.387
251	2021-08-30 15:08:27	00:04:20	00:04:03	49.448	-90.053	6.412
252	2021-08-30 15:08:28	00:04:21	00:04:04	49.447	-90.008	6.4371
253	2021-08-30 15:08:29	00:04:22	00:04:05	49.447	-90.013	6.4621
254	2021-08-30 15:08:30	00:04:23	00:04:06	49.446	-89.959	6.4871
255	2021-08-30 15:08:31	00:04:24	00:04:07	49.443	-90.044	6.5121
256	2021-08-30 15:08:32	00:04:25	00:04:08	49.442	-90.045	6.5371
257	2021-08-30 15:08:33	00:04:26	00:04:09	49.439	-90.021	6.5621
258	2021-08-30 15:08:34	00:04:27	00:04:10	49.439	-90.026	6.5872
259	2021-08-30 15:08:35	00:04:28	00:04:11	49.438	-90.076	6.6121
260	2021-08-30 15:08:36	00:04:29	00:04:12	49.436	-90.085	6.6371
261	2021-08-30 15:08:37	00:04:30	00:04:13	49.433	-90.054	6.6622
262	2021-08-30 15:08:38	00:04:31	00:04:14	49.43	-90.041	6.6872
263	2021-08-30 15:08:39	00:04:32	00:04:15	49.428	-90.078	6.7122
264	2021-08-30 15:08:40	00:04:33	00:04:16	49.427	-90.082	6.7247
265	2021-08-30 15:08:41	00:04:34	00:04:17	49.427	-90.057	6.7622
266	2021-08-30 15:08:42	00:04:35	00:04:18	49.426	-90.004	6.7872
267	2021-08-30 15:08:43	00:04:36	00:04:19	49.426	-90.063	6.8123
268	2021-08-30 15:08:44	00:04:37	00:04:20	49.426	-90.07	6.8373
269	2021-08-30 15:08:45	00:04:38	00:04:21	49.426	-90.038	6.8623
270	2021-08-30 15:08:46	00:04:39	00:04:22	49.424	-90.087	6.8873
271	2021-08-30 15:08:47	00:04:40	00:04:23	49.424	-90.002	6.9123
272	2021-08-30 15:08:48	00:04:41	00:04:24	49.422	-90.019	6.9374

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



273	2021-08-30 15:08:49	00:04:42	00:04:25	49.419	-90.048	6.9624
274	2021-08-30 15:08:50	00:04:43	00:04:26	49.419	-89.991	6.9874
275	2021-08-30 15:08:51	00:04:44	00:04:27	49.418	-89.946	7.0124
276	2021-08-30 15:08:52	00:04:45	00:04:28	49.416	-89.923	7.0374
277	2021-08-30 15:08:53	00:04:46	00:04:29	49.414	-89.958	7.0624
278	2021-08-30 15:08:54	00:04:47	00:04:30	49.414	-89.91	7.0874
279	2021-08-30 15:08:55	00:04:48	00:04:31	49.412	-89.959	7.0999
280	2021-08-30 15:08:56	00:04:49	00:04:32	49.41	-89.974	7.1375
281	2021-08-30 15:08:57	00:04:50	00:04:33	49.408	-90.076	7.1625
282	2021-08-30 15:08:58	00:04:51	00:04:34	49.408	-90.05	7.1875
283	2021-08-30 15:08:59	00:04:52	00:04:35	49.408	-90.011	7.2125
284	2021-08-30 15:09:01	00:04:53	00:04:36	49.406	-90.049	7.2375
285	2021-08-30 15:09:02	00:04:54	00:04:37	49.404	-90.029	7.2625
286	2021-08-30 15:09:03	00:04:55	00:04:38	49.402	-90.026	7.2875
287	2021-08-30 15:09:04	00:04:56	00:04:39	49.401	-90.001	7.3125
288	2021-08-30 15:09:05	00:04:57	00:04:40	49.401	-90.078	7.3375
289	2021-08-30 15:09:06	00:04:58	00:04:41	49.4	-90.009	7.3624
290	2021-08-30 15:09:07	00:04:59	00:04:42	49.399	-90.055	7.3874
291	2021-08-30 15:09:08	00:05:00	00:04:43	49.397	-90.074	7.4125
292	2021-08-30 15:09:09	00:05:01	00:04:44	49.396	-90.018	7.4374
293	2021-08-30 15:09:10	00:05:02	00:04:45	49.394	-90.045	7.4624
294	2021-08-30 15:09:11	00:05:03	00:04:46	49.393	-90.002	7.475
295	2021-08-30 15:09:12	00:05:04	00:04:47	49.391	-89.998	7.5125
296	2021-08-30 15:09:13	00:05:05	00:04:48	49.388	-90.051	7.55
297	2021-08-30 15:09:14	00:05:06	00:04:49	49.388	-89.987	7.575
298	2021-08-30 15:09:15	00:05:07	00:04:50	49.388	-89.945	7.6
299	2021-08-30 15:09:16	00:05:08	00:04:51	49.385	-90.014	7.625
300	2021-08-30 15:09:17	00:05:09	00:04:52	49.383	-90.039	7.65
301	2021-08-30 15:09:18	00:05:10	00:04:53	49.381	-90.015	7.6625
302	2021-08-30 15:09:19	00:05:11	00:04:54	49.379	-90.097	7.7001
303	2021-08-30 15:09:20	00:05:12	00:04:55	49.379	-90.089	7.7251
304	2021-08-30 15:09:21	00:05:13	00:04:56	49.377	-90.033	7.7501
305	2021-08-30 15:09:22	00:05:14	00:04:57	49.377	-90.088	7.7751
306	2021-08-30 15:09:23	00:05:15	00:04:58	49.377	-90.006	7.8001
307	2021-08-30 15:09:24	00:05:16	00:04:59	49.374	-90.049	7.8252
308	2021-08-30 15:09:25	00:05:17	00:05:00	49.373	-90.08	7.8502
309	2021-08-30 15:09:26	00:05:18	00:05:01	49.372	-90.009	7.8752
310	2021-08-30 15:09:27	00:05:19	00:05:02	49.372	-90.084	7.9002
311	2021-08-30 15:09:28	00:05:20	00:05:03	49.37	-90.087	7.9252
312	2021-08-30 15:09:29	00:05:21	00:05:04	49.367	-90.018	7.9503
313	2021-08-30 15:09:30	00:05:22	00:05:05	49.366	-90.097	7.9753
314	2021-08-30 15:09:31	00:05:23	00:05:06	49.362	-90.073	8.0003
315	2021-08-30 15:09:32	00:05:24	00:05:07	49.361	-90.047	8.0254
316	2021-08-30 15:09:33	00:05:25	00:05:08	49.361	-90.01	8.0379
317	2021-08-30 15:09:34	00:05:26	00:05:09	49.359	-90.087	8.0754
318	2021-08-30 15:09:35	00:05:27	00:05:10	49.359	-90.093	8.1004
319	2021-08-30 15:09:36	00:05:28	00:05:11	49.359	-90.045	8.1254
320	2021-08-30 15:09:37	00:05:29	00:05:12	49.359	-90.021	8.1504
321	2021-08-30 15:09:38	00:05:30	00:05:13	49.358	-90.015	8.1754
322	2021-08-30 15:09:39	00:05:31	00:05:14	49.357	-89.993	8.2004
323	2021-08-30 15:09:40	00:05:32	00:05:15	49.354	-90.054	8.2254
324	2021-08-30 15:09:41	00:05:33	00:05:16	49.353	-90.073	8.2504
325	2021-08-30 15:09:42	00:05:34	00:05:17	49.352	-90.051	8.2754
326	2021-08-30 15:09:43	00:05:35	00:05:18	49.351	-90.002	8.3004
327	2021-08-30 15:09:44	00:05:36	00:05:19	49.349	-89.993	8.3254
328	2021-08-30 15:09:45	00:05:37	00:05:20	49.347	-90.02	8.3505
329	2021-08-30 15:09:46	00:05:38	00:05:21	49.345	-89.979	8.3755
330	2021-08-30 15:09:47	00:05:39	00:05:22	49.343	-90.008	8.4005
331	2021-08-30 15:09:48	00:05:40	00:05:23	49.342	-89.993	8.413
332	2021-08-30 15:09:49	00:05:41	00:05:24	49.342	-90.023	8.4505
333	2021-08-30 15:09:50	00:05:42	00:05:25	49.342	-89.995	8.4755

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



334	2021-08-30 15:09:51	00:05:43	00:05:26	49.339	-90.029	8.5005
335	2021-08-30 15:09:52	00:05:44	00:05:27	49.338	-90.033	8.5255
336	2021-08-30 15:09:53	00:05:45	00:05:28	49.336	-90.056	8.5506
337	2021-08-30 15:09:54	00:05:46	00:05:29	49.335	-90.058	8.5756
338	2021-08-30 15:09:55	00:05:47	00:05:30	49.334	-90.09	8.6005
339	2021-08-30 15:09:56	00:05:48	00:05:31	49.334	-90.031	8.6255
340	2021-08-30 15:09:57	00:05:49	00:05:32	49.334	-89.977	8.6505
341	2021-08-30 15:09:58	00:05:50	00:05:33	49.331	-90.033	8.6756
342	2021-08-30 15:09:59	00:05:51	00:05:34	49.33	-89.973	8.7006
343	2021-08-30 15:10:00	00:05:52	00:05:35	49.329	-89.947	8.7255
344	2021-08-30 15:10:01	00:05:53	00:05:36	49.326	-90.038	8.7506
345	2021-08-30 15:10:02	00:05:54	00:05:37	49.324	-90.046	8.7756
346	2021-08-30 15:10:03	00:05:55	00:05:38	49.32	-90.039	8.7881
347	2021-08-30 15:10:04	00:05:56	00:05:39	49.319	-90.044	8.8256
348	2021-08-30 15:10:05	00:05:57	00:05:40	49.319	-90.017	8.8506
349	2021-08-30 15:10:06	00:05:58	00:05:41	49.317	-90.052	8.8756
350	2021-08-30 15:10:07	00:05:59	00:05:42	49.316	-90.056	8.9007
351	2021-08-30 15:10:08	00:06:00	00:05:43	49.316	-90.065	8.9256
352	2021-08-30 15:10:09	00:06:01	00:05:44	49.315	-90.079	8.9507
353	2021-08-30 15:10:10	00:06:02	00:05:45	49.315	-90.078	8.9757
354	2021-08-30 15:10:11	00:06:03	00:05:46	49.315	-90.004	9.0007
355	2021-08-30 15:10:12	00:06:04	00:05:47	49.314	-89.986	9.0257
356	2021-08-30 15:10:13	00:06:05	00:05:48	49.312	-90.038	9.0507
357	2021-08-30 15:10:14	00:06:06	00:05:49	49.309	-90.045	9.0757
358	2021-08-30 15:10:15	00:06:07	00:05:50	49.308	-90	9.1007
359	2021-08-30 15:10:16	00:06:08	00:05:51	49.305	-90.074	9.1257
360	2021-08-30 15:10:17	00:06:09	00:05:52	49.303	-90.097	9.1507
361	2021-08-30 15:10:18	00:06:10	00:05:53	49.3	-90.051	9.1632
362	2021-08-30 15:10:19	00:06:11	00:05:54	49.299	-90.047	9.2008
363	2021-08-30 15:10:20	00:06:12	00:05:55	49.297	-90.094	9.2258
364	2021-08-30 15:10:21	00:06:13	00:05:56	49.296	-90.088	9.2633
365	2021-08-30 15:10:22	00:06:14	00:05:57	49.296	-90.093	9.2883
366	2021-08-30 15:10:23	00:06:15	00:05:58	49.292	-90.013	9.3134
367	2021-08-30 15:10:24	00:06:16	00:05:59	49.292	-90.069	9.3384
368	2021-08-30 15:10:25	00:06:17	00:06:00	49.291	-90.054	9.3509
369	2021-08-30 15:10:26	00:06:18	00:06:01	49.29	-90.042	9.3884
370	2021-08-30 15:10:27	00:06:19	00:06:02	49.289	-89.977	9.4134
371	2021-08-30 15:10:28	00:06:20	00:06:03	49.289	-89.965	9.4384
372	2021-08-30 15:10:29	00:06:21	00:06:04	49.288	-90	9.4635
373	2021-08-30 15:10:30	00:06:22	00:06:05	49.287	-89.963	9.4884
374	2021-08-30 15:10:31	00:06:23	00:06:06	49.285	-89.952	9.5134
375	2021-08-30 15:10:32	00:06:24	00:06:07	49.282	-90.038	9.5385
376	2021-08-30 15:10:33	00:06:25	00:06:08	49.281	-90.024	9.5635
377	2021-08-30 15:10:34	00:06:26	00:06:09	49.279	-90.034	9.5885
378	2021-08-30 15:10:35	00:06:27	00:06:10	49.277	-90.017	9.6135
379	2021-08-30 15:10:36	00:06:28	00:06:11	49.274	-90.089	9.6385
380	2021-08-30 15:10:37	00:06:29	00:06:12	49.271	-90.059	9.6635
381	2021-08-30 15:10:38	00:06:31	00:06:14	49.27	-90.02	9.6885
382	2021-08-30 15:10:39	00:06:31	00:06:14	49.27	-90.003	9.7135
383	2021-08-30 15:10:40	00:06:33	00:06:16	49.27	-90.081	9.726
384	2021-08-30 15:10:41	00:06:33	00:06:16	49.27	-90.001	9.7635
385	2021-08-30 15:10:42	00:06:35	00:06:18	49.269	-89.978	9.7885
386	2021-08-30 15:10:43	00:06:35	00:06:18	49.266	-90.028	9.8135
387	2021-08-30 15:10:44	00:06:37	00:06:20	49.265	-90.028	9.8386
388	2021-08-30 15:10:45	00:06:37	00:06:20	49.265	-89.998	9.8636
389	2021-08-30 15:10:46	00:06:39	00:06:22	49.265	-89.941	9.8885
390	2021-08-30 15:10:47	00:06:39	00:06:22	49.264	-89.935	9.9135
391	2021-08-30 15:10:48	00:06:41	00:06:24	49.261	-89.939	9.9386
392	2021-08-30 15:10:49	00:06:41	00:06:24	49.26	-89.937	9.9636
393	2021-08-30 15:10:50	00:06:43	00:06:26	49.259	-89.936	9.9886
394	2021-08-30 15:10:51	00:06:43	00:06:26	49.258	-89.942	10.0135

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



395	2021-08-30 15:10:52	00:06:45	00:06:28	49.254	-90.078	10.0386
396	2021-08-30 15:10:53	00:06:45	00:06:28	49.252	-90.085	10.0636
397	2021-08-30 15:10:54	00:06:47	00:06:30	49.249	-90.022	10.0887
398	2021-08-30 15:10:55	00:06:47	00:06:30	49.248	-90.061	10.1012
399	2021-08-30 15:10:56	00:06:49	00:06:32	49.247	-90.034	10.1386
400	2021-08-30 15:10:57	00:06:49	00:06:32	49.246	-90.003	10.1637
401	2021-08-30 15:10:58	00:06:51	00:06:34	49.246	-89.946	10.1887
402	2021-08-30 15:10:59	00:06:51	00:06:34	49.244	-89.972	10.2137
403	2021-08-30 15:11:00	00:06:53	00:06:36	49.243	-89.967	10.2387
404	2021-08-30 15:11:01	00:06:53	00:06:36	49.243	-89.946	10.2637
405	2021-08-30 15:11:02	00:06:55	00:06:38	49.24	-90.016	10.2888
406	2021-08-30 15:11:03	00:06:55	00:06:38	49.239	-89.994	10.3137
407	2021-08-30 15:11:04	00:06:57	00:06:40	49.238	-89.997	10.3388
408	2021-08-30 15:11:05	00:06:57	00:06:40	49.236	-90.067	10.3638
409	2021-08-30 15:11:06	00:06:59	00:06:42	49.234	-90.057	10.3888
410	2021-08-30 15:11:07	00:06:59	00:06:42	49.232	-90.062	10.4138
411	2021-08-30 15:11:08	00:07:01	00:06:44	49.231	-90.066	10.4388
412	2021-08-30 15:11:09	00:07:01	00:06:44	49.229	-90.062	10.4639
413	2021-08-30 15:11:10	00:07:03	00:06:46	49.228	-89.994	10.4764
414	2021-08-30 15:11:11	00:07:04	00:06:47	49.226	-90.031	10.5139
415	2021-08-30 15:11:12	00:07:05	00:06:48	49.225	-89.998	10.5389
416	2021-08-30 15:11:13	00:07:06	00:06:49	49.223	-90.011	10.5639
417	2021-08-30 15:11:14	00:07:07	00:06:50	49.223	-89.984	10.589
418	2021-08-30 15:11:15	00:07:08	00:06:51	49.222	-89.984	10.6139
419	2021-08-30 15:11:16	00:07:09	00:06:52	49.22	-90.068	10.639
420	2021-08-30 15:11:17	00:07:10	00:06:53	49.219	-90.085	10.664
421	2021-08-30 15:11:18	00:07:11	00:06:54	49.216	-90.028	10.689
422	2021-08-30 15:11:19	00:07:12	00:06:55	49.213	-90.043	10.714
423	2021-08-30 15:11:20	00:07:13	00:06:56	49.211	-90.046	10.739
424	2021-08-30 15:11:21	00:07:14	00:06:57	49.211	-90.063	10.764
425	2021-08-30 15:11:22	00:07:15	00:06:58	49.209	-90.08	10.7891
426	2021-08-30 15:11:23	00:07:16	00:06:59	49.207	-90.059	10.8141
427	2021-08-30 15:11:24	00:07:17	00:07:00	49.205	-90.076	10.8391
428	2021-08-30 15:11:25	00:07:18	00:07:01	49.204	-90.052	10.8516
429	2021-08-30 15:11:26	00:07:19	00:07:02	49.202	-90.053	10.8891
430	2021-08-30 15:11:27	00:07:20	00:07:03	49.201	-90.064	10.9141
431	2021-08-30 15:11:28	00:07:21	00:07:04	49.201	-90.03	10.9391
432	2021-08-30 15:11:29	00:07:22	00:07:05	49.199	-90.084	10.9641
433	2021-08-30 15:11:30	00:07:23	00:07:06	49.196	-90.055	10.9891
434	2021-08-30 15:11:31	00:07:24	00:07:07	49.194	-90.021	11.0141
435	2021-08-30 15:11:32	00:07:25	00:07:08	49.193	-90.032	11.0392
436	2021-08-30 15:11:33	00:07:26	00:07:09	49.192	-90.088	11.0642
437	2021-08-30 15:11:34	00:07:27	00:07:10	49.191	-90.077	11.0892
438	2021-08-30 15:11:35	00:07:28	00:07:11	49.189	-90.059	11.1142
439	2021-08-30 15:11:36	00:07:29	00:07:12	49.189	-89.995	11.1392
440	2021-08-30 15:11:37	00:07:30	00:07:13	49.186	-90.038	11.1643
441	2021-08-30 15:11:38	00:07:31	00:07:14	49.184	-89.999	11.1893
442	2021-08-30 15:11:39	00:07:32	00:07:15	49.182	-90.007	11.2143
443	2021-08-30 15:11:40	00:07:33	00:07:16	49.181	-90.025	11.2268
444	2021-08-30 15:11:41	00:07:34	00:07:17	49.179	-90.057	11.2643
445	2021-08-30 15:11:42	00:07:35	00:07:18	49.178	-90.005	11.2893
446	2021-08-30 15:11:43	00:07:36	00:07:19	49.176	-90.062	11.3143
447	2021-08-30 15:11:44	00:07:37	00:07:20	49.175	-90.077	11.3393
448	2021-08-30 15:11:45	00:07:38	00:07:21	49.173	-90.057	11.3643
449	2021-08-30 15:11:46	00:07:39	00:07:22	49.172	-90.046	11.3894
450	2021-08-30 15:11:47	00:07:40	00:07:23	49.17	-90.048	11.4144
451	2021-08-30 15:11:48	00:07:41	00:07:24	49.17	-89.991	11.4394
452	2021-08-30 15:11:49	00:07:42	00:07:25	49.169	-89.977	11.4645
453	2021-08-30 15:11:50	00:07:43	00:07:26	49.168	-89.958	11.4895
454	2021-08-30 15:11:52	00:07:44	00:07:27	49.166	-89.982	11.5145
455	2021-08-30 15:11:53	00:07:45	00:07:28	49.163	-90.052	11.5395

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



456	2021-08-30 15:11:54	00:07:46	00:07:29	49.162	-90.009	11.5645
457	2021-08-30 15:11:55	00:07:47	00:07:30	49.16	-90.05	11.5895
458	2021-08-30 15:11:56	00:07:48	00:07:31	49.157	-90.085	11.602
459	2021-08-30 15:11:57	00:07:49	00:07:32	49.155	-90.051	11.6395
460	2021-08-30 15:11:58	00:07:50	00:07:33	49.154	-90.031	11.6645
461	2021-08-30 15:11:59	00:07:51	00:07:34	49.151	-90.005	11.6896
462	2021-08-30 15:12:00	00:07:52	00:07:35	49.15	-90.095	11.7146
463	2021-08-30 15:12:01	00:07:53	00:07:36	49.149	-90.068	11.7396
464	2021-08-30 15:12:02	00:07:54	00:07:37	49.147	-90.071	11.7646
465	2021-08-30 15:12:03	00:07:55	00:07:38	49.145	-90.056	11.7896
466	2021-08-30 15:12:04	00:07:56	00:07:39	49.145	-89.99	11.8272
467	2021-08-30 15:12:05	00:07:57	00:07:40	49.143	-89.938	11.8522
468	2021-08-30 15:12:06	00:07:58	00:07:41	49.141	-89.936	11.8772
469	2021-08-30 15:12:07	00:07:59	00:07:42	49.14	-89.975	11.9021
470	2021-08-30 15:12:08	00:08:00	00:07:43	49.138	-90.018	11.9271
471	2021-08-30 15:12:09	00:08:01	00:07:44	49.136	-90.071	11.9522
472	2021-08-30 15:12:10	00:08:02	00:07:45	49.134	-90.083	11.9772
473	2021-08-30 15:12:11	00:08:03	00:07:46	49.131	-90.02	12.0023
474	2021-08-30 15:12:12	00:08:04	00:07:47	49.13	-90.044	12.0273
475	2021-08-30 15:12:13	00:08:05	00:07:48	49.129	-90.031	12.0523
476	2021-08-30 15:12:14	00:08:06	00:07:49	49.126	-90.076	12.0773
477	2021-08-30 15:12:15	00:08:07	00:07:50	49.124	-90.052	12.1023
478	2021-08-30 15:12:16	00:08:08	00:07:51	49.122	-90.096	12.1273
479	2021-08-30 15:12:17	00:08:09	00:07:52	49.12	-90.039	12.1524
480	2021-08-30 15:12:18	00:08:10	00:07:53	49.12	-90.009	12.1648
481	2021-08-30 15:12:19	00:08:11	00:07:54	49.118	-90.006	12.2023
482	2021-08-30 15:12:20	00:08:12	00:07:55	49.115	-90.039	12.2274
483	2021-08-30 15:12:21	00:08:13	00:07:56	49.114	-90.072	12.2524
484	2021-08-30 15:12:22	00:08:14	00:07:57	49.114	-90.048	12.2773
485	2021-08-30 15:12:23	00:08:15	00:07:58	49.113	-90.04	12.3024
486	2021-08-30 15:12:24	00:08:16	00:07:59	49.111	-90.032	12.3274
487	2021-08-30 15:12:25	00:08:17	00:08:00	49.111	-89.968	12.3524
488	2021-08-30 15:12:26	00:08:18	00:08:01	49.109	-90.022	12.3774
489	2021-08-30 15:12:27	00:08:19	00:08:02	49.108	-89.976	12.4024
490	2021-08-30 15:12:28	00:08:20	00:08:03	49.105	-90.045	12.4274
491	2021-08-30 15:12:29	00:08:21	00:08:04	49.102	-90.059	12.4525
492	2021-08-30 15:12:30	00:08:22	00:08:05	49.102	-89.999	12.4774
493	2021-08-30 15:12:31	00:08:23	00:08:06	49.1	-90.028	12.5025
494	2021-08-30 15:12:32	00:08:24	00:08:07	49.098	-90.072	12.5275
495	2021-08-30 15:12:33	00:08:25	00:08:08	49.095	-90.02	12.5399
496	2021-08-30 15:12:34	00:08:26	00:08:09	49.095	-90.052	12.5775
497	2021-08-30 15:12:35	00:08:27	00:08:10	49.091	-90.046	12.6025
498	2021-08-30 15:12:36	00:08:28	00:08:11	49.089	-90.021	12.6275
499	2021-08-30 15:12:37	00:08:29	00:08:12	49.089	-90.01	12.6525
500	2021-08-30 15:12:38	00:08:30	00:08:13	49.087	-90.018	12.6776
501	2021-08-30 15:12:39	00:08:31	00:08:14	49.085	-90.018	12.7026
502	2021-08-30 15:12:40	00:08:32	00:08:15	49.084	-90.01	12.7276
503	2021-08-30 15:12:41	00:08:33	00:08:16	49.083	-90.058	12.7526
504	2021-08-30 15:12:42	00:08:34	00:08:17	49.082	-90.027	12.7776
505	2021-08-30 15:12:43	00:08:35	00:08:18	49.082	-89.963	12.8026
506	2021-08-30 15:12:44	00:08:36	00:08:19	49.08	-89.983	12.8277
507	2021-08-30 15:12:45	00:08:37	00:08:20	49.078	-89.928	12.8527
508	2021-08-30 15:12:46	00:08:38	00:08:21	49.074	-89.941	12.8777
509	2021-08-30 15:12:47	00:08:39	00:08:22	49.073	-89.95	12.9027
510	2021-08-30 15:12:48	00:08:40	00:08:23	49.07	-90.015	12.9152
511	2021-08-30 15:12:49	00:08:41	00:08:24	49.068	-90.013	12.9527
512	2021-08-30 15:12:50	00:08:42	00:08:25	49.065	-90.053	12.9777
513	2021-08-30 15:12:51	00:08:43	00:08:26	49.063	-90.054	13.0027
514	2021-08-30 15:12:52	00:08:44	00:08:27	49.062	-90.056	13.0277
515	2021-08-30 15:12:53	00:08:45	00:08:28	49.061	-90.051	13.0528
516	2021-08-30 15:12:54	00:08:46	00:08:29	49.06	-90.017	13.0778

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



517	2021-08-30 15:12:55	00:08:47	00:08:30	49.058	-90.041	13.1028
518	2021-08-30 15:12:56	00:08:48	00:08:31	49.058	-89.969	13.1278
519	2021-08-30 15:12:57	00:08:49	00:08:32	49.056	-89.975	13.1527
520	2021-08-30 15:12:58	00:08:50	00:08:33	49.054	-90.016	13.1777
521	2021-08-30 15:12:59	00:08:51	00:08:34	49.053	-89.956	13.2027
522	2021-08-30 15:13:00	00:08:52	00:08:35	49.05	-90.029	13.2277
523	2021-08-30 15:13:01	00:08:53	00:08:36	49.047	-90.072	13.2527
524	2021-08-30 15:13:02	00:08:54	00:08:37	49.045	-90.066	13.2777
525	2021-08-30 15:13:03	00:08:55	00:08:38	49.043	-90.083	13.2903
526	2021-08-30 15:13:04	00:08:56	00:08:39	49.041	-90.067	13.3278
527	2021-08-30 15:13:05	00:08:57	00:08:40	49.038	-90.079	13.3528
528	2021-08-30 15:13:06	00:08:58	00:08:41	49.037	-90.038	13.3778
529	2021-08-30 15:13:07	00:08:59	00:08:42	49.037	-90.031	13.4028
530	2021-08-30 15:13:08	00:09:00	00:08:43	49.034	-90.076	13.4279
531	2021-08-30 15:13:09	00:09:01	00:08:44	49.033	-90.059	13.4529
532	2021-08-30 15:13:10	00:09:02	00:08:45	49.03	-90.016	13.4779
533	2021-08-30 15:13:11	00:09:03	00:08:46	49.028	-90.024	13.5029
534	2021-08-30 15:13:12	00:09:04	00:08:47	49.026	-90.012	13.528
535	2021-08-30 15:13:13	00:09:05	00:08:48	49.025	-90.086	13.553
536	2021-08-30 15:13:14	00:09:06	00:08:49	49.023	-90.027	13.578
537	2021-08-30 15:13:15	00:09:07	00:08:50	49.021	-89.999	13.603
538	2021-08-30 15:13:16	00:09:08	00:08:51	49.018	-89.961	13.6405
539	2021-08-30 15:13:17	00:09:09	00:08:52	49.017	-89.973	13.6655
540	2021-08-30 15:13:18	00:09:10	00:08:53	49.016	-89.964	13.6905
541	2021-08-30 15:13:19	00:09:11	00:08:54	49.015	-89.918	13.7155
542	2021-08-30 15:13:20	00:09:12	00:08:55	49.011	-90.03	13.7406
543	2021-08-30 15:13:21	00:09:13	00:08:56	49.009	-90.037	13.7656
544	2021-08-30 15:13:22	00:09:14	00:08:57	49.007	-90.02	13.7906
545	2021-08-30 15:13:23	00:09:15	00:08:58	49.006	-89.994	13.8155
546	2021-08-30 15:13:24	00:09:16	00:08:59	49.003	-90.031	13.8406
547	2021-08-30 15:13:25	00:09:17	00:09:00	49.002	-89.971	13.8531
548	2021-08-30 15:13:26	00:09:18	00:09:01	49.001	-89.952	13.8906
549	2021-08-30 15:13:27	00:09:19	00:09:02	48.997	-90.02	13.9157
550	2021-08-30 15:13:28	00:09:20	00:09:03	48.996	-89.972	13.9407
551	2021-08-30 15:13:29	00:09:21	00:09:04	48.995	-89.951	13.9657
552	2021-08-30 15:13:30	00:09:22	00:09:05	48.993	-89.958	13.9906
553	2021-08-30 15:13:31	00:09:23	00:09:06	48.99	-90.018	14.0157
554	2021-08-30 15:13:32	00:09:25	00:09:08	48.988	-90.082	14.0407
555	2021-08-30 15:13:33	00:09:25	00:09:08	48.987	-90.067	14.0657
556	2021-08-30 15:13:34	00:09:27	00:09:10	48.985	-90.061	14.0907
557	2021-08-30 15:13:35	00:09:27	00:09:10	48.983	-90.089	14.1156
558	2021-08-30 15:13:36	00:09:29	00:09:12	48.983	-90.015	14.1406
559	2021-08-30 15:13:37	00:09:29	00:09:12	48.982	-89.968	14.1656
560	2021-08-30 15:13:38	00:09:31	00:09:14	48.977	-90.012	14.1907
561	2021-08-30 15:13:39	00:09:31	00:09:14	48.975	-89.988	14.2157
562	2021-08-30 15:13:40	00:09:33	00:09:16	48.973	-89.963	14.2282
563	2021-08-30 15:13:41	00:09:33	00:09:16	48.971	-90.021	14.2657
564	2021-08-30 15:13:42	00:09:35	00:09:18	48.968	-90.062	14.2906
565	2021-08-30 15:13:43	00:09:35	00:09:18	48.967	-90.064	14.3157
566	2021-08-30 15:13:44	00:09:37	00:09:20	48.966	-90.083	14.3407
567	2021-08-30 15:13:45	00:09:37	00:09:20	48.964	-90.099	14.3657
568	2021-08-30 15:13:46	00:09:39	00:09:22	48.962	-90.033	14.3907
569	2021-08-30 15:13:47	00:09:39	00:09:22	48.961	-90.079	14.4157
570	2021-08-30 15:13:48	00:09:41	00:09:24	48.958	-90.094	14.4408
571	2021-08-30 15:13:49	00:09:41	00:09:24	48.955	-90.072	14.4658
572	2021-08-30 15:13:50	00:09:43	00:09:26	48.954	-90.034	14.4908
573	2021-08-30 15:13:51	00:09:43	00:09:26	48.952	-89.977	14.5158
574	2021-08-30 15:13:52	00:09:45	00:09:28	48.951	-89.941	14.5407
575	2021-08-30 15:13:53	00:09:45	00:09:28	48.948	-89.948	14.5657
576	2021-08-30 15:13:54	00:09:47	00:09:30	48.948	-89.948	14.5907
577	2021-08-30 15:13:55	00:09:47	00:09:30	48.946	-89.957	14.6032

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



578	2021-08-30 15:13:56	00:09:49	00:09:32	48.942	-90.046	14.6407
579	2021-08-30 15:13:57	00:09:49	00:09:32	48.94	-90.061	14.6658
580	2021-08-30 15:13:58	00:09:51	00:09:34	48.938	-90.095	14.6907
581	2021-08-30 15:13:59	00:09:51	00:09:34	48.937	-90.092	14.7157
582	2021-08-30 15:14:00	00:09:53	00:09:36	48.935	-90.08	14.7407
583	2021-08-30 15:14:01	00:09:53	00:09:36	48.931	-90.042	14.7658
584	2021-08-30 15:14:02	00:09:55	00:09:38	48.93	-90.069	14.7908
585	2021-08-30 15:14:03	00:09:55	00:09:38	48.927	-90.002	14.8158
586	2021-08-30 15:14:04	00:09:57	00:09:40	48.924	-90.011	14.8409
587	2021-08-30 15:14:05	00:09:57	00:09:40	48.923	-90.033	14.8659
588	2021-08-30 15:14:06	00:09:59	00:09:42	48.92	-90.079	14.8909
589	2021-08-30 15:14:07	00:09:59	00:09:42	48.917	-90	14.9159
590	2021-08-30 15:14:08	00:10:01	00:09:44	48.914	-90.028	14.9409
591	2021-08-30 15:14:09	00:10:02	00:09:45	48.913	-90.092	14.966
592	2021-08-30 15:14:10	00:10:03	00:09:46	48.911	-90.011	14.9785
593	2021-08-30 15:14:11	00:10:04	00:09:47	48.909	-90.025	15.016
594	2021-08-30 15:14:12	00:10:05	00:09:48	48.906	-90.044	15.041
595	2021-08-30 15:14:13	00:10:06	00:09:49	48.904	-90.051	15.066
596	2021-08-30 15:14:14	00:10:07	00:09:50	48.902	-90.084	15.091
597	2021-08-30 15:14:15	00:10:08	00:09:51	48.9	-90.093	15.1161
598	2021-08-30 15:14:16	00:10:09	00:09:52	48.9	-90.02	15.141
599	2021-08-30 15:14:17	00:10:10	00:09:53	48.899	-90.028	15.166
600	2021-08-30 15:14:18	00:10:11	00:09:54	48.896	-90.046	15.1911
601	2021-08-30 15:14:19	00:10:12	00:09:55	48.894	-90.04	15.2161
602	2021-08-30 15:14:20	00:10:13	00:09:56	48.893	-90.002	15.2411
603	2021-08-30 15:14:21	00:10:14	00:09:57	48.892	-89.952	15.266
604	2021-08-30 15:14:22	00:10:15	00:09:58	48.888	-90.059	15.2911
605	2021-08-30 15:14:23	00:10:16	00:09:59	48.885	-90.038	15.3161
606	2021-08-30 15:14:24	00:10:17	00:10:00	48.882	-90.034	15.3411
607	2021-08-30 15:14:25	00:10:18	00:10:01	48.878	-90.016	15.3536
608	2021-08-30 15:14:26	00:10:19	00:10:02	48.876	-90.011	15.3911
609	2021-08-30 15:14:27	00:10:20	00:10:03	48.875	-90	15.4161
610	2021-08-30 15:14:28	00:10:21	00:10:04	48.872	-90.067	15.4412
611	2021-08-30 15:14:29	00:10:22	00:10:05	48.871	-90.079	15.4662
612	2021-08-30 15:14:30	00:10:23	00:10:06	48.87	-90.037	15.4912
613	2021-08-30 15:14:31	00:10:24	00:10:07	48.869	-90.082	15.5162
614	2021-08-30 15:14:32	00:10:25	00:10:08	48.868	-90.034	15.5412
615	2021-08-30 15:14:33	00:10:26	00:10:09	48.866	-90.035	15.5663
616	2021-08-30 15:14:34	00:10:27	00:10:10	48.864	-90.015	15.5913
617	2021-08-30 15:14:35	00:10:28	00:10:11	48.861	-90.013	15.6163
618	2021-08-30 15:14:36	00:10:29	00:10:12	48.858	-90.066	15.6414
619	2021-08-30 15:14:37	00:10:30	00:10:13	48.855	-90.015	15.6664
620	2021-08-30 15:14:38	00:10:31	00:10:14	48.853	-90.017	15.6914
621	2021-08-30 15:14:39	00:10:32	00:10:15	48.85	-90.079	15.7165
622	2021-08-30 15:14:41	00:10:33	00:10:16	48.848	-90.074	15.729
623	2021-08-30 15:14:42	00:10:34	00:10:17	48.846	-90.09	15.7665
624	2021-08-30 15:14:43	00:10:35	00:10:18	48.844	-90.088	15.7915
625	2021-08-30 15:14:44	00:10:36	00:10:19	48.843	-90.015	15.8165
626	2021-08-30 15:14:45	00:10:37	00:10:20	48.841	-90.044	15.8416
627	2021-08-30 15:14:46	00:10:38	00:10:21	48.84	-90.045	15.8665
628	2021-08-30 15:14:47	00:10:39	00:10:22	48.839	-90.028	15.8916
629	2021-08-30 15:14:48	00:10:40	00:10:23	48.837	-90.017	15.9166
630	2021-08-30 15:14:49	00:10:41	00:10:24	48.834	-89.999	15.9416
631	2021-08-30 15:14:50	00:10:42	00:10:25	48.833	-89.943	15.9666
632	2021-08-30 15:14:51	00:10:43	00:10:26	48.83	-89.995	15.9917
633	2021-08-30 15:14:52	00:10:44	00:10:27	48.828	-90.004	16.0167
634	2021-08-30 15:14:53	00:10:45	00:10:28	48.824	-90.072	16.0417
635	2021-08-30 15:14:54	00:10:46	00:10:29	48.821	-90.082	16.0667
636	2021-08-30 15:14:55	00:10:47	00:10:30	48.817	-90.062	16.1043
637	2021-08-30 15:14:56	00:10:48	00:10:31	48.815	-90.098	16.1292
638	2021-08-30 15:14:57	00:10:49	00:10:32	48.813	-90.092	16.1543

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



639	2021-08-30 15:14:58	00:10:50	00:10:33	48.812	-90.068	16.1793
640	2021-08-30 15:14:59	00:10:51	00:10:34	48.809	-90.077	16.2043
641	2021-08-30 15:15:00	00:10:52	00:10:35	48.807	-90.055	16.2293
642	2021-08-30 15:15:01	00:10:53	00:10:36	48.804	-90.036	16.2544
643	2021-08-30 15:15:02	00:10:54	00:10:37	48.802	-90.022	16.2794
644	2021-08-30 15:15:03	00:10:55	00:10:38	48.8	-90.02	16.2919
645	2021-08-30 15:15:04	00:10:56	00:10:39	48.798	-90.023	16.3295
646	2021-08-30 15:15:05	00:10:57	00:10:40	48.796	-90.058	16.3545
647	2021-08-30 15:15:06	00:10:58	00:10:41	48.792	-90.059	16.3795
648	2021-08-30 15:15:07	00:10:59	00:10:42	48.791	-90.04	16.4045
649	2021-08-30 15:15:08	00:11:00	00:10:43	48.789	-90.072	16.4295
650	2021-08-30 15:15:09	00:11:01	00:10:44	48.785	-90.046	16.4546
651	2021-08-30 15:15:10	00:11:02	00:10:45	48.784	-90.075	16.4796
652	2021-08-30 15:15:11	00:11:03	00:10:46	48.782	-90.097	16.5047
653	2021-08-30 15:15:12	00:11:04	00:10:47	48.78	-90.028	16.5297
654	2021-08-30 15:15:13	00:11:05	00:10:48	48.78	-90.06	16.5547
655	2021-08-30 15:15:14	00:11:06	00:10:49	48.777	-90.097	16.5797
656	2021-08-30 15:15:15	00:11:07	00:10:50	48.775	-90.024	16.6047
657	2021-08-30 15:15:16	00:11:08	00:10:51	48.772	-89.99	16.6297
658	2021-08-30 15:15:17	00:11:09	00:10:52	48.769	-90.034	16.6548
659	2021-08-30 15:15:18	00:11:10	00:10:53	48.768	-90	16.6673
660	2021-08-30 15:15:19	00:11:11	00:10:54	48.765	-90.031	16.7048
661	2021-08-30 15:15:20	00:11:12	00:10:55	48.762	-90.03	16.7298
662	2021-08-30 15:15:21	00:11:13	00:10:56	48.76	-90.064	16.7548
663	2021-08-30 15:15:22	00:11:14	00:10:57	48.758	-90.088	16.7799
664	2021-08-30 15:15:23	00:11:15	00:10:58	48.756	-90.05	16.8049
665	2021-08-30 15:15:24	00:11:16	00:10:59	48.754	-90.077	16.8299
666	2021-08-30 15:15:25	00:11:17	00:11:00	48.752	-90.099	16.8549
667	2021-08-30 15:15:26	00:11:18	00:11:01	48.751	-90.048	16.8799
668	2021-08-30 15:15:27	00:11:19	00:11:02	48.75	-89.967	16.9049
669	2021-08-30 15:15:28	00:11:20	00:11:03	48.748	-89.976	16.9299
670	2021-08-30 15:15:29	00:11:21	00:11:04	48.745	-90.012	16.9549
671	2021-08-30 15:15:30	00:11:22	00:11:05	48.742	-90.014	16.9799
672	2021-08-30 15:15:31	00:11:23	00:11:06	48.739	-90.022	17.0049
673	2021-08-30 15:15:32	00:11:24	00:11:07	48.736	-90.05	17.0299
674	2021-08-30 15:15:33	00:11:25	00:11:08	48.734	-90.034	17.0424
675	2021-08-30 15:15:34	00:11:26	00:11:09	48.731	-90.092	17.0799
676	2021-08-30 15:15:35	00:11:27	00:11:10	48.728	-90.095	17.1049
677	2021-08-30 15:15:36	00:11:28	00:11:11	48.727	-90.009	17.1299
678	2021-08-30 15:15:37	00:11:29	00:11:12	48.726	-89.975	17.1549
679	2021-08-30 15:15:38	00:11:30	00:11:13	48.722	-90.025	17.18
680	2021-08-30 15:15:39	00:11:31	00:11:14	48.72	-89.981	17.2049
681	2021-08-30 15:15:40	00:11:32	00:11:15	48.718	-89.99	17.23
682	2021-08-30 15:15:41	00:11:33	00:11:16	48.715	-89.982	17.255
683	2021-08-30 15:15:42	00:11:34	00:11:17	48.712	-90.026	17.28
684	2021-08-30 15:15:43	00:11:35	00:11:18	48.708	-90.066	17.305
685	2021-08-30 15:15:44	00:11:36	00:11:19	48.706	-90.006	17.33
686	2021-08-30 15:15:45	00:11:37	00:11:20	48.703	-90.05	17.3551
687	2021-08-30 15:15:46	00:11:38	00:11:21	48.7	-90.001	17.3801
688	2021-08-30 15:15:47	00:11:39	00:11:22	48.698	-90.021	17.4176
689	2021-08-30 15:15:48	00:11:40	00:11:23	48.697	-90.065	17.4426
690	2021-08-30 15:15:49	00:11:41	00:11:24	48.694	-90.046	17.4677
691	2021-08-30 15:15:50	00:11:42	00:11:25	48.692	-90.049	17.4927
692	2021-08-30 15:15:51	00:11:43	00:11:26	48.689	-90.017	17.5177
693	2021-08-30 15:15:52	00:11:44	00:11:27	48.686	-90.086	17.5427
694	2021-08-30 15:15:53	00:11:45	00:11:28	48.683	-90.086	17.5677
695	2021-08-30 15:15:54	00:11:46	00:11:29	48.681	-90.032	17.5927
696	2021-08-30 15:15:55	00:11:47	00:11:30	48.679	-90.017	17.6052
697	2021-08-30 15:15:56	00:11:48	00:11:31	48.678	-90.074	17.6428
698	2021-08-30 15:15:57	00:11:49	00:11:32	48.676	-90.047	17.6678
699	2021-08-30 15:15:58	00:11:50	00:11:33	48.673	-90.041	17.6928

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



700	2021-08-30 15:15:59	00:11:51	00:11:34	48.671	-90.046	17.7179
701	2021-08-30 15:16:00	00:11:52	00:11:35	48.669	-89.979	17.7429
702	2021-08-30 15:16:01	00:11:53	00:11:36	48.666	-90.018	17.7679
703	2021-08-30 15:16:02	00:11:55	00:11:38	48.662	-90.046	17.7929
704	2021-08-30 15:16:03	00:11:55	00:11:38	48.66	-90.032	17.8179
705	2021-08-30 15:16:04	00:11:57	00:11:40	48.657	-90.035	17.8429
706	2021-08-30 15:16:05	00:11:57	00:11:40	48.654	-90.082	17.8679
707	2021-08-30 15:16:06	00:11:59	00:11:42	48.651	-90.084	17.893
708	2021-08-30 15:16:07	00:11:59	00:11:42	48.65	-90.011	17.918
709	2021-08-30 15:16:08	00:12:01	00:11:44	48.645	-90.043	17.943
710	2021-08-30 15:16:09	00:12:01	00:11:44	48.644	-89.973	17.968
711	2021-08-30 15:16:10	00:12:03	00:11:46	48.642	-89.965	17.9805
712	2021-08-30 15:16:11	00:12:03	00:11:46	48.64	-89.952	18.018
713	2021-08-30 15:16:12	00:12:05	00:11:48	48.637	-90.013	18.043
714	2021-08-30 15:16:13	00:12:05	00:11:48	48.634	-90.013	18.068
715	2021-08-30 15:16:14	00:12:07	00:11:50	48.632	-90.034	18.093
716	2021-08-30 15:16:15	00:12:07	00:11:50	48.629	-90.084	18.118
717	2021-08-30 15:16:16	00:12:09	00:11:52	48.626	-90.088	18.143
718	2021-08-30 15:16:17	00:12:09	00:11:52	48.624	-90.029	18.1679
719	2021-08-30 15:16:18	00:12:11	00:11:54	48.621	-90.032	18.193
720	2021-08-30 15:16:19	00:12:11	00:11:54	48.618	-90.037	18.218
721	2021-08-30 15:16:20	00:12:13	00:11:56	48.616	-89.979	18.243
722	2021-08-30 15:16:21	00:12:13	00:11:56	48.612	-90.055	18.2681
723	2021-08-30 15:16:22	00:12:15	00:11:58	48.609	-90.071	18.2931
724	2021-08-30 15:16:23	00:12:15	00:11:58	48.604	-90.009	18.3181
725	2021-08-30 15:16:24	00:12:17	00:12:00	48.601	-90.096	18.3431
726	2021-08-30 15:16:25	00:12:17	00:12:00	48.598	-90.024	18.3556
727	2021-08-30 15:16:26	00:12:19	00:12:02	48.595	-90.035	18.3932
728	2021-08-30 15:16:27	00:12:19	00:12:02	48.593	-90.072	18.4182
729	2021-08-30 15:16:28	00:12:21	00:12:04	48.59	-90	18.4432
730	2021-08-30 15:16:29	00:12:21	00:12:04	48.589	-90.087	18.4682
731	2021-08-30 15:16:30	00:12:23	00:12:06	48.587	-90.021	18.4932
732	2021-08-30 15:16:31	00:12:23	00:12:06	48.583	-89.997	18.5183
733	2021-08-30 15:16:32	00:12:25	00:12:08	48.58	-90.001	18.5432
734	2021-08-30 15:16:33	00:12:25	00:12:08	48.578	-89.979	18.5682
735	2021-08-30 15:16:34	00:12:27	00:12:10	48.576	-89.967	18.5932
736	2021-08-30 15:16:35	00:12:28	00:12:11	48.572	-90.057	18.6183
737	2021-08-30 15:16:36	00:12:29	00:12:12	48.568	-90.091	18.6433
738	2021-08-30 15:16:37	00:12:30	00:12:13	48.565	-90.052	18.6683
739	2021-08-30 15:16:38	00:12:31	00:12:14	48.559	-90.087	18.6933
740	2021-08-30 15:16:39	00:12:32	00:12:15	48.557	-90.07	18.7183
741	2021-08-30 15:16:40	00:12:33	00:12:16	48.554	-90.053	18.7308
742	2021-08-30 15:16:41	00:12:34	00:12:17	48.551	-90.03	18.7683
743	2021-08-30 15:16:42	00:12:35	00:12:18	48.547	-90.045	18.7934
744	2021-08-30 15:16:43	00:12:36	00:12:19	48.545	-89.98	18.8184
745	2021-08-30 15:16:44	00:12:37	00:12:20	48.544	-89.957	18.8434
746	2021-08-30 15:16:45	00:12:38	00:12:21	48.541	-89.951	18.8684
747	2021-08-30 15:16:46	00:12:39	00:12:22	48.536	-90.016	18.8934
748	2021-08-30 15:16:47	00:12:40	00:12:23	48.533	-90.034	18.9184
749	2021-08-30 15:16:48	00:12:41	00:12:24	48.531	-90.064	18.9435
750	2021-08-30 15:16:49	00:12:42	00:12:25	48.527	-90.062	18.9684
751	2021-08-30 15:16:50	00:12:43	00:12:26	48.522	-90.005	18.9935
752	2021-08-30 15:16:51	00:12:44	00:12:27	48.52	-90.064	19.0185
753	2021-08-30 15:16:52	00:12:45	00:12:28	48.517	-90.05	19.0435
754	2021-08-30 15:16:53	00:12:46	00:12:29	48.512	-90.095	19.0685
755	2021-08-30 15:16:54	00:12:47	00:12:30	48.509	-90.04	19.0935
756	2021-08-30 15:16:55	00:12:48	00:12:31	48.504	-90.057	19.1061
757	2021-08-30 15:16:56	00:12:49	00:12:32	48.502	-89.989	19.1436
758	2021-08-30 15:16:57	00:12:50	00:12:33	48.498	-90.039	19.1686
759	2021-08-30 15:16:58	00:12:51	00:12:34	48.496	-89.964	19.1936
760	2021-08-30 15:16:59	00:12:52	00:12:35	48.495	-89.942	19.2186

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



761	2021-08-30 15:17:00	00:12:53	00:12:36	48.492	-89.993	19.2436
762	2021-08-30 15:17:01	00:12:54	00:12:37	48.489	-89.97	19.2686
763	2021-08-30 15:17:02	00:12:55	00:12:38	48.484	-89.931	19.2936
764	2021-08-30 15:17:03	00:12:56	00:12:39	48.479	-89.992	19.3187
765	2021-08-30 15:17:04	00:12:57	00:12:40	48.475	-90.012	19.3437
766	2021-08-30 15:17:05	00:12:58	00:12:41	48.47	-90.032	19.3687
767	2021-08-30 15:17:06	00:12:59	00:12:42	48.466	-90.063	19.3937
768	2021-08-30 15:17:07	00:13:00	00:12:43	48.461	-90.092	19.4187
769	2021-08-30 15:17:08	00:13:01	00:12:44	48.455	-90.009	19.4437
770	2021-08-30 15:17:09	00:13:02	00:12:45	48.451	-90.012	19.4687
771	2021-08-30 15:17:10	00:13:03	00:12:46	48.446	-90.059	19.4812
772	2021-08-30 15:17:11	00:13:04	00:12:47	48.443	-90.021	19.5188
773	2021-08-30 15:17:13	00:13:05	00:12:48	48.44	-90.004	19.5438
774	2021-08-30 15:17:14	00:13:06	00:12:49	48.437	-90.021	19.5688
775	2021-08-30 15:17:15	00:13:07	00:12:50	48.435	-90.02	19.5938
776	2021-08-30 15:17:16	00:13:08	00:12:51	48.432	-90.096	19.6189
777	2021-08-30 15:17:17	00:13:09	00:12:52	48.428	-90.091	19.6439
778	2021-08-30 15:17:18	00:13:10	00:12:53	48.424	-90.037	19.6689
779	2021-08-30 15:17:19	00:13:11	00:12:54	48.419	-90	19.694
780	2021-08-30 15:17:20	00:13:12	00:12:55	48.416	-90.062	19.719
781	2021-08-30 15:17:21	00:13:13	00:12:56	48.412	-90.062	19.744
782	2021-08-30 15:17:22	00:13:14	00:12:57	48.409	-90.055	19.769
783	2021-08-30 15:17:23	00:13:15	00:12:58	48.404	-90.059	19.794
784	2021-08-30 15:17:24	00:13:16	00:12:59	48.396	-90.008	19.8191
785	2021-08-30 15:17:25	00:13:17	00:13:00	48.392	-90.091	19.8441
786	2021-08-30 15:17:26	00:13:18	00:13:01	48.387	-90.029	19.8565
787	2021-08-30 15:17:27	00:13:19	00:13:02	48.382	-90.036	19.8941
788	2021-08-30 15:17:28	00:13:20	00:13:03	48.379	-90.063	19.9191
789	2021-08-30 15:17:29	00:13:21	00:13:04	48.374	-90.092	19.9441
790	2021-08-30 15:17:30	00:13:22	00:13:05	48.372	-90.092	19.9692
791	2021-08-30 15:17:31	00:13:23	00:13:06	48.365	-90.03	20.0067
792	2021-08-30 15:17:32	00:13:24	00:13:07	48.362	-90.014	20.0317
793	2021-08-30 15:17:33	00:13:25	00:13:08	48.358	-90.043	20.0442
794	2021-08-30 15:17:34	00:13:26	00:13:09	48.354	-90.039	20.0818
795	2021-08-30 15:17:35	00:13:27	00:13:10	48.35	-90.065	20.1067
796	2021-08-30 15:17:36	00:13:28	00:13:11	48.344	-90.019	20.1318
797	2021-08-30 15:17:37	00:13:29	00:13:12	48.342	-90	20.1568
798	2021-08-30 15:17:38	00:13:30	00:13:13	48.337	-90.08	20.1818
799	2021-08-30 15:17:39	00:13:31	00:13:14	48.331	-90.046	20.2068
800	2021-08-30 15:17:40	00:13:32	00:13:15	48.329	-90.048	20.2318
801	2021-08-30 15:17:41	00:13:33	00:13:16	48.325	-90.051	20.2569
802	2021-08-30 15:17:42	00:13:34	00:13:17	48.322	-89.97	20.2819
803	2021-08-30 15:17:43	00:13:35	00:13:18	48.316	-90.043	20.3069
804	2021-08-30 15:17:44	00:13:36	00:13:19	48.313	-89.987	20.3319
805	2021-08-30 15:17:45	00:13:37	00:13:20	48.307	-90.031	20.357
806	2021-08-30 15:17:46	00:13:38	00:13:21	48.3	-90.025	20.3819
807	2021-08-30 15:17:47	00:13:39	00:13:22	48.296	-90.024	20.4069
808	2021-08-30 15:17:48	00:13:40	00:13:23	48.292	-90.054	20.4194
809	2021-08-30 15:17:49	00:13:41	00:13:24	48.288	-90.024	20.457
810	2021-08-30 15:17:50	00:13:42	00:13:25	48.284	-89.98	20.4819
811	2021-08-30 15:17:51	00:13:43	00:13:26	48.279	-89.976	20.5069
812	2021-08-30 15:17:52	00:13:44	00:13:27	48.276	-89.988	20.532
813	2021-08-30 15:17:53	00:13:45	00:13:28	48.271	-89.972	20.5569
814	2021-08-30 15:17:54	00:13:46	00:13:29	48.266	-89.967	20.5819
815	2021-08-30 15:17:55	00:13:47	00:13:30	48.26	-89.969	20.607
816	2021-08-30 15:17:56	00:13:48	00:13:31	48.254	-90.019	20.632
817	2021-08-30 15:17:57	00:13:49	00:13:32	48.25	-90.014	20.657
818	2021-08-30 15:17:58	00:13:50	00:13:33	48.243	-90.006	20.682
819	2021-08-30 15:17:59	00:13:51	00:13:34	48.238	-90.014	20.707
820	2021-08-30 15:18:00	00:13:52	00:13:35	48.234	-90.029	20.732
821	2021-08-30 15:18:01	00:13:53	00:13:36	48.227	-90.086	20.757

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



822	2021-08-30 15:18:02	00:13:54	00:13:37	48.222	-90.071	20.782
823	2021-08-30 15:18:03	00:13:55	00:13:38	48.216	-90.013	20.7946
824	2021-08-30 15:18:04	00:13:56	00:13:39	48.212	-90.064	20.8321
825	2021-08-30 15:18:05	00:13:57	00:13:40	48.206	-90.097	20.8571
826	2021-08-30 15:18:06	00:13:58	00:13:41	48.201	-90.087	20.8821
827	2021-08-30 15:18:07	00:13:59	00:13:42	48.199	-90.077	20.9071
828	2021-08-30 15:18:08	00:14:00	00:13:43	48.191	-90.073	20.9322
829	2021-08-30 15:18:09	00:14:01	00:13:44	48.185	-90.096	20.9572
830	2021-08-30 15:18:10	00:14:02	00:13:45	48.18	-90.051	20.9822
831	2021-08-30 15:18:11	00:14:03	00:13:46	48.174	-90.093	21.0072
832	2021-08-30 15:18:12	00:14:04	00:13:47	48.17	-90.098	21.0322
833	2021-08-30 15:18:13	00:14:05	00:13:48	48.167	-90.034	21.0572
834	2021-08-30 15:18:14	00:14:06	00:13:49	48.161	-90.075	21.0823
835	2021-08-30 15:18:15	00:14:07	00:13:50	48.157	-89.994	21.1073
836	2021-08-30 15:18:16	00:14:08	00:13:51	48.147	-90.044	21.1323
837	2021-08-30 15:18:17	00:14:09	00:13:52	48.14	-90	21.1574
838	2021-08-30 15:18:18	00:14:10	00:13:53	48.135	-90.08	21.1699
839	2021-08-30 15:18:19	00:14:11	00:13:54	48.129	-90.017	21.2074
840	2021-08-30 15:18:20	00:14:12	00:13:55	48.123	-90.044	21.2324
841	2021-08-30 15:18:21	00:14:13	00:13:56	48.118	-90.014	21.2574
842	2021-08-30 15:18:22	00:14:14	00:13:57	48.115	-90.005	21.2824
843	2021-08-30 15:18:23	00:14:15	00:13:58	48.11	-90.084	21.3075
844	2021-08-30 15:18:24	00:14:16	00:13:59	48.104	-90.082	21.3325
845	2021-08-30 15:18:25	00:14:17	00:14:00	48.098	-90.086	21.3575
846	2021-08-30 15:18:26	00:14:18	00:14:01	48.093	-90.044	21.3825
847	2021-08-30 15:18:27	00:14:19	00:14:02	48.087	-90.015	21.4076
848	2021-08-30 15:18:28	00:14:20	00:14:03	48.08	-90.06	21.4326
849	2021-08-30 15:18:29	00:14:21	00:14:04	48.074	-90.042	21.4576
850	2021-08-30 15:18:30	00:14:22	00:14:05	48.067	-90.065	21.4826
851	2021-08-30 15:18:31	00:14:23	00:14:06	48.057	-90.074	21.5076
852	2021-08-30 15:18:32	00:14:24	00:14:07	48.049	-90.056	21.5452
853	2021-08-30 15:18:33	00:14:25	00:14:08	48.044	-90.013	21.5702
854	2021-08-30 15:18:34	00:14:26	00:14:09	48.036	-90.061	21.5952
855	2021-08-30 15:18:35	00:14:27	00:14:10	48.029	-90.041	21.6202
856	2021-08-30 15:18:36	00:14:28	00:14:11	48.022	-90.03	21.6453
857	2021-08-30 15:18:37	00:14:29	00:14:12	48.016	-90.081	21.6703
858	2021-08-30 15:18:38	00:14:30	00:14:13	48.006	-90.027	21.6953
859	2021-08-30 15:18:39	00:14:31	00:14:14	47.999	-90.018	21.7203
860	2021-08-30 15:18:40	00:14:32	00:14:15	47.993	-89.988	21.7328
861	2021-08-30 15:18:41	00:14:33	00:14:16	47.986	-90.016	21.7704
862	2021-08-30 15:18:42	00:14:34	00:14:17	47.98	-90.002	21.7954
863	2021-08-30 15:18:43	00:14:35	00:14:18	47.972	-90.03	21.8204
864	2021-08-30 15:18:44	00:14:36	00:14:19	47.969	-89.999	21.8454
865	2021-08-30 15:18:45	00:14:37	00:14:20	47.961	-90.059	21.8704
866	2021-08-30 15:18:46	00:14:39	00:14:22	47.953	-90.005	21.8954
867	2021-08-30 15:18:47	00:14:39	00:14:22	47.946	-90.016	21.9205
868	2021-08-30 15:18:48	00:14:41	00:14:24	47.938	-90.02	21.9455
869	2021-08-30 15:18:49	00:14:41	00:14:24	47.93	-90.014	21.9705
870	2021-08-30 15:18:50	00:14:43	00:14:26	47.923	-90.005	21.9955
871	2021-08-30 15:18:51	00:14:43	00:14:26	47.914	-90.012	22.0205
872	2021-08-30 15:18:52	00:14:45	00:14:28	47.907	-90.029	22.0456
873	2021-08-30 15:18:53	00:14:45	00:14:28	47.897	-89.974	22.0706
874	2021-08-30 15:18:54	00:14:47	00:14:30	47.889	-89.999	22.0956
875	2021-08-30 15:18:55	00:14:47	00:14:30	47.881	-89.961	22.1081
876	2021-08-30 15:18:56	00:14:49	00:14:32	47.872	-89.988	22.1456
877	2021-08-30 15:18:57	00:14:49	00:14:32	47.863	-90.058	22.1707
878	2021-08-30 15:18:58	00:14:51	00:14:34	47.856	-89.981	22.1957
879	2021-08-30 15:18:59	00:14:51	00:14:34	47.851	-90.03	22.2207
880	2021-08-30 15:19:00	00:14:53	00:14:36	47.843	-90.037	22.2457
881	2021-08-30 15:19:01	00:14:53	00:14:36	47.832	-90.01	22.2708
882	2021-08-30 15:19:02	00:14:55	00:14:38	47.823	-90.042	22.2958

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



883	2021-08-30 15:19:03	00:14:55	00:14:38	47.814	-90.035	22.3208
884	2021-08-30 15:19:04	00:14:57	00:00:01	48.027	0	22.3258
885	2021-08-30 15:19:05	00:14:57	00:00:01	48.413	0	22.3258
886	2021-08-30 15:19:06	00:14:59	00:00:03	48.729	0	22.3258
887	2021-08-30 15:19:07	00:14:59	00:00:03	49.099	0	22.3258
888	2021-08-30 15:19:08	00:15:01	00:00:05	49.29	0	22.3258
889	2021-08-30 15:19:09	00:15:01	00:00:05	49.447	0	22.3258
890	2021-08-30 15:19:10	00:15:03	00:00:07	49.577	0	22.3258
891	2021-08-30 15:19:11	00:15:03	00:00:07	49.685	0	22.3258
892	2021-08-30 15:19:12	00:15:05	00:00:09	49.775	0	22.3258
893	2021-08-30 15:19:13	00:15:05	00:00:09	49.815	0	22.3258
894	2021-08-30 15:19:14	00:15:07	00:00:11	49.887	0	22.3258
895	2021-08-30 15:19:15	00:15:07	00:00:11	49.949	0	22.3258
896	2021-08-30 15:19:16	00:15:09	00:00:13	50.003	0	22.3258
897	2021-08-30 15:19:17	00:15:09	00:00:13	50.051	0	22.3258
898	2021-08-30 15:19:18	00:15:11	00:00:15	50.093	0	22.3258
899	2021-08-30 15:19:19	00:15:11	00:00:15	50.131	0	22.3258
900	2021-08-30 15:19:20	00:15:13	00:00:17	50.166	0	22.3258
901	2021-08-30 15:19:21	00:15:13	00:00:17	50.198	0	22.3258
902	2021-08-30 15:19:22	00:15:15	00:00:19	50.241	0	22.3258
903	2021-08-30 15:19:23	00:15:15	00:00:19	50.267	0	22.3258
904	2021-08-30 15:19:24	00:15:17	00:00:21	50.292	0	22.3258
905	2021-08-30 15:19:25	00:15:18	00:00:22	50.315	0	22.3258
906	2021-08-30 15:19:26	00:15:19	00:00:23	50.337	0	22.3258
907	2021-08-30 15:19:27	00:15:20	00:00:24	50.358	0	22.3258
908	2021-08-30 15:19:28	00:15:21	00:00:25	50.368	0	22.3258
909	2021-08-30 15:19:29	00:15:22	00:00:26	50.387	0	22.3258
910	2021-08-30 15:19:30	00:15:23	00:00:27	50.405	0	22.3258
911	2021-08-30 15:19:31	00:15:24	00:00:28	50.423	0	22.3258
912	2021-08-30 15:19:32	00:15:25	00:00:29	50.441	0	22.3258
913	2021-08-30 15:19:33	00:15:26	00:00:30	50.457	0	22.3258
914	2021-08-30 15:19:34	00:15:27	00:00:31	50.473	0	22.3258
915	2021-08-30 15:19:35	00:15:28	00:00:32	50.488	0	22.3258
916	2021-08-30 15:19:36	00:15:29	00:00:33	50.502	0	22.3258
917	2021-08-30 15:19:37	00:15:30	00:00:34	50.523	0	22.3258
918	2021-08-30 15:19:38	00:15:31	00:00:35	50.537	0	22.3258
919	2021-08-30 15:19:39	00:15:32	00:00:36	50.55	0	22.3258
920	2021-08-30 15:19:40	00:15:33	00:00:37	50.562	0	22.3258
921	2021-08-30 15:19:41	00:15:34	00:00:38	50.574	0	22.3258
922	2021-08-30 15:19:42	00:15:35	00:00:39	50.586	0	22.3258
923	2021-08-30 15:19:43	00:15:36	00:00:40	50.592	0	22.3258
924	2021-08-30 15:19:44	00:15:37	00:00:41	50.602	0	22.3258
925	2021-08-30 15:19:45	00:15:38	00:00:42	50.612	0	22.3258
926	2021-08-30 15:19:46	00:15:39	00:00:43	50.622	0	22.3258
927	2021-08-30 15:19:47	00:15:40	00:00:44	50.632	0	22.3258
928	2021-08-30 15:19:48	00:15:41	00:00:45	50.641	0	22.3258
929	2021-08-30 15:19:49	00:15:42	00:00:46	50.658	0	22.3258
930	2021-08-30 15:19:50	00:15:43	00:00:47	50.662	0	22.3258
931	2021-08-30 15:19:51	00:15:44	00:00:48	50.67	0	22.3258
932	2021-08-30 15:19:52	00:15:45	00:00:49	50.678	0	22.3258
933	2021-08-30 15:19:53	00:15:46	00:00:50	50.686	0	22.3258
934	2021-08-30 15:19:54	00:15:47	00:00:51	50.694	0	22.3258
935	2021-08-30 15:19:55	00:15:48	00:00:52	50.702	0	22.3258
936	2021-08-30 15:19:56	00:15:49	00:00:53	50.71	0	22.3258
937	2021-08-30 15:19:57	00:15:50	00:00:54	50.718	0	22.3258
938	2021-08-30 15:19:58	00:15:51	00:00:55	50.726	0	22.3258
939	2021-08-30 15:20:00	00:15:52	00:00:56	50.737	0	22.3258
940	2021-08-30 15:20:01	00:15:53	00:00:57	50.743	0	22.3258
941	2021-08-30 15:20:02	00:15:54	00:00:58	50.75	0	22.3258
942	2021-08-30 15:20:03	00:15:55	00:00:59	50.756	0	22.3258
943	2021-08-30 15:20:04	00:15:56	00:01:00	50.762	0	22.3258

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



944	2021-08-30 15:20:05	00:15:57	00:01:01	50.768	0	22.3258
945	2021-08-30 15:20:06	00:15:58	00:01:02	50.771	0	22.3258
946	2021-08-30 15:20:07	00:15:59	00:01:03	50.777	0	22.3258
947	2021-08-30 15:20:08	00:16:00	00:01:04	50.783	0	22.3258
948	2021-08-30 15:20:09	00:16:01	00:01:05	50.789	0	22.3258
949	2021-08-30 15:20:10	00:16:02	00:01:06	50.794	0	22.3258
950	2021-08-30 15:20:11	00:16:03	00:01:07	50.798	0	22.3258
951	2021-08-30 15:20:12	00:16:04	00:01:08	50.803	0	22.3258
952	2021-08-30 15:20:13	00:16:05	00:01:09	50.808	0	22.3258
953	2021-08-30 15:20:14	00:16:06	00:01:10	50.812	0	22.3258
954	2021-08-30 15:20:15	00:16:07	00:01:11	50.818	0	22.3258
955	2021-08-30 15:20:16	00:16:08	00:01:12	50.823	0	22.3258
956	2021-08-30 15:20:17	00:16:09	00:01:13	50.827	0	22.3258
957	2021-08-30 15:20:18	00:16:10	00:01:14	50.832	0	22.3258
958	2021-08-30 15:20:19	00:16:11	00:01:15	50.836	0	22.3258
959	2021-08-30 15:20:20	00:16:12	00:01:16	50.84	0	22.3258
960	2021-08-30 15:20:21	00:16:13	00:01:17	50.842	0	22.3258
961	2021-08-30 15:20:22	00:16:14	00:01:18	50.846	0	22.3258
962	2021-08-30 15:20:23	00:16:15	00:01:19	50.85	0	22.3258
963	2021-08-30 15:20:24	00:16:16	00:01:20	50.854	0	22.3258
964	2021-08-30 15:20:25	00:16:17	00:01:21	50.858	0	22.3258
965	2021-08-30 15:20:26	00:16:18	00:01:22	50.862	0	22.3258
966	2021-08-30 15:20:27	00:16:19	00:01:23	50.866	0	22.3258
967	2021-08-30 15:20:28	00:16:20	00:01:24	50.87	0	22.3258
968	2021-08-30 15:20:29	00:16:21	00:01:25	50.874	0	22.3258
969	2021-08-30 15:20:30	00:16:22	00:01:26	50.879	0	22.3258
970	2021-08-30 15:20:31	00:16:23	00:01:27	50.883	0	22.3258
971	2021-08-30 15:20:32	00:16:24	00:01:28	50.886	0	22.3258
972	2021-08-30 15:20:33	00:16:25	00:01:29	50.89	0	22.3258
973	2021-08-30 15:20:34	00:16:26	00:01:30	50.894	0	22.3258
974	2021-08-30 15:20:35	00:16:27	00:01:31	50.896	0	22.3258
975	2021-08-30 15:20:36	00:16:28	00:01:32	50.898	0	22.3258
976	2021-08-30 15:20:37	00:16:29	00:01:33	50.9	0	22.3258
977	2021-08-30 15:20:38	00:16:30	00:01:34	50.903	0	22.3258
978	2021-08-30 15:20:39	00:16:31	00:01:35	50.905	0	22.3258
979	2021-08-30 15:20:40	00:16:32	00:01:36	50.908	0	22.3258
980	2021-08-30 15:20:41	00:16:33	00:01:37	50.91	0	22.3258
981	2021-08-30 15:20:42	00:16:34	00:01:38	50.912	0	22.3258
982	2021-08-30 15:20:43	00:16:35	00:01:39	50.915	0	22.3258
983	2021-08-30 15:20:44	00:16:36	00:01:40	50.917	0	22.3258
984	2021-08-30 15:20:45	00:16:37	00:01:41	50.921	0	22.3258
985	2021-08-30 15:20:46	00:16:38	00:01:42	50.923	0	22.3258
986	2021-08-30 15:20:47	00:16:39	00:01:43	50.925	0	22.3258
987	2021-08-30 15:20:48	00:16:40	00:01:44	50.927	0	22.3258
988	2021-08-30 15:20:49	00:16:41	00:01:45	50.929	0	22.3258
989	2021-08-30 15:20:50	00:16:42	00:01:46	50.931	0	22.3258
990	2021-08-30 15:20:51	00:16:43	00:01:47	50.932	0	22.3258
991	2021-08-30 15:20:52	00:16:44	00:01:48	50.934	0	22.3258
992	2021-08-30 15:20:53	00:16:45	00:01:49	50.938	0	22.3258
993	2021-08-30 15:20:54	00:16:46	00:01:50	50.94	0	22.3258
994	2021-08-30 15:20:55	00:16:47	00:01:51	50.942	0	22.3258
995	2021-08-30 15:20:56	00:16:48	00:01:52	50.944	0	22.3258
996	2021-08-30 15:20:57	00:16:49	00:01:53	50.946	0	22.3258
997	2021-08-30 15:20:58	00:16:50	00:01:54	50.948	0	22.3258
998	2021-08-30 15:20:59	00:16:51	00:01:55	50.95	0	22.3258
999	2021-08-30 15:21:00	00:16:52	00:01:56	50.953	0	22.3258
1000	2021-08-30 15:21:01	00:16:53	00:01:57	50.955	0	22.3258
1001	2021-08-30 15:21:02	00:16:54	00:01:58	50.957	0	22.3258
1002	2021-08-30 15:21:03	00:16:55	00:01:59	50.959	0	22.3258
1003	2021-08-30 15:21:04	00:16:56	00:02:00	50.962	0	22.3258
1004	2021-08-30 15:21:05	00:16:57	00:02:01	50.964	0	22.3258

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1005	2021-08-30 15:21:06	00:16:58	00:02:02	50.965	0	22.3258
1006	2021-08-30 15:21:07	00:16:59	00:02:03	50.967	0	22.3258
1007	2021-08-30 15:21:08	00:17:00	00:02:04	50.969	0	22.3258
1008	2021-08-30 15:21:09	00:17:01	00:02:05	50.971	0	22.3258
1009	2021-08-30 15:21:10	00:17:02	00:02:06	50.973	0	22.3258
1010	2021-08-30 15:21:11	00:17:03	00:02:07	50.975	0	22.3258
1011	2021-08-30 15:21:12	00:17:04	00:02:08	50.977	0	22.3258
1012	2021-08-30 15:21:13	00:17:05	00:02:09	50.979	0	22.3258
1013	2021-08-30 15:21:14	00:17:06	00:02:10	50.981	0	22.3258
1014	2021-08-30 15:21:15	00:17:07	00:02:11	50.984	0	22.3258
1015	2021-08-30 15:21:16	00:17:08	00:02:12	50.986	0	22.3258
1016	2021-08-30 15:21:17	00:17:09	00:02:13	50.988	0	22.3258
1017	2021-08-30 15:21:18	00:17:10	00:02:14	50.989	0	22.3258
1018	2021-08-30 15:21:19	00:17:11	00:02:15	50.991	0	22.3258
1019	2021-08-30 15:21:20	00:17:12	00:02:16	50.992	0	22.3258
1020	2021-08-30 15:21:21	00:17:13	00:02:17	50.993	0	22.3258
1021	2021-08-30 15:21:22	00:17:14	00:02:18	50.994	0	22.3258
1022	2021-08-30 15:21:23	00:17:15	00:02:19	50.996	0	22.3258
1023	2021-08-30 15:21:24	00:17:16	00:02:20	50.998	0	22.3258
1024	2021-08-30 15:21:25	00:17:17	00:02:21	51	0	22.3258
1025	2021-08-30 15:21:26	00:17:18	00:02:22	51.002	0	22.3258
1026	2021-08-30 15:21:27	00:17:19	00:02:23	51.003	0	22.3258
1027	2021-08-30 15:21:28	00:17:20	00:02:24	51.003	0	22.3258
1028	2021-08-30 15:21:29	00:17:21	00:02:25	51.003	0	22.3258
1029	2021-08-30 15:21:30	00:17:22	00:02:26	51.006	0	22.3258
1030	2021-08-30 15:21:31	00:17:23	00:02:27	51.008	0	22.3258
1031	2021-08-30 15:21:32	00:17:24	00:02:28	51.01	0	22.3258
1032	2021-08-30 15:21:33	00:17:25	00:02:29	51.011	0	22.3258
1033	2021-08-30 15:21:34	00:17:26	00:02:30	51.013	0	22.3258
1034	2021-08-30 15:21:35	00:17:27	00:02:31	51.014	0	22.3258
1035	2021-08-30 15:21:36	00:17:28	00:02:32	51.014	0	22.3258
1036	2021-08-30 15:21:37	00:17:29	00:02:33	51.015	0	22.3258
1037	2021-08-30 15:21:38	00:17:30	00:02:34	51.015	0	22.3258
1038	2021-08-30 15:21:39	00:17:31	00:02:35	51.017	0	22.3258
1039	2021-08-30 15:21:40	00:17:32	00:02:36	51.019	0	22.3258
1040	2021-08-30 15:21:41	00:17:33	00:02:37	51.02	0	22.3258
1041	2021-08-30 15:21:42	00:17:34	00:02:38	51.02	0	22.3258
1042	2021-08-30 15:21:43	00:17:35	00:02:39	51.022	0	22.3258
1043	2021-08-30 15:21:44	00:17:36	00:02:40	51.024	0	22.3258
1044	2021-08-30 15:21:45	00:17:37	00:02:41	51.026	0	22.3258
1045	2021-08-30 15:21:46	00:17:38	00:02:42	51.027	0	22.3258
1046	2021-08-30 15:21:47	00:17:39	00:02:43	51.028	0	22.3258
1047	2021-08-30 15:21:48	00:17:40	00:02:44	51.03	0	22.3258
1048	2021-08-30 15:21:49	00:17:41	00:02:45	51.031	0	22.3258
1049	2021-08-30 15:21:50	00:17:43	00:02:47	51.031	0	22.3258
1050	2021-08-30 15:21:51	00:17:43	00:02:47	51.032	0	22.3258
1051	2021-08-30 15:21:52	00:17:45	00:02:49	51.035	0	22.3258
1052	2021-08-30 15:21:53	00:17:45	00:02:49	51.036	0	22.3258
1053	2021-08-30 15:21:54	00:17:47	00:02:51	51.036	0	22.3258
1054	2021-08-30 15:21:55	00:17:47	00:02:51	51.037	0	22.3258
1055	2021-08-30 15:21:56	00:17:49	00:02:53	51.037	0	22.3258
1056	2021-08-30 15:21:57	00:17:49	00:02:53	51.039	0	22.3258
1057	2021-08-30 15:21:58	00:17:51	00:02:55	51.04	0	22.3258
1058	2021-08-30 15:21:59	00:17:51	00:02:55	51.041	0	22.3258
1059	2021-08-30 15:22:00	00:17:53	00:02:57	51.042	0	22.3258
1060	2021-08-30 15:22:01	00:17:53	00:02:57	51.042	0	22.3258
1061	2021-08-30 15:22:02	00:17:55	00:02:59	51.044	0	22.3258
1062	2021-08-30 15:22:03	00:17:55	00:02:59	51.044	0	22.3258
1063	2021-08-30 15:22:04	00:17:57	00:03:01	51.045	0	22.3258
1064	2021-08-30 15:22:05	00:17:57	00:03:01	51.046	0	22.3258
1065	2021-08-30 15:22:06	00:17:59	00:03:03	51.047	0	22.3258

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1066	2021-08-30 15:22:07	00:17:59	00:03:03	51.048	0	22.3258
1067	2021-08-30 15:22:08	00:18:01	00:03:05	51.049	0	22.3258
1068	2021-08-30 15:22:09	00:18:01	00:03:05	51.05	0	22.3258
1069	2021-08-30 15:22:10	00:18:03	00:03:07	51.05	0	22.3258
1070	2021-08-30 15:22:11	00:18:03	00:03:07	51.051	0	22.3258
1071	2021-08-30 15:22:12	00:18:05	00:03:09	51.051	0	22.3258
1072	2021-08-30 15:22:13	00:18:05	00:03:09	51.052	0	22.3258
1073	2021-08-30 15:22:14	00:18:07	00:03:11	51.053	0	22.3258
1074	2021-08-30 15:22:15	00:18:07	00:03:11	51.054	0	22.3258
1075	2021-08-30 15:22:16	00:18:09	00:03:13	51.055	0	22.3258
1076	2021-08-30 15:22:17	00:18:09	00:03:13	51.056	0	22.3258
1077	2021-08-30 15:22:18	00:18:11	00:03:15	51.057	0	22.3258
1078	2021-08-30 15:22:19	00:18:11	00:03:15	51.057	0	22.3258
1079	2021-08-30 15:22:20	00:18:13	00:03:17	51.058	0	22.3258
1080	2021-08-30 15:22:21	00:18:13	00:03:17	51.058	0	22.3258
1081	2021-08-30 15:22:22	00:18:15	00:03:19	51.059	0	22.3258
1082	2021-08-30 15:22:23	00:18:15	00:03:19	51.06	0	22.3258
1083	2021-08-30 15:22:24	00:18:17	00:03:21	51.062	0	22.3258
1084	2021-08-30 15:22:25	00:18:17	00:03:21	51.062	0	22.3258
1085	2021-08-30 15:22:26	00:18:19	00:03:23	51.063	0	22.3258
1086	2021-08-30 15:22:27	00:18:20	00:03:24	51.063	0	22.3258
1087	2021-08-30 15:22:28	00:18:21	00:03:25	51.063	0	22.3258
1088	2021-08-30 15:22:29	00:18:22	00:03:26	51.063	0	22.3258
1089	2021-08-30 15:22:30	00:18:23	00:03:27	51.065	0	22.3258
1090	2021-08-30 15:22:31	00:18:24	00:03:28	51.066	0	22.3258
1091	2021-08-30 15:22:32	00:18:25	00:03:29	51.067	0	22.3258
1092	2021-08-30 15:22:33	00:18:26	00:03:30	51.067	0	22.3258
1093	2021-08-30 15:22:34	00:18:27	00:03:31	51.067	0	22.3258
1094	2021-08-30 15:22:35	00:18:28	00:03:32	51.068	0	22.3258
1095	2021-08-30 15:22:36	00:18:29	00:03:33	51.069	0	22.3258
1096	2021-08-30 15:22:37	00:18:30	00:03:34	51.069	0	22.3258
1097	2021-08-30 15:22:38	00:18:31	00:03:35	51.071	0	22.3258
1098	2021-08-30 15:22:39	00:18:32	00:03:36	51.072	0	22.3258
1099	2021-08-30 15:22:40	00:18:33	00:03:37	51.073	0	22.3258
1100	2021-08-30 15:22:41	00:18:34	00:03:38	51.074	0	22.3258
1101	2021-08-30 15:22:42	00:18:35	00:03:39	51.074	0	22.3258
1102	2021-08-30 15:22:43	00:18:36	00:03:40	51.074	0	22.3258
1103	2021-08-30 15:22:44	00:18:37	00:03:41	51.075	0	22.3258
1104	2021-08-30 15:22:45	00:18:38	00:03:42	51.075	0	22.3258
1105	2021-08-30 15:22:46	00:18:39	00:03:43	51.075	0	22.3258
1106	2021-08-30 15:22:47	00:18:40	00:03:44	51.076	0	22.3258
1107	2021-08-30 15:22:48	00:18:41	00:03:45	51.077	0	22.3258
1108	2021-08-30 15:22:49	00:18:42	00:03:46	51.078	0	22.3258
1109	2021-08-30 15:22:50	00:18:43	00:03:47	51.079	0	22.3258
1110	2021-08-30 15:22:51	00:18:44	00:03:48	51.079	0	22.3258
1111	2021-08-30 15:22:52	00:18:45	00:03:49	51.081	0	22.3258
1112	2021-08-30 15:22:53	00:18:46	00:03:50	51.082	0	22.3258
1113	2021-08-30 15:22:55	00:18:47	00:03:51	51.083	0	22.3258
1114	2021-08-30 15:22:56	00:18:48	00:03:52	51.084	0	22.3258
1115	2021-08-30 15:22:57	00:18:49	00:03:53	51.084	0	22.3258
1116	2021-08-30 15:22:58	00:18:50	00:03:54	51.085	0	22.3258
1117	2021-08-30 15:22:59	00:18:51	00:03:55	51.085	0	22.3258
1118	2021-08-30 15:23:00	00:18:52	00:03:56	51.085	0	22.3258
1119	2021-08-30 15:23:01	00:18:53	00:03:57	51.086	0	22.3258
1120	2021-08-30 15:23:02	00:18:54	00:03:58	51.087	0	22.3258
1121	2021-08-30 15:23:03	00:18:55	00:03:59	51.087	0	22.3258
1122	2021-08-30 15:23:04	00:18:56	00:04:00	51.088	0	22.3258
1123	2021-08-30 15:23:05	00:18:57	00:04:01	51.088	0	22.3258
1124	2021-08-30 15:23:06	00:18:58	00:04:02	51.089	0	22.3258
1125	2021-08-30 15:23:07	00:18:59	00:04:03	51.09	0	22.3258
1126	2021-08-30 15:23:08	00:19:00	00:04:04	51.09	0	22.3258

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1127	2021-08-30 15:23:09	00:19:01	00:04:05	51.09	0	22.3258
1128	2021-08-30 15:23:10	00:19:02	00:04:06	51.09	0	22.3258
1129	2021-08-30 15:23:11	00:19:03	00:04:07	51.09	0	22.3258
1130	2021-08-30 15:23:12	00:19:04	00:04:08	51.091	0	22.3258
1131	2021-08-30 15:23:13	00:19:05	00:04:09	51.092	0	22.3258
1132	2021-08-30 15:23:14	00:19:06	00:04:10	51.093	0	22.3258
1133	2021-08-30 15:23:15	00:19:07	00:04:11	51.094	0	22.3258
1134	2021-08-30 15:23:16	00:19:08	00:04:12	51.094	0	22.3258
1135	2021-08-30 15:23:17	00:19:09	00:04:13	51.095	0	22.3258
1136	2021-08-30 15:23:18	00:19:10	00:04:14	51.095	0	22.3258
1137	2021-08-30 15:23:19	00:19:11	00:04:15	51.095	0	22.3258
1138	2021-08-30 15:23:20	00:19:12	00:04:16	51.096	0	22.3258
1139	2021-08-30 15:23:21	00:19:13	00:04:17	51.096	0	22.3258
1140	2021-08-30 15:23:22	00:19:14	00:04:18	51.096	0	22.3258
1141	2021-08-30 15:23:23	00:19:15	00:04:19	51.097	0	22.3258
1142	2021-08-30 15:23:24	00:19:16	00:04:20	51.098	0	22.3258
1143	2021-08-30 15:23:25	00:19:17	00:04:21	51.1	0	22.3258
1144	2021-08-30 15:23:26	00:19:18	00:04:22	51.1	0	22.3258
1145	2021-08-30 15:23:27	00:19:19	00:04:23	51.101	0	22.3258
1146	2021-08-30 15:23:28	00:19:20	00:04:24	51.102	0	22.3258
1147	2021-08-30 15:23:29	00:19:21	00:04:25	51.102	0	22.3258
1148	2021-08-30 15:23:30	00:19:22	00:04:26	51.102	0	22.3258
1149	2021-08-30 15:23:31	00:19:23	00:04:27	51.102	0	22.3258
1150	2021-08-30 15:23:32	00:19:24	00:04:28	51.103	0	22.3258
1151	2021-08-30 15:23:33	00:19:25	00:04:29	51.105	0	22.3258
1152	2021-08-30 15:23:34	00:19:26	00:04:30	51.105	0	22.3258
1153	2021-08-30 15:23:35	00:19:27	00:04:31	51.105	0	22.3258
1154	2021-08-30 15:23:36	00:19:28	00:04:32	51.106	0	22.3258
1155	2021-08-30 15:23:37	00:19:29	00:04:33	51.106	0	22.3258
1156	2021-08-30 15:23:38	00:19:30	00:04:34	51.106	0	22.3258
1157	2021-08-30 15:23:39	00:19:31	00:04:35	51.107	0	22.3258

2 pcs 51.2V30Ah Parallels connected into 51.2v60Ah Discharging with 3C 180A Testing



1158	2021-08-30 15:23:40	00:19:32	00:04:36	51.107	0	22.3258
1159	2021-08-30 15:23:41	00:19:33	00:04:37	51.107	0	22.3258
1160	2021-08-30 15:23:42	00:19:34	00:04:38	51.107	0	22.3258
1161	2021-08-30 15:23:43	00:19:35	00:04:39	51.109	0	22.3258
1162	2021-08-30 15:23:44	00:19:36	00:04:40	51.11	0	22.3258
1163	2021-08-30 15:23:45	00:19:37	00:04:41	51.111	0	22.3258
1164	2021-08-30 15:23:46	00:19:38	00:04:42	51.112	0	22.3258
1165	2021-08-30 15:23:47	00:19:39	00:04:43	51.112	0	22.3258
1166	2021-08-30 15:23:48	00:19:40	00:04:44	51.112	0	22.3258
1167	2021-08-30 15:23:49	00:19:41	00:04:45	51.112	0	22.3258
1168	2021-08-30 15:23:50	00:19:42	00:04:46	51.112	0	22.3258
1169	2021-08-30 15:23:51	00:19:43	00:04:47	51.112	0	22.3258
1170	2021-08-30 15:23:52	00:19:44	00:04:48	51.112	0	22.3258
1171	2021-08-30 15:23:53	00:19:45	00:04:49	51.113	0	22.3258
1172	2021-08-30 15:23:54	00:19:46	00:04:50	51.113	0	22.3258
1173	2021-08-30 15:23:55	00:19:47	00:04:51	51.114	0	22.3258
1174	2021-08-30 15:23:56	00:19:48	00:04:52	51.114	0	22.3258
1175	2021-08-30 15:23:57	00:19:49	00:04:53	51.115	0	22.3258
1176	2021-08-30 15:23:58	00:19:50	00:04:54	51.116	0	22.3258
1177	2021-08-30 15:23:59	00:19:51	00:04:55	51.117	0	22.3258
1178	2021-08-30 15:24:00	00:19:52	00:04:56	51.117	0	22.3258
1179	2021-08-30 15:24:01	00:19:53	00:04:57	51.117	0	22.3258
1180	2021-08-30 15:24:02	00:19:54	00:04:58	51.117	0	22.3258
1181	2021-08-30 15:24:03	00:19:55	00:04:59	51.117	0	22.3258
1182	2021-08-30 15:24:04	00:19:56	00:00:00	47.811	-180.086	22.3281
1183	2021-08-30 15:24:05	00:19:57	00:00:01	47.787	-180.078	22.3781
1184	2021-08-30 15:24:06	00:19:58	00:00:02	47.706	-180.003	22.4282
1185	2021-08-30 15:24:07	00:20:00	00:00:03	47.602	-180.003	22.4782
1186	2021-08-30 15:24:08	00:20:00	00:00:04	47.488	-180.021	22.5282
1187	2021-08-30 15:24:09	00:20:02	00:00:05	47.371	-180.008	22.5782
1188	2021-08-30 15:24:10	00:20:02	00:00:06	47.253	-180.024	22.6282
1189	2021-08-30 15:24:11	00:20:04	00:00:07	47.136	-180.023	22.6783
1190	2021-08-30 15:24:12	00:20:04	00:00:08	47.021	-180.064	22.7283
1191	2021-08-30 15:24:13	00:20:06	00:00:09	46.857	-180.039	22.7784
1192	2021-08-30 15:24:14	00:20:06	00:00:10	46.75	-180.002	22.8284
1193	2021-08-30 15:24:15	00:20:08	00:00:11	46.648	-180.045	22.8534
1194	2021-08-30 15:24:16	00:20:08	00:00:12	46.549	-180.098	22.9285
1195	2021-08-30 15:24:17	00:20:10	00:00:13	46.451	-180.065	22.9786
1196	2021-08-30 15:24:18	00:20:10	00:00:14	46.355	-180.072	23.0286
1197	2021-08-30 15:24:19	00:20:12	00:00:15	46.265	-180.064	23.1036
1198	2021-08-30 15:24:20	00:20:12	00:00:16	46.13	-180.079	23.1536
1199	2021-08-30 15:24:21	00:20:14	00:00:17	46.042	-180.04	23.2036
1200	2021-08-30 15:24:22	00:20:14	00:00:18	45.956	-180.042	23.2286
1	2021-08-30 15:26:23	00:00:00	00:00:00	49.389	0	24.2922
2	2021-08-30 15:26:33	00:00:10	00:00:00	49.411	0	0
3	2021-08-30 15:26:42	00:00:19	00:00:09	49.429	0	0
4	2021-08-30 15:26:43	00:00:20	00:00:00	46.015	-180.084	0.0095
5	2021-08-30 15:26:44	00:00:21	00:00:01	45.95	-180.015	0.0596
6	2021-08-30 15:26:45	00:00:22	00:00:02	45.843	-180.008	0.0846
7	2021-08-30 15:26:46	00:00:23	00:00:03	45.711	-180.048	0.1596
8	2021-08-30 15:26:47	00:00:24	00:00:04	45.565	-180.007	0.2097
9	2021-08-30 15:26:48	00:00:25	00:00:05	45.411	-180.076	0.2597
10	2021-08-30 15:26:49	00:00:26	00:00:06	45.332	-180.085	0.3097
11	2021-08-30 15:26:50	00:00:27	00:00:07	45.172	-180.023	0.3598
12	2021-08-30 15:26:51	00:00:28	00:00:08	45.008	-180.095	0.4098
13	2021-08-30 15:26:52	00:00:29	00:00:09	44.842	-180.036	0.4598
14	2021-08-30 15:26:53	00:00:30	00:00:10	44.678	-180.041	0.5098
15	2021-08-30 15:26:54	00:00:31	00:00:11	44.508	-179.99	0.5598
16	2021-08-30 15:26:55	00:00:32	00:00:12	44.333	-179.961	0.6098
17	2021-08-30 15:26:56	00:00:33	00:00:13	44.153	-179.991	0.6599